

Massachusetts  
Water Resources Authority

Industrial Waste Report



October 2022

*Industrial Waste Report # 38*

# Industrial Waste Report

**Number 38**

October 2022

Frederick A. Laskey  
Executive Director

David W. Coppes  
Chief Operating Officer

Carolyn McAvoy Fiore  
Deputy Chief Operating Officer

Matthew Dam  
Director, Toxic Reduction and Control

Tracy McGrath  
Senior Program Manager, Compliance

## **MASSACHUSETTS WATER RESOURCES AUTHORITY**

NPDES Permit Number MA0103284  
State Permit Number M-44

NPDES Permit Number MA0100404  
State Permit Number M-139



# FY 2022 Annual Report

## Table of Contents

Executive Summary .....	i
I. Pretreatment Program Activities and Results .....	1
Industrial Users .....	1
Permitting .....	2
Inspections .....	3
Monitoring .....	4
Enforcement .....	5
Information Systems .....	5
Legal Support .....	6
Local Limits .....	6
Emergency Response .....	6
Pass-Through and Interference .....	7
Pretreatment Program Resources .....	7
Budget .....	8
Program Cost Recovery .....	8
FY21 Accomplishments .....	9
II. Pollutant Analysis and Comparison to Environmental Standards .....	10
Priority Pollutant Scans .....	10
Toxicity .....	12
Residuals Quality .....	13

# FY 2022 TRAC Annual Report

## Table of Appendices

- A. SIU Data:
  - Permit number and date issued*
  - Sample location descriptions*
  - Reasons for SIU status*
  - SNC Status*
  - Inspection and monitoring dates*
  - Enforcement actions*
  - Deadline for compliance with schedules*
  - NOV dates*
  - Administrative order dates*
  - Dates and amounts of penalties assessed*
- B. Non-SIU Permitted Industrial Sewer Users
  - Permit category*
  - Sample location descriptions*
  - Sampling requirements*
  - Discharge violations*
  - Enforcement actions*
- C. Significant Industrial Users in Significant Noncompliance
- D. Former Significant Industrial Users
- E. Gas/Oil Separator Warning Letters
- F. Penalties Assessed and Collected
- G. TRAC Staff
- H. Priority Pollutant Scan Results and Comparison of Influent and Effluent to Established standards  
Deer Island
- I. Priority Pollutant Scan Results and Comparison of Influent and Effluent to Established standards  
Clinton
- J. Effluent Toxicity Test Results
- K. Comparison of Sludge Quality to EPA and State Standards
- L. Summary of EPA program statistics and EPA Industrial Pretreatment Program  
Summary Report Form, *Metropolitan Boston Service Area, Clinton Service Area*
- M. Local Limits
  - Metropolitan Area: Corrected MAHLs based on DITP Recycle Stream Loadings (2001) and Discharge Limitations/Local Limits from the MWRA Sewer Use Rules and Regulations (Metropolitan Area)*
  - Clinton Area: Discharge Limitations/Local Limits from the MWRA Sewer Use Rules and Regulations (specific to Clinton)*

# Executive Summary

This Industrial Pretreatment Program Annual Report is provided pursuant to 40 CFR 403.12(i) and Massachusetts Water Resources Authority's (MWRA's) National Pollutant Discharge Elimination System (NPDES) Permit numbers MA0103284 and MA0100404. It covers the reporting period of July 1, 2021 through June 30, 2022 (Fiscal Year (FY) 22).

## **Executive Summary and Program Highlights**

The FY22 report documents MWRA's ongoing efforts to implement the requirements of 40 CFR Part 403, General Pretreatment Regulations. Some highlights from the MWRA's Toxic Reduction and Control (TRAC) Department's FY22 activities in the Metropolitan Boston and Clinton sewerage services areas include:

MWRA's TRAC Department is responsible for implementing MWRA's industrial pretreatment program. Fiscal year 2022 presented challenges due to staffing issues. With respect to staffing, during FY22 MWRA experienced turnover in 17 positions due to retirement, resignation, or promotion. In FY22, 14 positions were backfilled, while three positions are currently vacant. MWRA is actively trying to fill the vacant positions. Despite these staffing issues, TRAC was able to inspect all SIUs and perform all required SIU monitoring.

**Significant Industrial Users:** The number of facilities designated as Significant Industrial Users (SIUs) in MWRA's sewer service areas at any time during FY22 was 184, three of which discharged to the Clinton Wastewater Treatment Plant. At the end of the fiscal year, the number of SIUs was 181. TRAC staff inspected 184 SIUs and sampled 159 SIUs. In FY22, 25 SIUs were not sampled for the following reasons: three discharging SIUs did not discharge during the year; two industries went out of business early in the fiscal year without adequate time to sample; and 20 SIUs hold non-discharging SIU permits and therefore cannot be sampled by MWRA. The number of SIUs in Significant Noncompliance (SNC) in FY22 was 30, an increase from the 26 FY21.

**Permitting:** TRAC issued or renewed a total of 350 industrial permits during FY22, including 82 permits to SIUs located in the Metropolitan Boston sewerage service area. Fifty percent of the SIU permits were issued within 120 days of their application received dates or previous expiration dates, whichever was later, and 83 percent were issued within 180 days. Permit issuance was delayed due in part to staff vacancies, delays in receiving critical data needed for permit processing, delays relating to new startup operations, and the late payment of the permit charges. Two permits were issued in the Clinton service area. One permit was issued in 90 days, consistent with the requirements of the Clinton NPDES permit effective March 1, 2017. TRAC issued one permit outside the 90-day timeframe due to late payment of the permit fee by the permittee.

**Monitoring and Inspections:** TRAC staff completed 1,452 sampling events at industrial/commercial facilities and 1,472 non-industrial sampling events (e.g., combined sewer overflow and other special project events). TRAC staff also completed a total of 1,436 inspections of industrial facilities; 554 inspections of oil/water separators at vehicle maintenance facilities and other garages; and 119 inspections of septage haulers and septage receiving sites.

Enforcement Program: TRAC issued a total of 224 Notices of Violations and 14 higher-level enforcement actions (13 Notices of Noncompliance, and 1 Penalty Assessment Notice) to industrial and commercial facilities. SIUs received 103 Notices of Violation and 7 higher level enforcement actions (7 Notices of Noncompliance). TRAC identified 45 gas/oil separators requiring Trap Warning Letters due to identified issues with maintenance or accessibility. In all of these cases, the facility was notified verbally that maintenance was required to be performed. Due to staff vacancies in the Traps group, and setting the focus on SIU permits, issuing the warning letters was delayed into FY23. They have since been issued. The number of enforcement actions TRAC issues varies from year to year.

#### FY22 Accomplishments:

##### Industrial Pretreatment Program Audit:

On October 5-7, 2021, EPA New England's consultant, PG Environmental, conducted an Industrial Pretreatment Program Audit of the TRAC program. EPA's consultant reviewed six permits. During the audit debrief, EPA reviewed its findings with TRAC staff. A report documenting only minor audit findings from EPA was issued February 24, 2022. All audit requirements and recommendations are being addressed and will be in place by December 1, 2022.

##### CROMERR Compliance:

MWRA is in the final stages of implementing its Cross Media Electronic Reporting Rule (CROMERR) compliant WebSMR application for accepting electronic data from laboratories submitting wastewater sampling results on behalf of TRAC permitted industrial users. After performing a successful pilot test early in FY22, the final group of laboratories is registering to submit CROMERR compliant electronic data. The next step is to seek EPA approval.

##### Dental Discharges Group Permit

FY22 was the first year that the new Dental Discharge group permit compliance report was due from over 750 permitted dental facilities. This biannual compliance report is a MWRA sewer use discharge permit requirement of the Dentist group permit that was issued for the first time in FY20. Reporting requirements were sent to all permittees on March 21, 2022. Currently, 66% of compliance reports have been returned. Since this was the first year of the compliance requirement, the missing reports are likely due to permittees being unfamiliar with the process or dentists ceasing operations. TRAC staff have been contacting the remaining dental facilities to remind them of this requirement and verify their operation.

Staffing: TRAC ended FY22 with 3 vacancies due to retirements and promotions. All 3 vacancies are anticipated to be filled in FY23.

## Section I.

# Pretreatment Program Activities and Results



## **Section I. Pretreatment Program Activities and Results**

A detailed accounting of the pretreatment program activities and accomplishments for MWRA's Industrial Users (including Significant Industrial Users or SIUs), during FY22 is presented below.

Appendix A contains information on MWRA's SIUs, and provides, in its Key, criteria for SIU status and compliance status codes. The Appendix provides information about why the facility is a SIU and whether it is in compliance with reporting requirements, categorical standards and local limits, dates of MWRA inspections and monitoring events for each facility, and what, if any, enforcement actions were taken by MWRA against the facility. Appendix B details all permitted industrial users not classified as SIUs. The information includes a description of the sampling locations and sampling requirements for each industry, any discharge violations during the year, and all enforcement actions taken against them during the year. Each SIU is inspected at least once per fiscal year and each SIU with a discharge to the sewer system is sampled at least once per fiscal year.

Statistics on MWRA's SIUs and the number of SIUs in Significant Noncompliance (SNC) for FY22 for the Clinton and the Metropolitan Boston sewerage service areas are summarized below. The list of SIUs in SNC can be found in Appendix C.

### **Industrial Users in FY22**

Total number of permitted industrial users = 2294

- The number of SIUs = 184 (3 in Clinton)
- The number of SIUs on June 30, 2022 = 181 (3 in Clinton)
- The number of SIUs that were Categorical Industrial Users (CIUs) = 70 (1 in Clinton)
- Industries categorized as SIUs because of process flows of at least 25,000 gallons per day (gpd) = 49 (0 in Clinton)
- Industries categorized as SIUs for Potential To Violate (PTV) = 98 (2 in Clinton)
- The number of SIUs in SNC = 30 (0 in Clinton)
- The number of industries in SNC for reporting violations only = 7 (0 in Clinton)
- The number of SIUs in SNC for discharge violations = 23 (0 in Clinton)
- The number of SIUs in SNC in the 4<sup>th</sup> Quarter = 10

The EPA Pretreatment Annual Report Summary forms are attached to the end of this report as Appendix L. A list of permitted users that were SIUs in FY21, but not in FY22, is attached as Appendix D.

MWRA typically holds annual educational meetings with SIUs to review and reinforce methods for staying in compliance. MWRA is planning to host virtual SIU meetings during the fall of 2022. The FY22 SIU meetings were postponed due to the COVID-19 pandemic.

## Permitting

Appendix A provides permit issuance and expiration dates for all SIUs. In FY22, 82 SIU permits were issued in the Metropolitan Boston sewerage service area. TRAC issued 50



Figure 1: SIU inspection of silver recovery unit

percent of these SIU permits (41 permits) within 120 days of their application received dates or previous expiration dates, whichever was later, and 83 percent (68 permits) within 180 days of their application received dates or previous expiration dates, whichever was later. Permit issuance was delayed largely due to staff vacancies, although there were also delays in receiving critical data needed for permit processing, delays relating to new startup operations, and the late payment of the permit charges. Two Non-SIU permits were issued to industries in the Clinton area during FY22. TRAC issued one permit outside the 90-day timeframe due to late payment of permit fees by the permittee.

During FY22, TRAC completed the following permitting activities:

- Total industrial permits issued = 350
- Total industrial permit renewals = 198
- Industrial permit renewals or issued to SIUs = 82
- Industrial permits issued to new dischargers = 152, including:
  - 61 Group Permits for Dental Discharges
  - 3 Group Permits for Food Processing
- Industrial permits revised = 27
- Municipal permit renewals = 45
- Temporary Construction Dewatering permits issued or renewed = 13
- Permits issued to municipal drinking water treatment plants = 5

## Inspections

Appendix A provides dates of inspections for all SIUs. During FY22, TRAC completed the following inspection activities

Total Industrial Facility visits = 1,436

- Annual inspections of SIUs = 184
- Other SIU inspections<sup>1</sup> = 145
- Non-SIU inspections = 1,107
- Audits of G1 (photodevelopers and printers) facilities = 3
- Audits of G2 (food processors) facilities conducted = 18
- Industrial Survey inspections<sup>2</sup> = 71
- Visits with no inspections<sup>3</sup> = 72

Septage facility inspections = 119

- Septage receiving site inspections = 103
- Septage hauler inspections = 16

Oil/water separator (trap) inspections = 554

- Full trap inspections = 367
- New trap inspections = 108
- Trap visits with no inspection<sup>4</sup> = 79

---

<sup>1</sup> Other SIU inspections include those conducted for permitting, follow-up to a prior inspection, enforcement/compliance inspections, sample location inspections, spot inspections and/or to gather additional information from facility contacts.

<sup>2</sup> Industrial Survey inspections include visits to newly identified addresses with potential industrial or commercial sewer discharges and visits to addresses confirmed at one time to have had only sanitary discharges for re-confirmation of status.

<sup>3</sup> These visits include visits to deliver documents and/or confirm address/contact information.

<sup>4</sup> Trap visits with no inspections result from facilities that had traps in the past but have since had them removed, visits when the trap was inaccessible or a knowledgeable contact was unavailable, or visits when the facility was found closed at the time of the visit.

## Monitoring

During FY22, TRAC's sampling staff conducted routine and emergency sampling activities for the pretreatment program, as well as for other MWRA programs. Appendix



A provides information on the dates of all MWRA sampling events for each SIU.

A summary of sampling activities completed by the staff follows:

*Figure 2: Field training new staff*

- SIUs with flow sampled at least once<sup>5,6,7</sup> = 159
- Number of sample locations (connections) at SIUs sampled at least once = 421
- Number of sample locations at SIUs that were sampled more than once = 112
- Total number of sampling events at SIUs = 1,255
- Non-SIUs sampled once = 90
- Number of sample locations at Non-SIUs sampled = 106
- Total number of sampling events at Non-SIUs = 197
- Total number of industries sampled = 249
- Total number of sampling events at all industries = 1,452
- Sampling events in support of NPDES permits = 246
- Sampling events in response to emergencies = 1
- Sampling events for the MWRA Local Limits program = 258
- Sampling events for special projects = 794
- Total number of non-industrial events = 1,472

---

<sup>5</sup> Five facilities were not sampled during FY22. Prolorized New England, MBTA Wellington and MBTA Codman were not sampled because they did not discharge in FY22. GCP Applied Technologies was not sampled because they went out of business in FY22. Commonwealth of MA-DEP Northeast Region discharged for less than four months and discharge was ceased before sampling was scheduled.

<sup>6</sup> One facility became an SIU during FY22. Commonwealth of MA-DEP Northeast Region discharged for less than four months and discharge was ceased before sampling was scheduled.

<sup>7</sup> One SIU facility went out of business in FY22. GCP Applied Technologies was not sampled because they did not discharge before going out of business.

## **Enforcement**

In FY22, TRAC issued a total of 224 Notices of Violations to industrial and commercial users of the sewer system, and 14 higher level enforcement actions to regulated facilities. In FY22, TRAC identified 51 gas/oil separators requiring Trap Warning Letters due to identified issues with maintenance or accessibility. In all of these cases, the facility was notified verbally at the time of the inspection that maintenance was required to be performed. Follow up warning letters were delayed into FY23, but the list of recipients have been included in Appendix E to demonstrate that they have since been issued. The types of actions and the number of each type follows. Appendices A and B explain the various types of enforcement actions, provide information on which facilities received enforcement actions, and when and what type(s) of actions. Appendix F provides a list of penalties assessed and collected in FY22.

- Notices of Violation issued = 224 (103 to SIUs; 1 to SIUs in Clinton)
- Warning letters about gas/oil separator maintenance and accessibility = 45 (Appendix E)
- Penalty Assessment Notice = 1 (0 to SIUs)
  
- Notices of Noncompliance issued = 13 ( 7 to SIUs)
- Return to Permit Letters= 1 ( 0 to SIUs)
- Extension Letters = 8 ( 8 to SIUs)

## **Information Systems**

MWRA continues to utilize its Pretreatment Information Management System (PIMS) software to manage its pretreatment program. The system continues to be adapted to accommodate pretreatment program requirements. TRAC's in-house information systems staff are responsible for supporting system design and implementation, data entry, quality assurance, and project management and coordination.

EPA's Cross-Media Electronic Reporting (CROMERR) Regulations, promulgated in 2005, provide a legal framework for electronic reporting under Title 40 of the Code of Federal Regulations to EPA and state, tribal and local governments, including MWRA, that are authorized to administer federal programs. The regulation authorizes electronic reporting for environmental programs while creating a level of corporate and individual accountability for those submitting environmental data.

MWRA is in the final stages of implementing its Cross Media Electronic Reporting Rule (CROMERR) compliant WebSMR application for accepting electronic data from laboratories submitting wastewater sampling results on behalf of TRAC permitted industrial users. After performing a successful pilot test early in FY22, the final group of laboratories is registering to submit CROMERR compliant electronic data. The next step is to seek EPA approval.

## Legal Support

MWRA's Law Division provides legal and policy advice and counsel to TRAC managers and staff, and represents MWRA in pretreatment-related matters.

In FY22, Law Division work for TRAC included:

- Providing counsel and reviewing and commenting on TRAC penalty assessment notices, and on enforcement orders, notices of noncompliance, and rulings;
- Representing MWRA in requests for reconsideration/administrative appeals of penalty assessment notices, enforcement orders, notices of noncompliance and permits;
- Representing MWRA in settlement negotiations; and
- Tracking bankruptcy filings by MWRA permittees.

## Local Limits

In February 2022, the draft Medium Wastewater Treatment Facilities General Permit was issued for the Clinton Wastewater Treatment Plant. A renewal application for the Clinton



*Figure 1: Collecting ambient samples for NPDES permit compliance*

NPDES permit was submitted in August 2021, 6 months in advance of its expiration date. MWRA has continued to sample in anticipation of the renewed permit and will review local limits per the permit requirements upon its renewal.

In anticipation of renewal of our Deer Island Treatment Plant NPDES permits, MWRA staff have been sampling since 2005 to support an evaluation of existing Metropolitan Boston sewerage service area local limits. Those limits will be evaluated per EPA requirements established in the Deer Island NPDES Permit upon its renewal.

## Emergency Response

TRAC field staff are responsible for responding to emergency events, toxics releases, and spills to the sewer system. These releases may result in Interference (disabling of the treatment plant's facilities/processes), or Pass-Through (discharge of toxics through the treatment works into the receiving waters). Due to the abrupt and often hazardous nature of these events, they generally take precedence over normal monitoring and inspection activities. Chemical and oil spills also pose significant concerns to the collection and treatment systems, due to the possibility of explosion, toxic fumes, and facility damage. TRAC staff respond to these types of events to assess their potential to affect the sewerage system and downstream facilities. TRAC staff are an integral part of MWRA's emergency response organization and are trained to respond immediately to emergencies

posing a threat to public health, worker safety, and facility operation. A TRAC manager and two sampling associates, as well as a fully equipped sampling van are on-call 24 hours a day to respond to reported emergencies.

TRAC emergency responses may be initiated for both short-term, episodic releases and continuing events, which may potentially impact the Authority's collection and treatment system. During FY22 TRAC staff responded to three reported releases in the sanitary sewerage districts. These reports included:

1. On 10/13/21, TRAC received a call from Operations that a tanker had rolled over in the Brown Circle in Revere and ruptured discharging approximately 10,000 gallons of diesel fuel to the pavement. TRAC staff responded and with an inspection of the nearby sewer lines determined that while the fuel did impact the adjoining marsh, it did not enter the sewer system.
2. On 11/13/21, TRAC received a call from MWRA OCC of an oil spill in a basement in Quincy that had occurred sometime between 11/4 and 11/12. TRAC staff investigated by calling the responding environmental spill response company Riverhawk Environmental. It was determined from the phone conversation that Riverhawk had notified the DEP and Quincy DPW. After stopping the flow of oil they pumped out the remaining oil from the problem tanks and recovered 1 gallon from the trap. They TV'd the line from the building to the sewer line and saw no evidence of oil. They checked nearby manholes and saw no evidence of residual oil. Since no oil appeared to be remaining in the sewer no sampling team was sent to the site.
3. On 2/17/22, TRAC staff received a call from an industry to report that between 100 and 150 pounds of liquid chocolate spilled outside the facility and went into a nearby storm drain. TRAC notified MWRA Wastewater Operations of the spill. TRAC staff reported to confirm that the spill was being cleaned up by an Industry contracted cleanup company. Samples were collected downstream of the impacted storm drain.

### **Pass-Through and Interference**

There were no investigations of, nor were there any instances of, Pass-Through or Interference at the Deer Island Wastewater Treatment Plant or the Clinton Wastewater Treatment Plant in FY22.

### **Pretreatment Program Resources**

MWRA's TRAC Department is organized along a functional alignment. Presently, a Sr. Program Manager for Field Operations and Permitting oversees two Program Managers,

one for Monitoring and one for Inspections and Permitting. The Senior Program Manager also directly oversees the 8M and Direct Connections Group.

The Inspections Program Manager supervises 9 Industrial Coordinators, who conduct inspections and draft industrial permits, and three staff who are responsible for implementing MWRA's septage and gasoline/oil separator programs. The Monitoring Regional Manager oversees 13 monitoring staff who collect industrial and other wastewater samples.

A Sr. Program Manager for Compliance and Enforcement manages four Compliance Coordinators, as well as staff dedicated to file and data management. This group is primarily responsible for TRAC's enforcement proceedings. They review sampling data for permit compliance and draft Notices of Violations, Notices of Non-Compliance, calculate the dollar amounts of penalties, as well as oversee higher levels of enforcement in concert with the Legal Department. The Senior Program Manager is also responsible for TRAC's information management system, PIMS.

TRAC has 47 full-time permanent positions (see Appendix G). In FY22, there was significant turnover due to retirements, departures, and promotions, with a total of 14 positions vacant at some time during the year. There are three vacant positions at this time with plans to fill all three vacancies during this fiscal year.

### **Budget**

In FY22, the TRAC Department recovered \$2,693,958 or 56.6 percent of the Department's actual Current Expense Budget (CEB) spending (\$4,758,727) through Permit and Monitoring Charges.

### **Program Cost Recovery**

MWRA's Incentive and Other Charges Program continues to recover a substantial portion of MWRA's costs of inspecting, monitoring, and permitting industrial sewer users. The total adjusted amount billed under the program in FY22 was \$2,623,764, an increase from \$2,516,741 in FY21. As of September 2022, collections for FY22 bills were at \$2,741,460 (compared to \$2,566,229 in FY21), an approximate 104% recovery of the adjusted amount invoiced. The additional revenue is the result of payment of interest, payment of outstanding permitting and monitoring charges, and new industries opening in the service area.

TRAC's revised Sewer Use Regulations (360 CMR 10.000), promulgated September 6, 2019, included a 3 percent increase in all permitting and monitoring charges in FY22. In addition to the changes made in FY22, for the upcoming two fiscal years (2023, and 2024), permitting and monitoring charges will increase by an additional 3 percent in each year.



## **FY22 Accomplishments**

### **Industrial Pretreatment Program Audit:**

On October 5-7, 2021, EPA New England's consultant, PG Environmental, conducted an Industrial Pretreatment Program Audit of MWRA's Industrial Pretreatment Program. EPA staff reviewed six permits. During the audit debrief, EPA reviewed its findings with TRAC staff. A report documenting only minor audit findings from EPA was issued February 24, 2022. All requirements and recommendations are being addressed and will be in place by December 1, 2022.

### **CROMERR Compliance:**

MWRA is in the final stages of implementing its Cross Media Electronic Reporting Rule (CROMERR) compliant WebSMR application for accepting electronic data from laboratories submitting wastewater sampling results on behalf of TRAC permitted industrial users. After performing a successful pilot test early in FY22, the final group of laboratories is registering to submit CROMERR compliant electronic data. The next step is to seek EPA approval, which we anticipate doing in FY23.

### **Dental Discharges Group Permit**

FY22 was the first year that the new Dental Discharge group permit compliance report was due from over 750 permitted dental facilities. This biannual compliance report is a MWRA sewer use discharge permit requirement of the Dentist group permit that was issued for the first time in FY20. Reporting requirements were sent to all permittees on March 21, 2022. Currently, 66% of compliance reports have been returned. TRAC staff have been contacting the remaining 250 dental facilities to remind them of this requirement and verify their operation. As staff have seen with TRAC's other group permits, the first year of the biennial reporting requirement is challenging as facilities are unfamiliar with the process. Dental facilities have experienced high turnover since the initial permits were issued, which might explain some of the failures to report.

## Section II.

# Pollutant Analyses and Comparison to Environmental Standards

## Section II. Pollutant Analyses and Comparison to Environmental Standards

The MWRA's Environmental Quality Department (ENQUAL) evaluates the water quality and biological health of Massachusetts Bay, to ensure that the Deer Island discharge does not harm the marine environment. ENQUAL monitors water quality data from Boston Harbor, and the rivers tributary to the harbor, to assess the impacts of CSOs, and to track the effects of the Boston Harbor Project and the long-term CSO control plan on the harbor.

MWRA measures pollutant concentrations: (a) in the plant influent to determine if pollutants are present in quantities that could inhibit proper operation of the treatment facilities; (b) in the effluent to determine the effectiveness of its pollutant control measures and compliance with water quality standards; and (c) in the sludge to ensure it meets beneficial reuse criteria. This section discusses the results of the influent and effluent analyses.

### Priority Pollutants Scans

**Metropolitan Boston Service Area:** MWRA regularly performs scans for priority pollutants on Deer Island Treatment Plant (DITP) influent and effluent samples. Additional non-priority pollutants are analyzed in support of meeting receiving water quality goals and the beneficial reuse standards for plant biosolids.

Appendix H presents the analyses of influent and effluent samples from DITP using both EPA-approved methods and (for some organic contaminants) non-EPA-approved ultra-low detection methods. Results are presented as flow-weighted monthly averages of all the samples analyzed during the fiscal year. For levels below reporting limits, one half of the reporting limit for inorganic compounds or one tenth of the quantitation limit for organic compounds was substituted to calculate concentrations. This allows the data to be used without the less conservative assumption that non-detect values are zero. Analyses performed using non-EPA-approved ultra- low detection methods generally confirm that this methodology for handling non-detects is a conservative way to estimate the concentrations of otherwise non-detected pollutants.

**Influent:** As would be expected for a large urban system, fats, oils and grease, nutrients, and most metals were detected regularly. Of the samples analyzed using EPA-approved detection methods, acetone (used in paints, varnishes, and lacquers manufacturing) and benzoic acid (used primarily as a food preservative and in pharmaceutical and cosmetic preparations) were detected regularly. Benzyl alcohol (used as a general solvent for inks, paints, perfumes, and waxes), 4-methylphenol (*p*-cresol) (an intermediate in the manufacture of chemicals, dyes, plastics, and antioxidants), 2-butanone (methyl ethyl ketone) (widely used as a solvent and intermediate product in the manufacture of ketones and amines), and carbon disulfide (a chemical used in the manufacture of rayon, cellophane, rubber chemicals, and flotation chemicals), were detected in about a third of the samples. Phenol (used in plastics synthesis) and toluene (a solvent and a chemical used in the manufacture of benzene derivatives, dyes, and perfumes) were detected in less than 13% of the samples. Styrene (used in the manufacture of synthetic rubber, plastics, resins, and protective coatings) and trichlorethene (used in removing grease from metals and in the production of some textiles) were detected in two (less than 10%) of the samples.

Of the pesticides and PCBs in tests with EPA-approved methods, total AMP (Ambient Monitoring Plan) PCBs (20 PCB congeners specific to MWRA's ambient monitoring plan) were detected regularly. Alpha-chlordane and gamma-chlordane were detected periodically.

When characteristics of DITP influent are compared to literature inhibition values, analysis shows that the majority of parameters did not exceed the thresholds. Zinc exceeded the activated sludge inhibition threshold once in FY22. DITP did not experience any problems with process inhibition in either the sludge digestion or the activated sludge process during FY22. Appendix H includes a table comparing DITP's influent monthly average concentrations to inhibition values.

**Effluent:** The activated sludge secondary process removes from the effluent most of the organic pollutants and pesticides and PCBs. Of the samples analyzed with EPA-approved methods, total AMP PCBs were detected regularly. The activated sludge process also effectively removes metals. Removal rate for mercury was 97%, for aluminum and lead 94%, copper 88%, zinc and chromium 87%, silver 85%, cadmium 81%, and nickel 42%.

The DITP NPDES permit has no numerical permit limits for any priority pollutants except for arochlors because of the low concentrations in the effluent and high available dilution. In fact, toxic contaminants generally met water quality criteria in the effluent even before dilution. Copper is the only parameter that requires use of a dilution factor to meet water quality criteria. MWRA's NPDES permit allows for a 50:1 dilution for determining compliance with acute water quality standards and a 70:1 dilution for chronic water quality standards. Appendix H includes tables comparing DITP's effluent to both acute and chronic water quality standards.

**Clinton Treatment Plant:** MWRA also samples the Clinton Treatment Plant (CLTP) influent and effluent for conventional parameters, nutrients, and certain metals. Appendix I presents the results of these analyses.

**Influent:** Arsenic, copper, iron, and zinc were detected consistently. Aluminum and lead were detected in half of the samples. No other tested metals were detected. Appendix I-2 compares CLTP influent samples to literature inhibition values for its treatment processes. No parameters exceeded either the published acute inhibition level for the activated sludge or the sludge digestion processes in FY22.

**Effluent:** The advanced treatment process at Clinton effectively removes metals as well as phosphorus and ammonia.

Appendix I also includes tables comparing effluent concentrations with both acute and chronic water quality criteria. The CLTP NPDES permit allows for a 1.6:1 dilution for determining compliance with acute and chronic water quality criteria. In FY22, the CLTP effluent met all of the acute and chronic water quality standards for the Nashua River. To be conservative, half the reporting limit is used when determining compliance with water quality standards, resulting in four instances when the calculated value was above the cyanide standard, but there were no actual exceedances in FY22.

Prior to 2011, aluminum levels in the CLTP effluent had the potential to exceed water quality standards when the plant was using aluminum sulfate (alum) for phosphorus removal. In early May 2011, CLTP replaced alum with ferric chloride, which has been as effective at phosphorus removal as aluminum sulfate. Since that time, the effluent concentrations have been well below the water quality criteria of 200 µg/L and 368 µg/L for chronic and acute water quality standards respectively. The December 2016 NPDES permit requires stringent permit limits on phosphorus year-round and does not include a reporting requirement for aluminum. However, the permit prohibits the use of alum for phosphorus removal.

The current permit, has effluent limits for copper of 11.6 µg/L (average monthly) and 14.0 µg/L (maximum daily). There was one copper concentration exceedance in FY22.

## Toxicity

MWRA tests the acute and chronic toxicity of the DITP effluent every month and the CLTP effluent quarterly. Effluent toxicity provides an overall view of effluent quality, ensuring that the effluent does not adversely affect the receiving waters. The results of the Deer Island and Clinton toxicity tests for FY22 can be found in Appendix J.

Acute toxicity, or LC-50 (lethal concentration 50%), is the concentration of effluent in a sample that kills half of the test organisms over the duration of the test. Acute toxicity tests involve preparing a series of test concentrations by diluting effluent with control water. Groups of test organisms are exposed to each effluent concentration and a control for a specified period. Chronic toxicity, or NOEC (no observed effect concentration), measures the highest effluent concentration at which no observed chronic effects will occur at continuous exposure to test organisms (in a life-cycle or partial life-cycle). For example, a NOEC limit of 1.5% means that there should be no effect when 1.5% of the sample is effluent, and the remainder dilution water. Chronic tests evaluate toxicity based on sub-lethal effects (growth, reproduction, mortality), exposing test organisms to samples during a sensitive period in the life-cycle.

The MWRA DITP permit requires four tests for effluent toxicity testing each month. Two 48-hour acute static toxicity tests using the mysid shrimp (*Americamysis bahia*) and the inland silverside fish (*Menidia beryllina*) measure the short-term lethal effects caused by the effluent. A chronic survival and growth test using *Menidia* and a chronic fertilization test using the sea urchin (*Arbacia punctulata*) both measure subtle toxic impacts over a longer period of time. Any acute LC-50 below 50% (i.e. less than 50% concentration) or chronic NOEC below 1.5% (i.e. less than 1.5% effluent concentration) would violate the NPDES limit. There were no toxicity permit violations for DITP effluent in FY22.

The CLTP permit requires two tests for effluent toxicity using freshwater daphnid shrimp (*Ceriodaphnia dubia*) each quarter. The first, a 48-hour acute toxicity test, measures potential short-term lethal effects caused by the effluent. The second test includes a chronic survival and reproduction test that measures subtle toxic impacts over a longer period of time. Any acute LC-50 below 100% or chronic NOEC below 62.5% (i.e. less than 62.5% concentration) would violate the NPDES limit. There were no toxicity permit violations for CLTP effluent in FY22.

## **Residuals Quality**

EPA and the MassDEP regulate the quality of sewage biosolids intended for beneficial use. At the federal level, these products are governed by the Clean Water Act. These regulations establish quality criteria for several metals and for the degree of pathogen reduction. Federal and state regulations have adopted a two-tiered approach to biosolids regulation. Products meeting the strictest standards for all parameters (MassDEP Type I) may be distributed or marketed with few restrictions. Products meeting only the less-prohibitive Type II standards may be used as fertilizer, but additional distribution, use restrictions and management practices apply. During FY22, MWRA's biosolids met all applicable federal and state standards for unrestricted use as a fertilizer.

Federal and state limits for the distribution of biosolids as a MassDEP Type I Sludge with no limitations for land application are outlined in the tables found in Appendix K.

THIS PAGE IS INTENTIONALLY LEFT BLANK

**Town**

**Industry name Permit Number, Date last permit issued/expiration date\***

**Industry Address**

**National Pretreatment Categorical Standard:** *See description below*

**MWRA Category:** *See description of MWRA categories below*

**Sample locations:** *Sample location number and description of sampling location. Sample locations coded as “Unregulated” are only subject to MWRA limits. Sample locations coded as “Regulated” are subject to both Federal Categorical standards and MWRA limits.*

**Reason for SIU status:** *See descriptions of reasons for SIU status below*

**SNC:** *Yes, if industry was in significant noncompliance. See descriptions of SNC status below. Please note that the SNC quarters listed in Appendix A are inaccurate due to a database problem. Refer to Appendix C for the correct information.*

**Inspections:** *Dates the MWRA inspected the facility*

**Monitoring:** *Dates the MWRA took wastewater samples for analysis from the industry’s Sampling locations*

**Enforcement Actions:** *Dates and type of enforcement actions in the last two fiscal years (see description of enforcement actions below).*

- \* No permit issued date indicates that a permit application has been received and is currently in process. If the permit expired date is more than a month or two in the future, the industry is currently permitted but has recently been identified as an SIU and the permit is being reevaluated. If there is no permit expired date, it is a newly identified discharger to the sewer system.

**National Pretreatment Categorical Standards:**

The number refers to a section and subsection of 40 CFR in which EPA has specified limits on the quantities or concentrations of pollutants that may be discharged. The name after the number is the EPA description of the industrial subcategory to which the specified limits apply. This identification is made by individual sample location. Therefore, an industry may be regulated by more than one subsection. If no number appears here, but the reason for SIU status is CIU, it indicates that the industry has a regulated process, but that there is no flow to the sewer system.

**PSes:** *Pretreatment Standards for Existing Sources -Existing sources refers to a building, structure, facility or installation whose construction began prior to the date that the standards were proposed.*

**PSNs:** *Pretreatment Standards for New Sources -New Sources refers to a building, structure, facility or installation whose construction began after the standards were proposed.*

**MWRA Category:**

- Category 1: A sewer user whose process results in a discharge containing one or more substances in a concentration or quantity requiring pretreatment to meet the requirements of federal and local discharge limits.
- Category 2: A sewer user whose process results in a discharge containing one or more substances regulated by the MWRA at a concentration and quantity not requiring pretreatment to meet the requirements of federal and local discharge limits.
- Category 3: A sewer user whose process results in a discharge not containing a substance regulated by the MWRA or photoprocessors who can meet federal and local discharge limits with silver recovery units.
- Category 4: A sewer user without an industrial discharge to the sewer system.



**Reasons for SIU Status:**

*Possible reasons for an industry to be designated a Significant Industrial User:*

- CIU-#            An industrial user subject to Categorical Pretreatment Standards under 40 CFR, 403.6 and 40 CFR, Chapter I, subchapter N. Any industry that falls under these categories is considered an SIU whether or not they have flow. These industries are Categorical Industrial Users (CIUs).
- 25K or >25,000 gpd    An industry which discharges an average of 25,000 gallons per day or more of process wastewater to the sewer system (excluding sanitary, noncontact cooling and boiler blowdown wastewater;)
- PTV            An industry which is designated as such by the MWRA on the basis that the industrial user has a reasonable potential for adversely affecting the operation of the collection system or treatment plant, or violating any pretreatment requirement.

**Significant Noncompliance:**

*Possible reasons for an industry to be in Significant Noncompliance:*

- A.            Chronic violations of wastewater discharge limits, defined here as those in which 66% or more of all of the measurements taken during a six month period exceed (by any magnitude) the daily maximum limit or the average limit for the same pollutant parameter;
- B.            Technical Review Criteria (TRC) violations, defined here as those in which 33% or more of all of the measurements for each pollutant parameter taken during a six month period equal or exceed the product of the daily maximum limit or the average limit times the applicable TRC (TRC=1.4 for BOD, TSS, fats, oil and grease, and 1.2 for all other pollutants except for pH);
- C.            Any other violation of a pretreatment effluent limit (daily maximum or longer term average) that the MWRA determines has caused, alone or in combination with other discharges, interference or pass through (including endangering the health of treatment plant personnel or the general public);
- D.            Any discharge of a pollutant that has caused imminent endangerment to human health, welfare or to the environment or has resulted in the MWRA’s exercise of its emergency Authority to halt or prevent such discharge;
- E1.           Failure to meet, within 90 days after the schedule date, a permit milestone for starting construction.
- E2.           Failure to meet, within 90 days after the schedule date, a permit milestone for completing construction.
- E3.           Failure to meet, within 90 days after the schedule date, a permit milestone for attaining final compliance.
- E4.           Failure to meet, within 90 days after the schedule date, an enforcement milestone contained in a permit or enforcement order for starting construction.
- E5.           Failure to meet, within ninety days after the schedule date, a compliance milestone contained in an enforcement order for completing construction.
- E6.           Failure to meet, within ninety days after the schedule date, a compliance milestone contained in an enforcement order for attaining final compliance.

- F1. Failure to provide, within 45 days after the due date, required baseline monitoring reports.
- F2. Failure to provide, within 45 days after the due date, required 90 day compliance reports.
- F3. Failure to provide, within 45 days after the due date, required self-monitoring reports.
- F4. Failure to provide, within 45 days after the due date, required compliance schedule reports.
- G. Failure to accurately report noncompliance;
- H. Any other violation or group of violations which the MWRA determines will adversely affect the operation or implementation of the pretreatment program. The MWRA has used this description for those industries that failed to submit permit applications in accordance with the regulations.

**Enforcement Actions:**

The type of enforcement action selected to respond to a violation depends on a variety of factors including, but not necessarily limited to: magnitude of the violations, duration of the violations, compliance history of the sewer user, perceived good faith of the user, clarity of the user’s responsibility, and, where such issues arise, the effects of the violation on the receiving waters and/or the treatment works.

*TRAC’s enforcement options found in this report include:*

**Notice of Violation (NOV)**

This enforcement action is a letter to the user describing the violation and asking the user to identify the reason for the violation and what steps it will take to ensure that the violation will not recur.

**Notice of Noncompliance/Order to Take Corrective Action (NON/OTCA):**

This formal, written notice and order identifies which requirements the user has violated and specifies deadlines by which the user must come into compliance. It requires increased sampling and reporting of discharges by the user and the submission of a detailed report by the user on how and when it intends to achieve and maintain compliance with MWRA regulations.

**Enforcement Order (EO):**

Issued by the MWRA to an industry outlining violations and the actions the violator must take.

**Penalty Assessment Notice (PAN):**

Formal, written notice to an industry assessing civil monetary penalties.

**Supplemental Order to Comply (SOC):**

A further order, usually issued after a previous order fails to bring an industry into compliance. Often issued with a Penalty Assessment Notice (PAN).

**Administrative Orders (AO):**

These formal written orders include Enforcement Orders, Supplemental Orders, Orders to Take Corrective Action, Orders to Comply, and Cease and Desist Orders. They are sent as follow-ups to *NON/OTCA*'s as new information is obtained, or are sent in other instances where violations of MWRA regulations are taking place or threaten to take place. They often require increased sampling and reporting of discharges by the user and detailed schedules to achieve or maintain compliance with MWRA requirements. They may contain an order to stop a discharge or a violation.

**Notice of Proposed Permit Revocation (NPPR):**

Issued to an industry when violations are so severe or repetitive, that the MWRA must resort to revoking the industry's permit.

**Ruling on Request for Reconsideration of NON/OTCA/EO/SOC/NPPR:**

In response to an industry's appeal of an order or permit revocation, the Authority will issue its decision in the form of a Ruling on Request for Reconsideration of the order or permit revocation.

**Amended Ruling:**

An amendment to a ruling or order which modifies the original ruling.

**Compliance Schedule:**

Issued by the MWRA in a permit or a settlement agreement. It lists dates and milestones that an industry must meet to achieve compliance.

**Settlement Agreement:**

A formal document resolving violations and enforcement actions.

**Returned to Permit Letter:**

Notice to an industry that the industry has been relieved, in part or in full, of the sampling and reporting requirements of a prior enforcement action and can, therefore, return to those of its permit.

**Stipulated Penalties Under Agreement:**

Penalties which the settling parties agreed to pay for certain types of violations during the period of a settlement agreement.

**Interim Ruling on Req. for Reconsideration:**

These rulings resolve some but not all, issues appealed by an industry. A formal ruling will be issued later.

**Extension of NON/OTCA/EO/SOC/NPPR Letter:**

Extends dates in compliance order.

TRAC has the power to take other types of actions for violations, some of which are described below:

**Emergency Suspension:**

Sewer service may be immediately suspended after informal notice to the user if the discharge reasonably appears to present an imminent danger to health, public welfare or the environment, or if it threatens to interfere with the operation of the sewer system.

**Civil Court Action:**

TRAC may refer a case to the Attorney general for action in civil court, including injunctive relief, the collection of penalties, and the recovery of expenses. Referrals are seldom made because TRAC can issue and enforce administrative orders and financial penalties without court action.

**Criminal Action:**

TRAC may refer a case to the Attorney General's Office and the Environmental Crimes Strike Force for criminal charges to be brought against a user. Referrals are made for serious and intentional violations.

# Appendix A

## Significant Industrial Users

Includes:

- Permit # and Date
- Sample Location Description
  - Reason for SIU Status
    - SNC Status
    - Inspection Dates
    - Monitoring Dates
  - Enforcement Actions

## Allston

**Resilience Boston Inc, a subsidiary National Resilience Inc**

Facility ID: 44100358

500 Soldiers Field Road  
Allston, MA 02134

Permit: Issued: 12/12/2019 Expires: 11/15/2023 Amended: 08/19/2021  
Issued: 12/12/2019 Expires: 11/15/2023 Amended: 03/01/2021 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated  
0102 Boiler/Tower Blowdown Cogeneration Plant

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 26-Jul-2021  
28-Jul-2021  
21-Mar-2022

Monitoring: 0101 10-Aug-2021  
0101 28-Feb-2022  
0101 03-Mar-2022  
0101 04-Mar-2022  
0102 10-Aug-2021  
9100 28-Feb-2022

Enforcement Actions:

## Ashland

***Nyacol Nano Technologies Inc.***

Facility ID: 02003625

230 Megunko Road  
Ashland, MA 01721-0349

<u>Permit:</u>	Issued: 09/15/2022	Expires: 08/15/2026		
	Issued: 06/28/2018	Expires: 08/15/2022	Amended: 08/18/2021	Termination: 09/14/2022
	Issued: 06/28/2018	Expires: 08/15/2022		Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated antimony pentoxide and silica oxide colloid production

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 15-Sep-2021  
13-Apr-2022

<u>Monitoring:</u>	0101	27-Jul-2021
	0101	28-Jul-2021
	0101	31-Jan-2022
	0101	01-Feb-2022
	9100	31-Jan-2022

<u>Enforcement Actions:</u>	01-Oct-2020	Notice of Violation
	04-Feb-2021	Notice of Violation
	29-Mar-2021	Notice of Violation
	27-Aug-2021	Notice of Violation

## Bedford

**Anika Therapeutics, Inc.**

Facility ID: 03103603

32 Wiggins Avenue  
Bedford, MA 01730

Permit: Issued: 11/18/2019 Expires: 10/15/2023 Amended: 08/18/2021  
Issued: 11/18/2019 Expires: 10/15/2023 Termination: 08/18/2021

National Pretreatment Categorical Standards: 17-Aug-2015 to 439.47 D Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated mfg. and R&D of HA-based products

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 12-Jan-2022  
01-Jun-2022

Monitoring: 0101 07-Jul-2021

Enforcement Actions: 04-Aug-2021 Notice of Violation



<b>Cubic PV, Inc.</b>	Facility ID: 03103701
6 -8 Preston Court Bedford, MA 01730	

<u>Permit:</u>	Issued: 09/30/2022	Expires: 09/15/2026		
	Issued: 06/20/2018	Expires: 09/15/2022	Amended: 06/03/2022	Termination: 09/29/2022
	Issued: 06/20/2018	Expires: 09/15/2022	Amended: 08/18/2021	Termination: 06/02/2022
	Issued: 06/20/2018	Expires: 09/15/2022		Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated solar cell R&D wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 01-Dec-2021  
01-Jun-2022

<u>Monitoring:</u>	0101	08-Jul-2021
	0101	18-Oct-2021
	0101	19-Oct-2021
	0101	21-Mar-2022
	9100	21-Mar-2022

<u>Enforcement Actions:</u>	19-Oct-2020	Notice of Violation
	10-Mar-2021	Notice of Violation

**Entegris, Inc.**

Facility ID: 03403799

9 Crosby Drive  
Bedford, MA 01730

Permit: Issued: 05/26/2022 Expires: 03/15/2024  
Issued: 06/04/2018 Expires: 03/15/2022 Amended: 08/18/2021 Termination: 05/25/2022  
Issued: 06/04/2018 Expires: 03/15/2022 Termination: 08/18/2021

National Pretreatment Categorical Standards: 01-Sep-2013 to 433.17 A Metal Finishing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated Wastewater from specialty coatings manufacturing and a new membra  
0102 Process Wastewater - Regulated Wet Process Lab discharge

Reason for SIU Status: Is a Categorical Industrial User.

SNC: YES B Quarter: 4

Inspections: 06-Jul-2021  
01-Feb-2022

Monitoring: 0101 07-Jul-2021  
0101 26-Aug-2021  
0101 18-Oct-2021  
0101 19-Oct-2021  
0101 24-Jan-2022  
0101 31-Jan-2022  
0101 01-Feb-2022  
0102 07-Jul-2021  
9100 24-Jan-2022

Enforcement Actions: 31-Jul-2020 Notice of Violation  
13-Jul-2021 Notice of Violation  
14-Feb-2022 Notice of Violation  
23-Feb-2022 Notice of Noncompliance  
08-Apr-2022 Notice of Violation

<b>Instrumentation Laboratory</b>	Facility ID: 03403233
180 Hartwell Road Bedford, MA 01730	

Permit: Issued: 06/24/2021 Expires: 03/15/2023 Amended: 09/29/2022  
 Issued: 06/24/2021 Expires: 03/15/2023 Amended: 08/18/2021 Termination: 09/28/2022  
 Issued: 06/24/2021 Expires: 03/15/2023 Termination: 08/18/2021

National Pretreatment Categorical Standards: 05-Dec-2008 to 433.17 A Metal Finishing

MWRA Category: 01

Sample Locations:

0101	OTHER_DESC	RO reject water
	Process Wastewater - Unregulated	laboratory wastewater
	Process Wastewater - Unregulated	laboratory wastewater
0102	Process Wastewater - Unregulated	R&D of medical devices
0103	Process Wastewater - Regulated	platinizing line
0104	Process Wastewater - Unregulated	batch discharge from glass-cleaning unit

Reason for SIU Status: Is a CIU without flow., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 08-Sep-2021  
23-Mar-2022

Monitoring:

0101	07-Jul-2021
0101	18-Oct-2021
0101	19-Oct-2021
0101	21-Mar-2022
0102	08-Jul-2021
0104	07-Jul-2021
9100	21-Mar-2022

Enforcement Actions:

**N2 Biomedical, LLC**

Facility ID: 03004344

One Patriots Park  
Bedford, MA 01730

Permit: Issued: 04/11/2022 Expires: 12/15/2023  
Issued: 06/09/2020 Expires: 12/15/2021 Termination: 04/10/2022

National Pretreatment Categorical Standards: 05-Jan-2001 to 433.15 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated anodizing & ancillary operations  
Process Wastewater - Unregulated miscellaneous processes not covered by 433

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 01-Nov-2021  
12-May-2022

Monitoring: 0101 13-Aug-2021  
0101 18-Oct-2021  
0101 19-Oct-2021  
0101 31-Jan-2022  
9100 31-Jan-2022

Enforcement Actions: 14-Mar-2022 Notice of Violation

**Ocular Therapeutix Inc.**

Facility ID: 03403390

36 Crosby Drive Suite 101  
Bedford, MA 01730

Permit: Issued: 12/18/2019 Expires: 11/15/2023 Amended: 08/18/2021  
Issued: 12/18/2019 Expires: 11/15/2023 Termination: 08/18/2021

National Pretreatment Categorical Standards: 17-Jan-2019 to 439.47 D Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated  
0102 Process Wastewater - Unregulated  
0103 Process Wastewater - Regulated Non-discharging Fed Cat 439

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 08-Oct-2021  
22-Apr-2022

Monitoring: 0101 06-Jul-2021  
0102 05-Oct-2021

Enforcement Actions: 17-Jul-2020 Notice of Violation

<b>Thermo Fisher Scientific</b>	Facility ID: 03103123
2 Preston Court Bedford, MA 01730	

Permit: Issued: 09/30/2022 Expires: 09/15/2024  
 Issued: 01/21/2021 Expires: 09/15/2022 Amended: 08/18/2021 Termination: 09/29/2022  
 Issued: 01/21/2021 Expires: 09/15/2022 Termination: 08/18/2021

National Pretreatment Categorical Standards: 31-Jul-2003 to 414.45 D Organic Chemicals, Plastics, and Synthetic Fibers

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated OCPSF wastewater

Reason for SIU Status: Is a Categorical Industrial User.

SNC: YES B Quarter: 2

Inspections: 06-Jul-2021  
06-Jan-2022

Monitoring: 0101 06-Jul-2021  
0101 07-Jul-2021  
0101 18-Oct-2021  
0101 19-Oct-2021  
0101 14-Feb-2022  
9100 14-Feb-2022

Enforcement Actions: 08-Mar-2021 Notice of Violation  
12-May-2022 Notice of Violation

## Belmont

**Purecoat North, LLC**

Facility ID: 04001403

39 Hittinger Street  
Belmont, MA 02478

Permit: Issued: 06/06/2022 Expires: 06/15/2024  
Issued: 06/30/2020 Expires: 06/15/2022 Amended: 08/18/2021 Termination: 06/05/2022  
Issued: 06/30/2020 Expires: 06/15/2022 Termination: 08/18/2021

National Pretreatment Categorical Standards: 02-May-2009 to 433.17 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated Metal Finishing Operations  
OTHER\_DESC Metal Finishing Operations  
0103 OTHER\_DESC Cyanide Destruct Operations

Reason for SIU Status: Is a Categorical Industrial User., Flow greater than 25,000 gpd.

SNC: NO

Inspections: 05-Nov-2021  
02-May-2022

Monitoring: 0101 08-Jul-2021  
0101 09-Nov-2021  
0101 05-Jan-2022  
0101 14-Feb-2022  
0103 08-Jul-2021  
9100 14-Feb-2022

Enforcement Actions: 08-Feb-2021 Notice of Violation  
05-Apr-2021 Notice of Violation  
20-Sep-2021 Notice of Violation  
24-Sep-2021 Notice of Violation  
03-Nov-2021 Notice of Violation

## Boston (Dwntn)

<b>Beth Israel Deaconess Medical Center</b>	Facility ID: 45005703
330 Brookline Avenue Boston, MA 02215	

Permit: Issued: 06/06/2022 Expires: 02/15/2024  
Issued: 04/10/2020 Expires: 02/15/2022 Amended: 08/19/2021 Termination: 06/05/2022  
Issued: 04/10/2020 Expires: 02/15/2022 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0112	Process Wastewater - Unregulated	
	0113	Process Wastewater - Unregulated	
	0114	Process Wastewater - Unregulated	
	0301	Process Wastewater - Unregulated	Lab & cagewashing wastewater
	0303	Process Wastewater - Unregulated	clinical lab wastewater & CPD
	0901	Process Wastewater - Unregulated	Lab wastewater
	1001	Process Wastewater - Unregulated	CPD wastewater
	1101	Process Wastewater - Unregulated	CPD wastewater
	1201	Process Wastewater - Unregulated	CPD wastewater

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 15-Jul-2021  
24-Feb-2022

<u>Monitoring:</u>	0112	16-Aug-2021
	0112	17-Aug-2021
	0112	02-Dec-2021
	0112	03-Dec-2021
	0112	09-May-2022
	0113	17-Aug-2021
	0113	18-Aug-2021
	0113	03-Nov-2021
	0113	04-Nov-2021
	0114	16-Aug-2021
	0114	17-Aug-2021
	0114	04-Nov-2021
	0114	05-Nov-2021
	0301	02-Nov-2021
	0301	03-Nov-2021
	0301	14-Mar-2022
	0301	15-Mar-2022



**Beth Israel Deaconess Medical Center**

Facility ID: 45005703

330 Brookline Avenue  
Boston, MA 02215

0301	19-May-2022
0301	20-May-2022
0303	02-Nov-2021
0303	03-Nov-2021
0303	14-Mar-2022
0303	15-Mar-2022
0901	17-Aug-2021
0901	18-Aug-2021
0901	03-Nov-2021
0901	04-Nov-2021
0901	27-Jun-2022
1001	16-Aug-2021
1001	02-Dec-2021
1101	18-Aug-2021
1101	19-Aug-2021
1101	02-Dec-2021
1101	03-Dec-2021
9100	09-May-2022
9100	27-Jun-2022

<u>Enforcement Actions:</u>	16-Nov-2021	Notice of Violation
	02-Dec-2021	Notice of Violation
	20-Apr-2022	Notice of Noncompliance

**Boston Children's Hospital**

Facility ID: 45005920

300 Longwood Avenue  
Boston, MA 02115

<u>Permit:</u>	Issued: 06/25/2019	Expires: 05/15/2023	Amended: 05/17/2022	
	Issued: 06/25/2019	Expires: 05/15/2023	Amended: 10/21/2021	Termination: 05/16/2022
	Issued: 06/25/2019	Expires: 05/15/2023	Amended: 06/17/2021	Termination: 10/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

<u>Sample Locations:</u>	0102	Process Wastewater - Unregulated	
	0201	Process Wastewater - Unregulated	clinical labs and CPD wastewater
	0301	Process Wastewater - Unregulated	
	0402	Process Wastewater - Unregulated	pharmacy wastewater
	0501	Process Wastewater - Unregulated	Research labs & animal care labs
	0601	Process Wastewater - Unregulated	

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 13-Jul-2021  
16-Nov-2021  
21-Feb-2022

<u>Monitoring:</u>	0102	30-Sep-2021
	0102	01-Oct-2021
	0102	15-Feb-2022
	0102	16-Feb-2022
	0102	09-May-2022
	0301	25-Oct-2021
	0301	26-Oct-2021
	0301	17-Feb-2022
	0301	18-Feb-2022
	0501	30-Sep-2021
	0501	01-Oct-2021
	0501	15-Feb-2022
	0501	16-Feb-2022
	0601	28-Sep-2021
	0601	29-Sep-2021
	0601	15-Feb-2022
	0601	16-Feb-2022
	9100	09-May-2022

Enforcement Actions:

**Boston University - National Emerging Infectious Disease Lab**

Facility ID: 45403758

620 Albany Street  
Boston, MA 02118

Permit: Issued: 03/29/2022 Expires: 03/15/2024  
Issued: 05/06/2020 Expires: 03/15/2022 Amended: 08/19/2021 Termination: 03/28/2022  
Issued: 05/06/2020 Expires: 03/15/2022 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated research lab wastewater  
0102 Process Wastewater - Unregulated tissue digester wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 15-Sep-2021  
22-Feb-2022

Monitoring: 0101 06-Jan-2022  
0101 10-Jan-2022  
0101 11-Jan-2022  
0101 24-May-2022  
0101 25-May-2022

Enforcement Actions:

**Boston University Medical Campus**

Facility ID: 45006015

715 Albany Street  
Boston, MA 02118-2526

Permit: Issued: 06/17/2021 Expires: 02/15/2023 Amended: 08/19/2021  
Issued: 06/17/2021 Expires: 02/15/2023 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	Process Wastewater - Unregulated	
	0301	Process Wastewater - Unregulated	wastewater from R&D lab & cage washers
	0401	Process Wastewater - Unregulated	
	0601	Process Wastewater - Unregulated	
	0701	Process Wastewater - Unregulated	
	0801	Process Wastewater - Unregulated	
	1001	Process Wastewater - Unregulated	
	1101	Process Wastewater - Unregulated	Lab wastewater
	1201	Process Wastewater - Unregulated	dental instrument wash water

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: YES B Quarter: 3

Inspections: 01-Apr-2022  
23-May-2022

<u>Monitoring:</u>	0101	19-Jul-2021
	0101	20-Jul-2021
	0301	19-Jul-2021
	0301	20-Jul-2021
	0401	23-Jul-2021
	0401	02-Feb-2022
	0401	03-Feb-2022
	0601	21-Jul-2021
	0601	22-Jul-2021
	0601	01-Feb-2022
	0601	02-Feb-2022
	0701	20-Jul-2021
	0701	21-Jul-2021
	0701	20-Dec-2021
	0701	31-Jan-2022
	0801	21-Jul-2021
	0801	22-Jul-2021
	1001	20-Jul-2021
	1001	21-Jul-2021
	1001	26-Apr-2022

**Boston University Medical Campus**

Facility ID: 45006015

715 Albany Street  
Boston, MA 02118-2526

1001	27-Apr-2022
1001	17-May-2022
1001	18-May-2022
1101	21-Jul-2021
1201	22-Jul-2021
1201	23-Jul-2021
1201	02-Feb-2022
1201	03-Feb-2022

<u>Enforcement Actions:</u>	15-Jul-2020	Notice of Violation
	19-Aug-2020	Notice of Violation
	01-Mar-2021	Notice of Violation
	17-Sep-2021	Notice of Violation
	14-Mar-2022	Notice of Violation

**Brigham & Women's Hospital**

Facility ID: 45005731

75 Francis Street  
Boston, MA 02115

Permit: Issued: 02/25/2022 Expires: 08/15/2023  
Issued: 09/16/2019 Expires: 08/15/2021 Amended: 12/28/2020 Termination: 02/24/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0105	Process Wastewater - Unregulated	
	0701	Process Wastewater - Unregulated	
	1001	Process Wastewater - Unregulated	
	1301	Process Wastewater - Unregulated	
	1401	Process Wastewater - Unregulated	
	1402	Process Wastewater - Unregulated	co-gen plant discharge
	1501	Process Wastewater - Unregulated	
	1502	Process Wastewater - Unregulated	
	1601	Process Wastewater - Unregulated	laboratory wastewater

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 29-Jul-2021  
10-Feb-2022

<u>Monitoring:</u>	0105	17-Aug-2021
	0105	18-Aug-2021
	0105	16-Mar-2022
	0105	17-Mar-2022
	0105	23-May-2022
	0701	18-Aug-2021
	0701	19-Aug-2021
	0701	16-Mar-2022
	0701	17-Mar-2022
	0701	28-Apr-2022
	0701	29-Apr-2022
	0701	24-May-2022
	0701	25-May-2022
	1001	23-Nov-2021
	1001	27-Jun-2022
	1301	22-Nov-2021
	1301	23-Nov-2021
	1401	18-Aug-2021
	1401	19-Aug-2021
	1401	17-Mar-2022

**Brigham & Women's Hospital**

Facility ID: 45005731

75 Francis Street  
Boston, MA 02115

1401	18-Mar-2022
1402	12-Aug-2021
1402	13-Aug-2021
1501	24-Nov-2021
1502	24-Nov-2021
1601	14-Feb-2022
9100	23-May-2022
9100	27-Jun-2022

<u>Enforcement Actions:</u>	30-Jun-2020	Notice of Violation
	12-Aug-2020	Notice of Violation
	16-Sep-2020	Notice of Violation
	23-Sep-2020	Notice of Violation
	29-Oct-2020	Notice of Noncompliance
	17-Nov-2020	Notice of Violation
	17-Nov-2020	Notice of Violation
	30-Mar-2021	Returned to Permit Letter
	25-May-2021	Notice of Violation

**Dana-Farber Cancer Institute**

Facility ID: 45005701

450 Brookline Avenue  
Boston, MA 02215

<u>Permit:</u>	Issued: 10/19/2021	Expires: 07/15/2023	Amended: 09/07/2022	
	Issued: 10/19/2021	Expires: 07/15/2023		Termination: 09/06/2022
	Issued: 06/26/2019	Expires: 07/15/2021	Amended: 06/01/2021	Termination: 10/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0201	Process Wastewater - Unregulated	
	0203	Process Wastewater - Unregulated	
	0304	Process Wastewater - Unregulated	
	0403	Process Wastewater - Unregulated	
	0501	Process Wastewater - Unregulated	
	0503	Process Wastewater - Unregulated	
	0504	Process Wastewater - Unregulated	
	0601	Process Wastewater - Unregulated	
	0701	Process Wastewater - Unregulated	
	0801	Process Wastewater - Unregulated	
	0802	Process Wastewater - Unregulated	
	0803	Process Wastewater - Unregulated	Research lab effluent

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

<u>SNC:</u>	YES B	Quarter: 1
	F3	Quarter: 1
	B	Quarter: 3
	A	Quarter: 4
	B	Quarter: 4
	F3	Quarter: 4

Inspections: 07-Oct-2021  
14-Feb-2022

<u>Monitoring:</u>	0201	08-Jul-2021
	0201	09-Jul-2021
	0201	21-Dec-2021
	0201	22-Dec-2021
	0203	08-Jul-2021
	0203	09-Jul-2021
	0304	25-Oct-2021
	0304	26-Oct-2021
	0304	21-Dec-2021
	0304	22-Dec-2021
	0304	22-Mar-2022



**Dana-Farber Cancer Institute**

Facility ID: 45005701

450 Brookline Avenue  
Boston, MA 02215

0304	24-Mar-2022
0403	09-Jul-2021
0403	21-Dec-2021
0501	06-Jul-2021
0501	07-Jul-2021
0501	27-Jun-2022
0502	06-Jul-2021
0502	07-Jul-2021
0502	20-Dec-2021
0502	21-Dec-2021
0503	07-Jul-2021
0504	22-Jul-2021
0504	23-Jul-2021
0504	25-Oct-2021
0504	26-Oct-2021
0601	25-Oct-2021
0601	26-Oct-2021
0701	22-Jul-2021
0701	23-Jul-2021
0801	19-Jul-2021
0801	20-Jul-2021
0801	27-Oct-2021
0801	28-Oct-2021
0802	19-Jul-2021
0802	20-Jul-2021
0802	28-Oct-2021
0803	19-Jul-2021
0803	20-Jul-2021
0803	27-Oct-2021
0803	28-Oct-2021
9100	27-Jun-2022

<u>Enforcement Actions:</u>	08-Jul-2020	Extension of NON/OTCA/EO/SOC/NPPR Letter
	10-Nov-2020	Notice of Violation
	16-Dec-2020	Notice of Violation
	08-Feb-2021	Returned to Permit Letter
	01-Mar-2021	Notice of Violation
	15-Jul-2021	Notice of Violation
	01-Sep-2021	Notice of Violation
	08-Dec-2021	Notice of Violation
	10-Feb-2022	Notice of Noncompliance
	08-Mar-2022	Notice of Violation

**Harvard University - Longwood Campus**

Facility ID: 45005962

200 Longwood Avenue  
Boston, MA 02115

Permit: Issued: 03/23/2021 Expires: 01/15/2023 Amended: 08/19/2021  
Issued: 03/23/2021 Expires: 01/15/2023 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations:

0101	Process Wastewater - Unregulated
0201	Process Wastewater - Unregulated
0301	Process Wastewater - Unregulated
0401	Process Wastewater - Unregulated
0503	Process Wastewater - Unregulated
0601	Process Wastewater - Unregulated
0702	Process Wastewater - Unregulated
0703	Process Wastewater - Unregulated
0802	Process Wastewater - Unregulated
1101	Process Wastewater - Unregulated
1201	Process Wastewater - Unregulated

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: YES A Quarter: 3  
B Quarter: 3

Inspections: 29-Sep-2021  
18-Mar-2022

Monitoring:

0101	14-Oct-2021
0101	15-Oct-2021
0101	25-Jan-2022
0201	03-Jan-2022
0201	04-Jan-2022
0201	17-Mar-2022
0201	19-May-2022
0201	20-May-2022
0301	14-Oct-2021
0301	15-Oct-2021
0301	26-Jan-2022
0301	27-Jan-2022
0401	26-Jan-2022
0401	27-Jan-2022
0401	16-Mar-2022
0401	17-Mar-2022
0503	12-Oct-2021

**Harvard University - Longwood Campus**

Facility ID: 45005962

200 Longwood Avenue  
Boston, MA 02115

0503	13-Oct-2021
0601	12-Oct-2021
0601	13-Oct-2021
0601	11-Jan-2022
0601	12-Jan-2022
0702	12-Oct-2021
0702	13-Oct-2021
0702	25-Jan-2022
0702	26-Jan-2022
0703	12-Oct-2021
0703	16-Mar-2022
0802	14-Oct-2021
0802	26-Jan-2022
1101	12-Jan-2022
1101	13-Jan-2022
1101	27-Jan-2022
1101	28-Jan-2022
1201	14-Jan-2022
1201	27-Jan-2022
1201	28-Jan-2022

<u>Enforcement Actions:</u>	27-Oct-2020	Notice of Violation
	04-Nov-2020	Notice of Violation
	25-Nov-2020	Notice of Violation
	06-Aug-2021	Notice of Violation

**MATEP, LP**

Facility ID: 45005964

474 Brookline Avenue  
Boston, MA 02215

Permit: Issued: 10/04/2022 Expires: 08/15/2024  
Issued: 06/08/2020 Expires: 06/15/2022 Amended: 08/19/2021 Termination: 10/03/2022  
Issued: 06/08/2020 Expires: 06/15/2022 Amended: 09/25/2020 Termination: 08/19/2021

National Pretreatment Categorical Standards: 04-May-2007 to 423.16 A Steam Electric Power Generating

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Low Volume Waste Sources  
0202 Process Wastewater - Regulated Cooling tower blowdown & overflow  
0301 Process Wastewater - Unregulated Low Volume Waste Sources

Reason for SIU Status: Is a Categorical Industrial User., Flow greater than 25,000 gpd.

SNC: NO

Inspections: 02-Dec-2021  
09-May-2022

Monitoring: 0101 24-Aug-2021  
0101 25-Aug-2021  
0101 30-Nov-2021  
0101 01-Dec-2021  
0101 28-Feb-2022  
0202 24-Aug-2021  
0202 01-Feb-2022  
0301 24-Aug-2021  
0301 25-Aug-2021  
0301 30-Nov-2021  
0301 01-Dec-2021  
9100 28-Feb-2022

Enforcement Actions: 04-Aug-2020 Notice of Violation  
29-Apr-2021 Notice of Violation  
01-Sep-2021 Notice of Violation  
14-Mar-2022 Notice of Violation  
08-Jun-2022 Notice of Violation

**MBTA - Albany Street Bus Garage**

Facility ID: 45102178

421 Albany Street  
Boston, MA 02116

Permit: Issued: 03/16/2021 Expires: 03/15/2023 Amended: 08/19/2021  
Issued: 03/16/2021 Expires: 03/15/2023 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 19-Jul-2021  
19-Jan-2022

Monitoring: 0101 07-Jul-2021  
0101 19-Jan-2022  
0101 28-Feb-2022  
0101 07-Mar-2022  
9100 28-Feb-2022

Enforcement Actions:

**Massachusetts Department of Transportation, I-93 Tunnel**

Facility ID: 45103098

I-93 Central Artery Tunnel  
Boston, MA 02111

Permit: Issued: 02/07/2022 Expires: 12/15/2025  
Issued: 05/04/2020 Expires: 12/15/2021

Termination: 02/06/2022

National Pretreatment Categorical Standards:

MWRA Category: 02

<u>Sample Locations:</u>	0101	OTHER_DESC	Tunnel wash water, ground water, storm water runoff and air handling
	0201	OTHER_DESC	Wash water, ground water, storm water runoff and air handling plenum
	0301	OTHER_DESC	Wash water, ground water, storm water runoff and air handling plenum
	0401	OTHER_DESC	Tunnel wash water, ground water, storm water runoff and air handling
	0501	OTHER_DESC	Tunnel wash water, ground water, storm water runoff and air handling
	0601	OTHER_DESC	Tunnel wash water, ground water, storm water runoff and air handling

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 08-Dec-2021  
02-Jun-2022

<u>Monitoring:</u>	0101	18-Sep-2021
	0101	09-Oct-2021
	0101	22-Oct-2021
	0201	08-Oct-2021
	0201	22-Oct-2021
	0301	22-Oct-2021
	0301	09-Nov-2021
	0401	22-Oct-2021
	0401	09-Nov-2021
	0401	16-Nov-2021
	0501	16-Nov-2021
	0601	18-Sep-2021
	0601	22-Oct-2021

<u>Enforcement Actions:</u>	15-Jun-2021	Notice of Violation
	23-Jun-2021	Notice of Violation

**Massachusetts General Hospital**

Facility ID: 45005712

55 Fruit Street  
Boston, MA 02114

Permit: Issued: 03/16/2022 Expires: 01/15/2024  
Issued: 03/03/2020 Expires: 01/15/2022 Amended: 08/19/2021 Termination: 03/15/2022  
Issued: 03/03/2020 Expires: 01/15/2022 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	Process Wastewater - Unregulated	Laboratory effluent
	0104	Process Wastewater - Unregulated	Laboratory effluent
	0105	Process Wastewater - Unregulated	
	0301	Process Wastewater - Unregulated	
	0401	Process Wastewater - Unregulated	
	0402	Process Wastewater - Unregulated	
	0601	Process Wastewater - Unregulated	CPD effluent

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 16-Dec-2021  
19-May-2022

<u>Monitoring:</u>	0101	28-Oct-2021
	0101	29-Oct-2021
	0101	18-May-2022
	0101	19-May-2022
	0104	16-Feb-2022
	0104	17-Feb-2022
	0104	18-May-2022
	0104	19-May-2022
	0104	22-Jun-2022
	0104	23-Jun-2022
	0105	17-Feb-2022
	0105	22-Jun-2022
	0105	23-Jun-2022
	0301	28-Oct-2021
	0301	29-Oct-2021
	0301	22-Jun-2022
	0401	14-Oct-2021
	0402	14-Oct-2021
	0601	16-Feb-2022
	0601	17-Feb-2022

<b>Massachusetts General Hospital</b>	Facility ID:	45005712
55 Fruit Street Boston, MA 02114		

Enforcement Actions:      08-Feb-2021      Notice of Violation



**Northeastern University**

Facility ID: 45004837

360 Huntington Avenue  
Boston, MA 02115

Permit: Issued: 05/22/2019 Expires: 04/15/2023 Amended: 08/19/2021  
Issued: 05/22/2019 Expires: 04/15/2023 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations:

0101	Process Wastewater - Unregulated	
0201	Process Wastewater - Unregulated	
0301	Process Wastewater - Unregulated	
0501	Process Wastewater - Unregulated	
0602	Process Wastewater - Unregulated	
0701	Process Wastewater - Unregulated	
0801	Process Wastewater - Unregulated	
1101	Process Wastewater - Unregulated	laundry wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC:

YES	A	Quarter: 1
	B	Quarter: 1
	B	Quarter: 3

Inspections: 29-Oct-2021  
04-Mar-2022

Monitoring:

0101	24-Sep-2021
0101	25-Jan-2022
0101	27-Jan-2022
0201	24-Sep-2021
0201	21-Apr-2022
0201	22-Apr-2022
0301	24-Jan-2022
0301	25-Jan-2022
0301	01-Jun-2022
0501	25-Jan-2022
0501	26-Jan-2022
0501	16-Feb-2022
0501	21-Jun-2022
0602	23-Sep-2021
0602	24-Sep-2021
0701	26-Jan-2022
0701	28-Jan-2022
0801	02-Feb-2022
1101	02-Feb-2022

<b>Northeastern University</b>	Facility ID: 45004837
360 Huntington Avenue Boston, MA 02115	

1101                      01-Jun-2022

<u>Enforcement Actions:</u>	13-Jul-2021	Notice of Violation
	13-May-2022	Notice of Violation
	19-May-2022	Notice of Violation

**PerkinElmer, Inc.**

Facility ID: 45006727

549 Albany Street  
Boston, MA 02118

<u>Permit:</u>	Issued: 06/28/2022	Expires: 06/15/2024		
	Issued: 06/22/2020	Expires: 06/15/2022	Amended: 08/19/2021	Termination: 06/27/2022
	Issued: 06/22/2020	Expires: 06/15/2022		Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0202 Process Wastewater - Unregulated Laboratory wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 20-Dec-2021  
17-May-2022

<u>Monitoring:</u>	0202	09-Jul-2021
	0202	24-Jan-2022
	0202	22-Mar-2022
	0202	23-Mar-2022
	9100	24-Jan-2022

Enforcement Actions: 25-May-2022 Notice of Violation

**Trustees of Boston University-Charles River Campus**

Facility ID: 45004825

704 Commonwealth Avenue  
Boston, MA 02215

Permit: Issued: 03/16/2022 Expires: 09/15/2023  
Issued: 10/09/2019 Expires: 09/15/2021 Amended: 07/22/2020 Termination: 03/15/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	Process Wastewater - Unregulated	
	0201	Process Wastewater - Unregulated	
	0301	Process Wastewater - Unregulated	
	0303	Process Wastewater - Unregulated	
	0401	Process Wastewater - Unregulated	
	0501	Process Wastewater - Unregulated	
	0601	Process Wastewater - Unregulated	
	0701	Process Wastewater - Unregulated	
	0801	Process Wastewater - Unregulated	
	0901	Process Wastewater - Unregulated	
	1001	Process Wastewater - Unregulated	
	1101	Process Wastewater - Unregulated	lab wastewater
	1201	Process Wastewater - Unregulated	Laboratory wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES A Quarter: 2  
B Quarter: 2

Inspections: 18-Aug-2021  
16-Feb-2022

<u>Monitoring:</u>	0101	16-Sep-2021
	0101	17-Sep-2021
	0101	28-Mar-2022
	0201	13-Sep-2021
	0301	16-Sep-2021
	0301	17-Sep-2021
	0303	13-Sep-2021
	0303	14-Sep-2021
	0401	15-Sep-2021
	0501	15-Sep-2021
	0501	25-Apr-2022
	0601	14-Sep-2021
	0701	15-Sep-2021
	0801	13-Sep-2021
	0801	14-Sep-2021

**Trustees of Boston University-Charles River Campus**

Facility ID: 45004825

704 Commonwealth Avenue  
Boston, MA 02215

0901	13-Jan-2022
1001	15-Sep-2021
1101	10-Jan-2022
1101	12-Jan-2022
1201	16-Sep-2021
9100	28-Mar-2022

<u>Enforcement Actions:</u>	25-Nov-2020	Notice of Violation
	16-Aug-2021	Notice of Violation

<b>Tufts Medical Center</b>	Facility ID: 45005753
800 Washington Street Boston, MA 02111	

<u>Permit:</u>	Issued: 07/19/2021	Expires: 05/15/2023	Amended: 08/19/2021
	Issued: 07/19/2021	Expires: 05/15/2023	Termination: 08/19/2021
	Issued: 05/31/2019	Expires: 05/15/2021	Amended: 09/24/2019
			Termination: 07/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0203	Process Wastewater - Unregulated	
	0204	Process Wastewater - Unregulated	CPD wastewater
	0301	Process Wastewater - Unregulated	
	0802	Process Wastewater - Unregulated	

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES F3 Quarter: 4

Inspections: 07-Oct-2021  
19-Apr-2022

<u>Monitoring:</u>	0203	09-Dec-2021
	0203	10-Dec-2021
	0203	28-Mar-2022
	0204	09-Dec-2021
	0204	10-Dec-2021
	0204	26-May-2022
	0204	27-May-2022
	0301	27-Oct-2021
	0301	29-Oct-2021
	0301	26-May-2022
	0301	27-May-2022
	0802	18-Aug-2021
	0802	19-Aug-2021
	0802	27-Oct-2021
	0802	28-Oct-2021
	9100	28-Mar-2022

Enforcement Actions: 16-Mar-2022 Notice of Violation

<b>Tufts University, Boston Campus</b>	Facility ID: 45004793
200 Harrison Avenue Boston, MA 02111	

<u>Permit:</u>	Issued: 03/12/2020	Expires: 11/15/2023	Amended: 08/19/2021	
	Issued: 03/12/2020	Expires: 11/15/2023	Amended: 02/04/2021	Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

<u>Sample Locations:</u>	0102	Process Wastewater - Unregulated	Laboratory wastewater
	0202	Process Wastewater - Unregulated	Laboratory wastewater

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 19-Oct-2021  
25-Apr-2022

<u>Monitoring:</u>	0102	17-Aug-2021
	0102	18-Aug-2021
	0102	04-Jan-2022
	0102	05-Jan-2022
	0202	17-Aug-2021
	0202	18-Aug-2021
	0202	27-May-2022

Enforcement Actions: 25-Nov-2020 Notice of Violation

**Vicinity Energy, Inc. - Kneeland Station**

Facility ID: 45004707

165 Kneeland Street  
Boston, MA 02111

Permit: Issued: 03/17/2022 Expires: 10/15/2023  
Issued: 11/05/2019 Expires: 10/15/2021 Amended: 02/22/2021 Termination: 03/16/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated  
0201 Process Wastewater - Unregulated

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 21-Sep-2021  
27-Apr-2022

Monitoring: 0101 22-Nov-2021  
0101 23-Nov-2021  
0101 12-Jan-2022  
0101 13-Jan-2022  
0101 08-Mar-2022  
0201 09-Dec-2021  
0201 12-Jan-2022  
0201 13-Jan-2022  
9100 08-Mar-2022

Enforcement Actions:



## Braintree

<b>Channel Fish Processing, Inc.</b>	Facility ID: 06405423
200 Commerce Drive Braintree, MA 02184	

Permit: Issued: 01/25/2022 Expires: 01/15/2026  
Issued: 05/24/2018 Expires: 01/15/2022 Amended: 08/18/2021 Termination: 01/24/2022  
Issued: 05/24/2018 Expires: 01/15/2022 Amended: 09/12/2019 Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated Fish processing wastewater

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 08-Jul-2021  
06-Dec-2021

Monitoring: 0101 25-Aug-2021  
0101 11-Apr-2022  
9100 11-Apr-2022

Enforcement Actions:

<b>Citra Labs (Zimmer-Biomet Co.)</b>	Facility ID: 06001611
55 Messina Drive Braintree, MA 02184	

Permit: Issued: 07/12/2021 Expires: 03/15/2023 Amended: 08/18/2021  
 Issued: 07/12/2021 Expires: 03/15/2023 Termination: 08/18/2021  
 Issued: 03/24/2017 Expires: 03/15/2021 Amended: 04/12/2019 Termination: 07/11/2021

National Pretreatment Categorical Standards: 21-Sep-2001 to 439.46 D Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0103 Process Wastewater - Regulated pharmaceutical & medical device mfg. wastewater

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 02-Feb-2022  
24-Jun-2022

Monitoring: 0103 26-Aug-2021  
0103 08-Mar-2022  
9100 08-Mar-2022

Enforcement Actions:

**River Street Metal Finishing, Inc.**

Facility ID: 06101856

35 Johnson Lane  
Braintree, MA 02184

Permit: Issued: 04/23/2018 Expires: 01/15/2023 Amended: 08/20/2021  
Issued: 04/23/2018 Expires: 01/15/2023 Termination: 08/20/2021

National Pretreatment Categorical Standards: 12-Mar-1997 to 433.15 A Metal Finishing

MWRA Category: 04

Sample Locations: 0101

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 08-Mar-2022

Monitoring:

Enforcement Actions:

<b>Ryder Transportation Services</b>	Facility ID: 06102545
285 Wood Road Braintree, MA 02184	

Permit: Issued: 05/26/2022 Expires: 05/15/2024  
 Issued: 02/05/2020 Expires: 12/15/2021 Termination: 05/25/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Truck washing

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 04-Nov-2021  
13-Apr-2022

Monitoring: 0101 08-Dec-2021  
0101 11-Apr-2022  
0101 03-May-2022  
0101 04-May-2022  
9100 11-Apr-2022

Enforcement Actions:

<b>Symmons Industries, Inc.</b>	Facility ID: 06000958
31 Brooks Drive Braintree, MA 02184	

Permit: Issued: 01/25/2022 Expires: 12/15/2023  
 Issued: 12/18/2019 Expires: 12/15/2021 Termination: 01/24/2022

National Pretreatment Categorical Standards: 07-Oct-2003 to 433.15 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated metal plating operation  
 0201 Process Wastewater - Regulated valve testing water and parts cleaning baths

Reason for SIU Status: Is a Categorical Industrial User., Has a reasonable potential to violate MWRA limits.

SNC: YES A Quarter: 1  
 B Quarter: 1  
 A Quarter: 2  
 B Quarter: 2

Inspections: 12-Nov-2021  
 27-Apr-2022

Monitoring: 0101 06-Jul-2021  
 0101 07-Jul-2021  
 0101 29-Nov-2021  
 0101 30-Nov-2021  
 0101 19-Jan-2022  
 0101 24-Jan-2022  
 0201 06-Jul-2021  
 0201 07-Jul-2021  
 0201 29-Nov-2021  
 0201 30-Nov-2021  
 0201 11-Apr-2022  
 0201 12-Apr-2022  
 0201 13-Apr-2022  
 9100 24-Jan-2022  
 9100 11-Apr-2022

Enforcement Actions: 08-Sep-2020 Notice of Violation  
 14-Mar-2022 Notice of Violation

**Tri-Town Regional Water Treatment Plant**

Facility ID: 06408882

300 King Hill Road  
Braintree, MA 02184

Permit: Issued: 04/14/2022 Expires: 03/15/2024

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated 01water treatment plant residuals

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 22-Jun-2022

Monitoring:

Enforcement Actions:

## Brighton

**Steward St. Elizabeth's Medical Center**

Facility ID: 46005935

736 Cambridge Street  
Brighton, MA 02135

Permit: Issued: 12/11/2020 Expires: 11/15/2022 Amended: 08/20/2021  
Issued: 12/11/2020 Expires: 11/15/2022 Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0201	OTHER_DESC	Hospital Laboratory Effluent
	0402	OTHER_DESC	Medical cart washer.
	0403	Process Wastewater - Unregulated	Endoscope washing
	0404		
	0405		
	0406		

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES F3 Quarter: 3

Inspections: 09-Aug-2021  
29-Mar-2022

<u>Monitoring:</u>	0201	01-Nov-2021
	0201	02-Nov-2021
	0201	02-May-2022
	0402	01-Nov-2021
	0403	01-Nov-2021
	0403	17-Mar-2022
	0404	02-Nov-2021
	0405	02-Nov-2021
	0406	02-Nov-2021
	9100	02-May-2022

Enforcement Actions: 22-Nov-2021 Notice of Violation

## Brookline

<b>MBTA Reservoir Carhouse</b>	Facility ID: 07101154
400 Chestnut Hill Avenue Brookline, MA 02146	

Permit: Issued: 05/26/2022 Expires: 01/15/2024  
Issued: 02/07/2020 Expires: 01/15/2022 Amended: 08/18/2021 Termination: 05/25/2022  
Issued: 02/07/2020 Expires: 01/15/2022 Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES A Quarter: 4  
B Quarter: 4

Inspections: 20-Jul-2021  
17-Dec-2021

Monitoring: 0101 05-May-2022  
0101 02-Jun-2022  
0101 23-Jun-2022

Enforcement Actions: 08-Jul-2020 Notice of Violation  
11-Jan-2022 Notice of Violation



## Burlington

**Curia Massachusetts, Inc. (formerly AMRI - Burlington)**

Facility ID: 08103431

99 S Bedford Street Suite 2  
Burlington, MA 01803

Permit: Issued: 06/14/2021 Expires: 03/15/2026 Amended: 12/30/2021  
Issued: 06/14/2021 Expires: 03/15/2026 Termination: 12/29/2021

National Pretreatment Categorical Standards: 03-Jan-2006 to 439.47 D Pharmaceutical Manufacturing

MWRA Category: 03

Sample Locations:

0101	Process Wastewater - Unregulated	laboratory wastewater
0102	Process Wastewater - Unregulated	wash water from vial washer and sink in clean room
0103		
0104	Process Wastewater - Unregulated	Clean room sink

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 08-Jul-2021  
04-Jan-2022

Monitoring:

0101	22-Nov-2021
0102	22-Nov-2021
0104	22-Nov-2021

Enforcement Actions:

**Lahey Hospital & Medical Center**

Facility ID: 08002766

41 Mall Road  
Burlington, MA 01805

Permit: Issued: 03/08/2022 Expires: 09/15/2023  
Issued: 09/17/2019 Expires: 09/15/2021

Termination: 03/07/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	Process Wastewater - Unregulated	medical labs
	0104	Process Wastewater - Unregulated	medical cart washer
	0105	Process Wastewater - Unregulated	01washer/sterilizer in CPD
	0201	Process Wastewater - Unregulated	medical R&D lab

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 03-Aug-2021  
11-Mar-2022

<u>Monitoring:</u>	0101	20-Jul-2021
	0101	03-Nov-2021
	0101	04-Nov-2021
	0101	25-Apr-2022
	0101	26-May-2022
	0101	27-May-2022
	0104	21-Jul-2021
	0105	22-Jul-2021
	0201	21-Jul-2021
	9100	25-Apr-2022

Enforcement Actions: 13-May-2022 Notice of Violation

<b>Vine Brook Water Treatment Plant</b>	Facility ID: 08101677
171 Middlesex Turnpike Burlington, MA 01803	

Permit: Issued: 06/16/2021 Expires: 06/15/2025 Amended: 08/18/2021  
 Issued: 06/16/2021 Expires: 06/15/2025 Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated water treatment backwash  
 Uncontaminated Cooling Water lab sample tap water - dilution

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 03-Dec-2021  
03-Jun-2022

Monitoring: 0101 12-Aug-2021  
 0101 09-Nov-2021  
 0101 15-Dec-2021  
 0101 25-Apr-2022  
 0101 01-Jun-2022  
 9100 25-Apr-2022

Enforcement Actions:

## Cambridge

**ARE - 300 TechSquare**

Facility ID: 09101756

300 Technology Square  
Cambridge, MA 02139

Permit: Issued: 05/04/2022  
Issued: 12/10/2019

Expires: 12/15/2023  
Expires: 12/15/2021

Termination: 05/03/2022

### National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	OTHER_DESC	Lab sink and glassware washing effluent
	0103	Process Wastewater - Unregulated	Bomedical reserach waste water
	0401	Process Wastewater - Unregulated	Biomedical research waste water
	0501	Process Wastewater - Unregulated	biomedical research

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES B Quarter: 1

Inspections: 03-Nov-2021  
04-May-2022

<u>Monitoring:</u>	0101	29-Sep-2021
	0101	30-Sep-2021
	0101	30-Mar-2022
	0101	26-Apr-2022
	0103	30-Aug-2021
	0103	31-Aug-2021
	0401	30-Aug-2021
	0401	31-Aug-2021
	0401	30-Mar-2022
	0401	27-Apr-2022
	0401	28-Apr-2022
	0501	29-Sep-2021
	0501	30-Mar-2022

<u>Enforcement Actions:</u>	20-Aug-2020	Notice of Violation
	03- Jun-2021	Notice of Violation
	04- Aug-2021	Notice of Violation
	06-Apr-2022	Notice of Violation

**Biogen, Inc.**

Facility ID: 09101193

115 Broadway  
Cambridge, MA 02142

Permit: Issued: 02/21/2020 Expires: 02/15/2024 Amended: 08/18/2021  
Issued: 02/21/2020 Expires: 02/15/2024 Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 OTHER\_DESC Lab sinks, glassware washing and cage washing  
0102 OTHER\_DESC wastewater produced during cogen plant water treatment including car

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: YES B Quarter: 1  
B Quarter: 2

Inspections: 10-Jan-2022  
10-May-2022

Monitoring: 0101 18-Aug-2021  
0101 20-Aug-2021  
0101 28-Mar-2022  
0101 29-Mar-2022  
0101 12-May-2022  
0101 26-May-2022  
0101 27-May-2022  
0102 20-Aug-2021  
0102 27-Jun-2022  
9100 12-May-2022  
9100 27-Jun-2022

Enforcement Actions: 31-Mar-2022 Notice of Violation  
18-May-2022 Notice of Noncompliance

**Cambridge Brands, Inc.**

Facility ID: 09007168

810 Main Street  
Cambridge, MA 02139

Permit: Issued: 06/24/2021 Expires: 04/15/2023 Amended: 08/18/2021  
Issued: 06/24/2021 Expires: 04/15/2023 Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Candy manufacture  
0301 Process Wastewater - Unregulated candy manufacture  
0401 Process Wastewater - Unregulated candy manufacture

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 21-Jul-2021  
01-Feb-2022

Monitoring: 0101 25-Aug-2021  
0101 26-Aug-2021  
0101 18-Nov-2021  
0101 19-Nov-2021  
0301 25-Aug-2021  
0301 26-Aug-2021  
0401 28-Feb-2022  
0401 09-Mar-2022  
0401 10-Mar-2022  
0401 27-Jun-2022  
9100 27-Jun-2022

Enforcement Actions: 18-Nov-2021 Notice of Violation  
02-Dec-2021 Notice of Violation  
10-Jan-2022 Notice of Violation  
07-Apr-2022 Notice of Violation

**GCP Applied Technologies, Inc.**

Facility ID: 09001993

62 Whittemore Avenue  
Cambridge, MA 02140

<u>Permit:</u>	Issued: 10/08/2020		Amended: 03/29/2022	Termination: 03/29/2022
	Issued: 10/08/2020	Expires: 09/15/2022	Amended: 08/18/2021	Termination: 03/28/2022
	Issued: 10/08/2020	Expires: 09/15/2022		Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0301 OTHER\_DESC Cement additive research; waterproofing and fireproofing R&D

Reason for SIU Status:

SNC: NO

Inspections: 10-Nov-2021

Monitoring:

Enforcement Actions:

<b>Harvard University - Blackstone Street Station</b>	Facility ID: 09003701
46 Blackstone Street Cambridge, MA 02139	

Permit: Issued: 05/04/2022 Expires: 08/15/2023  
 Issued: 08/29/2019 Expires: 08/15/2021 Termination: 05/03/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER\_DESC Boiler blowdown, zeolite regen., floor drains.

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 20-Jan-2022

Monitoring: 0101 11-Aug-2021  
 0101 18-Nov-2021  
 0101 19-Nov-2021  
 0101 12-Jan-2022  
 0101 13-Jan-2022  
 0101 27-Jun-2022  
 9100 27-Jun-2022

Enforcement Actions: 22-Oct-2020 Notice of Violation



**Harvard University - Cambridge Campus**

Facility ID: 09003755

46 Blackstone Street  
Cambridge, MA 02139

Permit: Issued: 03/29/2022 Expires: 12/15/2023  
Issued: 03/06/2020 Expires: 12/15/2021

Termination: 03/28/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	OTHER_DESC	Effluent from research chemistry labs
	0201	OTHER_DESC	Effluent from research chemistry laboratories
	0801	OTHER_DESC	Effluent from research lab sinks, photoprocessing glassware washing
	0901	OTHER_DESC	Chemistry, physics, organic chemistry and biology teaching lab sink an
	1001	OTHER_DESC	Effluent from the Geology Laboratory
	1301	OTHER_DESC	Bioengineering research lab effluent
	1401	OTHER_DESC	Anthropology research labs
	1502	OTHER_DESC	Plastic animal cage washing.
	1503	OTHER_DESC	Animal cage washing.
	1504	OTHER_DESC	Animal cage rack washing.
	1701	OTHER_DESC	Engineering research in materials technology research on a nano scal
	2001	OTHER_DESC	R&D science labs - Northwest Building
	2002	OTHER_DESC	Mouse cage washing
	2401	Process Wastewater - Unregulated	laundry

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: YES A Quarter: 1  
B Quarter: 1  
B Quarter: 2

Inspections: 17-Nov-2021

<u>Monitoring:</u>	0101	30-Aug-2021
	0101	31-Aug-2021
	0101	27-Sep-2021
	0101	28-Sep-2021
	0101	26-Oct-2021
	0101	02-Dec-2021
	0101	23-May-2022
	0201	31-Aug-2021
	0201	27-Sep-2021
	0201	28-Sep-2021
	0201	25-Oct-2021
	0201	26-Oct-2021
	0201	02-Dec-2021
	0201	27-Jun-2022

46 Blackstone Street  
Cambridge, MA 02139

0801	29-Sep-2021
0801	30-Sep-2021
0801	28-Oct-2021
0801	29-Oct-2021
0801	09-Nov-2021
0801	10-Nov-2021
0901	01-Sep-2021
0901	16-Sep-2021
0901	28-Oct-2021
0901	29-Oct-2021
0901	28-Jan-2022
1001	08-Nov-2021
1301	05-Jan-2022
1301	06-Jan-2022
1301	16-Mar-2022
1301	22-Jun-2022
1401	16-Jun-2022
1502	28-Oct-2021
1503	28-Oct-2021
1504	28-Oct-2021
1701	01-Sep-2021
1701	02-Sep-2021
1701	05-Jan-2022
1701	06-Jan-2022
2001	28-Sep-2021
2001	26-Oct-2021
2001	16-Mar-2022
2001	17-Mar-2022
2002	28-Jan-2022
2401	30-Nov-2021
9100	23-May-2022
9100	27-Jun-2022

<u>Enforcement Actions:</u>	06-Jan-2021	Notice of Violation
	11-Feb-2021	Notice of Violation
	25-Mar-2021	Notice of Violation
	06-Apr-2022	Notice of Noncompliance

***Ipsen Bioscience, Inc.***

Facility ID: 09405507

One Kendall Square  
Cambridge, MA 02139

Permit: Issued: 04/13/2018 Expires: 12/15/2022 Amended: 08/18/2021  
Issued: 04/13/2018 Expires: 12/15/2022 Amended: 01/09/2019 Termination: 08/18/2021

National Pretreatment Categorical Standards: 03-Apr-2017 to 439.47 D Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated drug manufacturing and support

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 20-Sep-2021  
11-Mar-2022

Monitoring: 0101 11-Aug-2021

Enforcement Actions:

<b>MBTA - North Cambridge Carhouse</b>	Facility ID: 09102175
2375 Massachusetts Avenue Cambridge, MA 02140	

<u>Permit:</u>	Issued: 06/22/2020	Expires: 05/15/2022	Amended: 08/18/2021	Termination: 03/28/2022
	Issued: 06/22/2020	Expires: 05/15/2022		Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 04

Sample Locations: 0101 OTHER\_DESC Trackless trolley bus washing

Reason for SIU Status:

SNC: NO

Inspections: 28-Oct-2021  
17-Mar-2022

Monitoring: 0101 27-Sep-2021

Enforcement Actions: 29-Jul-2020 Notice of Violation

**Massachusetts Institute of Technology (MIT)**

Facility ID: 09003259

77 Massachusetts Avenue  
Cambridge, MA 02139

Permit: Issued: 05/04/2022 Expires: 09/15/2023 Amended: 06/09/2022  
Issued: 05/04/2022 Expires: 09/15/2023 Termination: 06/08/2022  
Issued: 12/10/2019 Expires: 09/15/2021 Termination: 05/03/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0201	OTHER_DESC	Microbiology Research & Development Labs
	0301	OTHER_DESC	Research & development Laboratories
	0401	OTHER_DESC	Biological R&D labs
	0502	OTHER_DESC	R&D lab sinks, photo processing, cage washing operations, glassware
	0701	OTHER_DESC	Institute for Soldier Nanotech/Bioengineering R&D Labs
	0702	OTHER_DESC	biomedical research waste water
	0801	OTHER_DESC	R & D lab
	0901	OTHER_DESC	Bldgs NW13 & NW14 R&D Labs
	1001	Process Wastewater - Unregulated	chemistry and nanotech
	1101	Process Wastewater - Unregulated	laundry
	1201	Process Wastewater - Unregulated	laundry

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: YES A Quarter: 1  
A Quarter: 3  
B Quarter: 3  
A Quarter: 4  
B Quarter: 4

Inspections: 19-Oct-2021

<u>Monitoring:</u>	0201	02-Sep-2021
	0201	03-Sep-2021
	0201	23-Sep-2021
	0201	24-Sep-2021
	0301	01-Sep-2021
	0301	02-Sep-2021
	0401	30-Aug-2021
	0401	31-Aug-2021
	0401	25-Oct-2021
	0401	26-Oct-2021
	0401	28-Oct-2021
	0401	15-Feb-2022
	0401	16-Feb-2022
	0502	30-Aug-2021

**Massachusetts Institute of Technology (MIT)**

Facility ID: 09003259

77 Massachusetts Avenue  
Cambridge, MA 02139

0502	31-Aug-2021
0502	25-Oct-2021
0502	26-Oct-2021
0502	28-Oct-2021
0701	31-Aug-2021
0701	01-Sep-2021
0701	27-Jun-2022
0702	30-Aug-2021
0702	31-Aug-2021
0702	25-Oct-2021
0702	26-Oct-2021
0702	28-Oct-2021
0801	01-Sep-2021
0801	02-Sep-2021
0801	21-Sep-2021
0901	02-Sep-2021
0901	03-Sep-2021
0901	29-Oct-2021
0901	10-Feb-2022
0901	11-Feb-2022
1001	31-Aug-2021
1001	26-Oct-2021
1001	15-Feb-2022
1001	16-Feb-2022
1101	02-Sep-2021
1101	03-Sep-2021
1201	02-Sep-2021
1201	03-Sep-2021
9100	27-Jun-2022

<u>Enforcement Actions:</u>	01-Aug-2020	Ruling on Req for recon of NON/OTCA/EO/SOC/NPPR
	24-Nov-2020	Notice of Violation
	21-Dec-2020	Notice of Violation
	23-Dec-2020	Extension of NON/OTCA/EO/SOC/NPPR Letter
	21-Dec-2021	Extension of NON/OTCA/EO/SOC/NPPR Letter
	10-May-2022	Extension of NON/OTCA/EO/SOC/NPPR Letter

<b>Massachusetts Institute of Technology-Central Utility Plant</b>	Facility ID: 09101084
59 Vassar Street Building 42 Cambridge, MA 02139	

Permit: Issued: 05/04/2022 Expires: 11/15/2023  
 Issued: 12/30/2019 Expires: 11/15/2021 Termination: 05/03/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER\_DESC Cogeneration plant effluent and lab sinks from Building 5, Building 7, B

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 28-Oct-2021  
26-Apr-2022

<u>Monitoring:</u>	0101	16-Aug-2021
	0101	17-Aug-2021
	0101	28-Oct-2021
	0101	29-Oct-2021
	0101	20-Jan-2022
	0101	21-Jan-2022
	0101	28-Feb-2022
	9100	28-Feb-2022

<u>Enforcement Actions:</u>	28-Dec-2020	Notice of Violation
	07- Apr-2021	Notice of Noncompliance
	08- Jul-2021	Extension of NON/OTCA/EO/SOC/NPPR Letter
	09-Jul-2021	Notice of Violation
	12-May-2022	Extension of NON/OTCA/EO/SOC/NPPR Letter

<b>The Charles Stark Draper Laboratory, Inc.</b>	Facility ID: 09001132
555 Technology Square Cambridge, MA 02139	

<u>Permit:</u>	Issued: 03/29/2022	Expires: 04/15/2024		
	Issued: 05/08/2020	Expires: 04/15/2022	Amended: 08/18/2021	Termination: 03/28/2022
	Issued: 05/08/2020	Expires: 04/15/2022		Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0102	OTHER_DESC	Bio lab effluent & Metal finishing for R&D labs and prototype fabricatio
	0104	OTHER_DESC	Biolab effluent & Silicon wafer etching and metal coating for R&D labs
	0105	OTHER_DESC	Glassware washing and acid cleaning effluent

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

<u>SNC:</u>	YES A	Quarter: 2
	B	Quarter: 2

Inspections: 16-Sep-2021  
15-Mar-2022

<u>Monitoring:</u>	0102	26-Aug-2021
	0104	25-Aug-2021
	0104	26-Aug-2021
	0105	26-Aug-2021

<u>Enforcement Actions:</u>	08-Mar-2021	Notice of Violation
	23-Jun-2022	Notice of Violation



<b>Vicinity Energy Boston, Inc.</b>	Facility ID: 09002256
265 First Street Cambridge, MA 02142	

<u>Permit:</u>	Issued: 05/19/2022	Expires: 06/15/2024	Amended: 06/01/2022	
	Issued: 05/19/2022	Expires: 06/15/2024		Termination: 05/31/2022
	Issued: 06/22/2020	Expires: 06/15/2022	Amended: 08/18/2021	Termination: 05/18/2022
	Issued: 06/22/2020	Expires: 06/15/2022		Termination: 08/18/2021

National Pretreatment Categorical Standards: 01-Sep-2003 to 423.16 A Steam Electric Power Generating

MWRA Category: 01

<u>Sample Locations:</u>	0202	Process Wastewater - Regulated	boiler blowdown, condensate reclaim tank overflow, city water reclaim
	0301	OTHER_DESC	Carriage House and Main Building pH neutralization syste.; RO & UF s

Reason for SIU Status: Is a Categorical Industrial User., Flow greater than 25,000 gpd.

SNC: NO

Inspections: 23-Nov-2021  
04-May-2022

<u>Monitoring:</u>	0202	11-Aug-2021
	0202	12-Aug-2021
	0202	15-Nov-2021
	0202	17-Nov-2021
	0202	12-May-2022
	0301	11-Aug-2021
	0301	12-Aug-2021
	0301	15-Nov-2021
	0301	16-Nov-2021
	9100	12-May-2022

Enforcement Actions:

<b>Walter J Sullivan Water Purification Facility</b>	Facility ID: 09101863
250 Fresh Pond Parkway Cambridge, MA 02138	

Permit: Issued: 06/24/2021 Expires: 05/15/2023 Amended: 08/18/2021  
 Issued: 06/24/2021 Expires: 05/15/2023 Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	OTHER_DESC	Effluent generated from sludge and filter backwash.
	0102	OTHER_DESC	Effluent generated from water quality laboratory.

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 20-Oct-2021  
12-Apr-2022

<u>Monitoring:</u>	0101	23-Aug-2021
	0101	24-Aug-2021
	0101	20-Sep-2021
	0101	21-Sep-2021
	0101	20-Dec-2021
	0101	21-Dec-2021
	0101	31-May-2022
	0101	01-Jun-2022
	0102	23-Aug-2021
	0102	31-May-2022

Enforcement Actions:

## Canton

***Emergent BioSolutions, Inc.***

Facility ID: 10102853

90 Shawmut Road  
Canton, MA 02021

Permit: Issued: 10/23/2018 Expires: 11/15/2022 Amended: 08/18/2021  
Issued: 10/23/2018 Expires: 11/15/2022 Termination: 08/18/2021

National Pretreatment Categorical Standards: 17-Jan-2002 to 439.17 A Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated Pharmaceuticals mfg. by fermentation

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 08-Jul-2021  
20-Jan-2022

Monitoring: 0101 19-Oct-2021

Enforcement Actions:

**Interpolymer Corporation**

Facility ID: 10100536

200 Dan Road  
Canton, MA 02021

Permit: Issued: 08/16/2018 Expires: 08/15/2023 Amended: 08/20/2021  
Issued: 08/16/2018 Expires: 08/15/2023 Termination: 08/20/2021

National Pretreatment Categorical Standards: 08-Oct-1993 to 414.46 D Organic Chemicals, Plastics, and Synthetic Fibers

MWRA Category: 04

Sample Locations:

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 11-Aug-2021

Monitoring:

Enforcement Actions: 25-Apr-2022 Notice of Violation

<b>Neponset Street Water Treatment Facility</b>	Facility ID: 10103713
480 Neponset Street Canton, MA 02021	

Permit: Issued: 06/17/2021 Expires: 06/15/2023 Amended: 08/18/2021  
 Issued: 06/17/2021 Expires: 06/15/2023 Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated water treatment plant residuals

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 17-Nov-2021  
26-May-2022

Monitoring: 0101 20-Oct-2021  
0101 21-Oct-2021  
0101 29-Dec-2021  
0101 30-Dec-2021

Enforcement Actions:

## Charlestown

**Boston Sand & Gravel Company**

Facility ID: 47005927

180 New Rutherford Avenue  
Charlestown, MA 02129

Permit: Issued: 03/16/2022  
Issued: 12/27/2019

Expires: 10/15/2023  
Expires: 10/15/2021

Termination: 03/15/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 08-Sep-2021  
09-Mar-2022

Monitoring:

0101	06-Jan-2022
0101	19-Jan-2022
0101	08-Mar-2022
0101	17-May-2022
9100	08-Mar-2022

Enforcement Actions:

**Diversified Automotive, Inc.**

Facility ID: 47403474

100 Terminal Street  
Charlestown, MA 02129

Permit: Issued: 08/04/2022 Expires: 07/15/2023  
Issued: 06/26/2019 Expires: 07/15/2021 Amended: 02/25/2021 Termination: 08/03/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0201 Process Wastewater - Unregulated Car wash effluent

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 02-Jul-2021  
09-Dec-2021  
27-Jun-2022

Monitoring: 0201 28-Jul-2021  
0201 02-Mar-2022  
0201 01-Jun-2022  
0201 28-Jun-2022

Enforcement Actions:

**MBTA - Charlestown Yard Complex**

Facility ID: 47006019

21 Arlington Avenue  
Charlestown, MA 02129

Permit: Issued: 05/16/2022 Expires: 01/15/2024  
Issued: 03/04/2020 Expires: 01/15/2022 Amended: 08/20/2021 Termination: 05/15/2022  
Issued: 03/04/2020 Expires: 01/15/2022 Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	OTHER_DESC	Bus washing effluent.
	0102	OTHER_DESC	Steam cleaning effluent.
	0201	OTHER_DESC	Truck/car washing effluent
	0301	OTHER_DESC	Truck & heavy equipment washing effluent

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 14-Jul-2021  
03-Dec-2021

Monitoring: 0101 17-Sep-2021  
0301 09-Nov-2021

Enforcement Actions:



**MGH - Lawrence C. Martin Laboratory**

Facility ID: 47007025

13th Street Building 149  
Charlestown, MA 02129

Permit: Issued: 04/26/2022 Expires: 12/15/2023  
Issued: 02/12/2020 Expires: 12/15/2021

Termination: 04/25/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER\_DESC Laboratory wastewater.

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 01-Nov-2021  
22-Apr-2022

Monitoring: 0101 25-Oct-2021  
0101 26-Oct-2021  
0101 16-May-2022  
0101 17-May-2022  
0101 30-Jun-2022

Enforcement Actions:

## Chelsea

<b>Catalent</b>	Facility ID: 11403573
190 Everett Avenue Chelsea, MA 02150	

Permit: Issued: 04/14/2020 Expires: 02/15/2024 Amended: 08/18/2021  
Issued: 04/14/2020 Expires: 02/15/2024 Amended: 04/08/2021 Termination: 08/18/2021

National Pretreatment Categorical Standards: 28-Mar-2019 to 439.47 D Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated CIP skid cleaning, glass washer and laboratory cleaning wastewater

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 06-Jul-2021

Monitoring: 0101 19-Aug-2021  
0101 20-Aug-2021

Enforcement Actions:

<b>Kayem Foods, Inc.</b>	Facility ID: 11000611
75 Arlington Street Chelsea, MA 02150	

Permit: Issued: 06/14/2021 Expires: 05/15/2023 Amended: 08/18/2021  
 Issued: 06/14/2021 Expires: 05/15/2023 Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Meat processing

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 14-Jul-2021

Monitoring: 0101 16-Sep-2021  
 0101 17-Sep-2021

Enforcement Actions: 27-May-2021 Notice of Violation  
 19-May-2022 Notice of Violation

<b>State Garden Inc.</b>	Facility ID: 11403376
300 Third Street Chelsea, MA 02150	

Permit: Issued: 11/23/2020 Expires: 09/15/2024 Amended: 08/18/2021  
 Issued: 11/23/2020 Expires: 09/15/2024 Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0103 Process Wastewater - Unregulated Vegetable washing and equipment sanitizing wastewater  
 0201 Process Wastewater - Unregulated Vegetable washing and equipment sanitizing wastewater

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 08-Sep-2021  
17-Mar-2022

Monitoring: 0103 23-Aug-2021  
0103 24-Aug-2021  
0201 01-Dec-2021  
0202 08-Jun-2022

Enforcement Actions: 10-Feb-2022 Notice of Violation  
09-Jun-2022 Notice of Violation

## Clinton

**Central Mass Powder Coating**

Facility ID: 57102782

32 Greeley Street  
Clinton, MA 01510

Permit: Issued: 06/25/2021 Expires: 04/15/2026 Amended: 08/20/2021  
Issued: 06/25/2021 Expires: 04/15/2026 Termination: 08/20/2021

National Pretreatment Categorical Standards: 01-Mar-2003 to 433.17 A Metal Finishing

MWRA Category: 04

Sample Locations: 0101

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 16-Mar-2022

Monitoring:

Enforcement Actions: 16-Sep-2020 Notice of Violation

<b>Darmann Abrasive Products, Inc.</b>	Facility ID: 57006959
100 Sterling Street Clinton, MA 01510	

Permit: Issued: 06/25/2021 Expires: 03/15/2023 Amended: 08/20/2021  
 Issued: 06/25/2021 Expires: 03/15/2023 Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated equipment discharge

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 21-Jul-2021  
27-Jan-2022

Monitoring: 0101 14-Oct-2021  
0101 03-Jan-2022  
0101 31-Jan-2022  
0101 16-Feb-2022  
0101 16-Mar-2022  
9100 31-Jan-2022

Enforcement Actions:

<b>Sterling Precision, Inc.</b>	Facility ID: 57103051
90 Parker Street Clinton, MA 01510	

Permit: Issued: 06/25/2021 Expires: 07/15/2023 Amended: 08/20/2021  
 Issued: 06/25/2021 Expires: 07/15/2023 Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated  
 0102 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 27-Jan-2022

Monitoring: 0101 12-Oct-2021  
 0101 13-Oct-2021  
 0101 03-Jan-2022  
 0101 04-Jan-2022  
 0101 22-Feb-2022  
 0101 28-Mar-2022  
 0102 12-Oct-2021  
 0102 03-Jan-2022  
 9100 28-Mar-2022

Enforcement Actions: 20-Jan-2022 Notice of Violation

## Dorchester

<b>Dutch Maid Bakery, Inc.</b>	Facility ID: 48101125
50 Park Street Dorchester, MA 02122	

Permit: Issued: 04/26/2022 Expires: 12/15/2023  
Issued: 02/06/2020 Expires: 12/15/2021 Termination: 04/25/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0103 OTHER\_DESC Cleaning bakery equipment  
0201 OTHER\_DESC washing cake decorating utensils and containers

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 03-Nov-2021  
28-Apr-2022

Monitoring: 0103 07-Dec-2021  
0103 08-Dec-2021  
0201 07-Dec-2021

Enforcement Actions: 02-Dec-2020 Notice of Violation  
09-Dec-2020 Notice of Violation



**MBTA - Codman Yard**

Facility ID: 48102660

375 Gallivan Boulevard  
Dorchester, MA 02124

Permit: Issued: 06/10/2022 Expires: 06/15/2024  
Issued: 06/22/2020 Expires: 06/15/2022 Amended: 08/20/2021 Termination: 06/09/2022  
Issued: 06/22/2020 Expires: 06/15/2022 Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER\_DESC Train washing effluent

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 18-Oct-2021  
02-May-2022

Monitoring:

Enforcement Actions:

**Unifirst Corporation**

Facility ID: 48003934

78 -80 East Cottage Street  
Dorchester, MA 02125

Permit: Issued: 09/25/2020 Expires: 10/15/2022 Amended: 08/20/2021  
Issued: 09/25/2020 Expires: 10/15/2022 Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER\_DESC Laundry effluent

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 22-Sep-2021  
25-Mar-2022

Monitoring: 0101 02-Sep-2021  
0101 22-Dec-2021  
0101 23-Dec-2021  
0101 26-Jan-2022  
0101 14-Mar-2022  
0101 22-Mar-2022  
9100 14-Mar-2022

Enforcement Actions:

**University of Massachusetts, Boston**

Facility ID: 48100569

100 Morrissey Boulevard  
Dorchester, MA 02125-3393

Permit: Issued: 01/20/2021 Expires: 11/15/2022 Amended: 08/20/2021  
Issued: 01/20/2021 Expires: 11/15/2022 Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	OTHER_DESC	Lab wastewater
	0102	OTHER_DESC	Lab wastewater
	0103	Process Wastewater - Unregulated	Lab wastewater, cu & zn etch
	0204	Process Wastewater - Unregulated	Lab wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 13-Dec-2021  
03-Mar-2022

<u>Monitoring:</u>	0101	08-Nov-2021
	0101	10-Nov-2021
	0102	08-Nov-2021
	0102	09-Nov-2021
	0103	08-Nov-2021
	0204	09-Nov-2021
	0204	10-Nov-2021
	0204	23-Mar-2022
	0204	24-Mar-2022

Enforcement Actions: 23-Sep-2020 Notice of Violation

## East Boston

**MBTA - Orient Heights Maintenance Facility**

Facility ID: 49003659

34 Barnes Avenue  
East Boston, MA 02128

Permit: Issued: 06/01/2022 Expires: 05/15/2024  
Issued: 06/03/2020 Expires: 05/15/2022 Amended: 08/20/2021 Termination: 05/31/2022  
Issued: 06/03/2020 Expires: 05/15/2022 Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0102 Process Wastewater - Unregulated Railroad car washing

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 12-Oct-2021  
08-Apr-2022

Monitoring: 0102 31-Mar-2022

Enforcement Actions: 16-Mar-2021 Notice of Violation

<b>MassPort - Green Bus Depot</b>	Facility ID: 49403923
23 Lovell Street East Boston, MA 02128	

Permit: Issued: 12/28/2020 Expires: 11/15/2022 Amended: 08/20/2021  
 Issued: 12/28/2020 Expires: 11/15/2022 Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated bus washing

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 26-Oct-2021  
26-Apr-2022

Monitoring: 0101 16-Nov-2021  
0101 17-Nov-2021

Enforcement Actions:

## Everett

<b>Cambridge Health Alliance-Everett Hospital</b>	Facility ID: 13006521
96 -103 Garland Street Everett, MA 02149	

Permit: Issued: 05/04/2020 Expires: 04/15/2024 Amended: 08/18/2021  
Issued: 05/04/2020 Expires: 04/15/2024 Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0202 Process Wastewater - Unregulated Clinical Labs  
0601 Process Wastewater - Unregulated Central Processing

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 10-Sep-2021  
17-Mar-2022

Monitoring: 0202 18-Aug-2021  
0202 19-Aug-2021  
0202 27-Apr-2022  
0601 22-Jul-2021  
0601 23-Jul-2021  
0601 27-Sep-2021  
0601 28-Sep-2021

Enforcement Actions: 27-Jul-2021 Notice of Violation

**Constellation Mystic Power, LLC (Units 8 & 9)**

Facility ID: 13102507

39 Rover Street  
Everett, MA 02149

Permit: Issued: 06/09/2022 Expires: 05/15/2024  
Issued: 05/15/2020 Expires: 05/15/2022 Amended: 08/18/2021 Termination: 06/08/2022  
Issued: 05/15/2020 Expires: 05/15/2022 Termination: 08/18/2021

National Pretreatment Categorical Standards: 06-Aug-2007 to 423.17 N/A Steam Electric Power Generating

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated Wastewater from steam electric power generation

Reason for SIU Status: Is a Categorical Industrial User., Flow greater than 25,000 gpd.

SNC: NO

Inspections: 12-Oct-2021  
08-Apr-2022

Monitoring: 0101 13-Sep-2021  
0101 14-Sep-2021  
0101 11-Jan-2022  
0101 12-Jan-2022  
0101 13-Jan-2022

Enforcement Actions:

**Duncan Galvanizing Corporation**

Facility ID: 13000624

69 Norman Street  
Everett, MA 02149

Permit: Issued: 05/22/2018 Expires: 12/15/2022 Amended: 08/20/2021  
Issued: 05/22/2018 Expires: 12/15/2022 Termination: 08/20/2021

National Pretreatment Categorical Standards: 17-Dec-1991 to 420.115 K Iron and Steel Manufacturing  
17-Dec-1991 to 420.125 L Iron and Steel Manufacturing  
17-Dec-1991 to 420.95 I Iron and Steel Manufacturing

MWRA Category: 04

Sample Locations: 0103

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 30-Jul-2021  
24-Jan-2022

Monitoring:

Enforcement Actions:



<b>Hi-Tech Plating/The Tinning Company</b>	Facility ID: 13006291
69 Norman Street Everett, MA 02149	

Permit: Issued: 05/17/2022 Expires: 03/15/2024  
 Issued: 05/07/2020 Expires: 03/15/2022 Amended: 08/18/2021 Termination: 05/16/2022  
 Issued: 05/07/2020 Expires: 03/15/2022 Termination: 08/18/2021

National Pretreatment Categorical Standards: 04-Apr-2019 to 433.17 A Metal Finishing

MWRA Category: 01

Sample Locations: 0201 Process Wastewater - Regulated 413 Wastestream - Tinning Co.  
 Process Wastewater - Regulated 433 Wastestream - Hi-Tech Plating  
 0202 Cyanide Waste Stream

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 27-Aug-2021  
23-Feb-2022

Monitoring: 0201 31-Aug-2021  
0201 02-Sep-2021  
0201 23-Nov-2021  
0201 28-Feb-2022  
9100 28-Feb-2022

Enforcement Actions: 06-Jul-2020 Notice of Violation  
21-Oct-2021 Notice of Violation  
07-Dec-2021 Notice of Violation  
08-Dec-2021 Notice of Violation

<b>MBTA Everett Shops</b>	Facility ID: 13006006
80 Broadway Everett, MA 02149	

Permit: Issued: 05/04/2022 Expires: 12/15/2023  
 Issued: 01/07/2020 Expires: 12/15/2021 Termination: 05/03/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 15-Nov-2021  
16-May-2022

Monitoring: 0101 24-Sep-2021  
0101 24-Mar-2022

Enforcement Actions:

***Prolerized New England Company, LLC (PNE)***

Facility ID: 13000150

69 Rover Street  
Everett, MA 02149

<u>Permit:</u>	Issued: 08/09/2019	Expires: 07/15/2023	Amended: 05/12/2022	
	Issued: 08/09/2019	Expires: 07/15/2023	Amended: 08/18/2021	Termination: 05/11/2022
	Issued: 08/09/2019	Expires: 07/15/2023	Amended: 03/18/2021	Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Air Pollution Control Wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 20-Oct-2021  
14-Apr-2022

Monitoring:

Enforcement Actions:

<b>The Leavitt Corporation</b>	Facility ID: 13000351
100 Santilli Highway Everett, MA 02149	

<u>Permit:</u>	Issued: 06/09/2022	Expires: 03/15/2024		
	Issued: 05/04/2020	Expires: 03/15/2022	Amended: 08/18/2021	Termination: 06/08/2022
	Issued: 05/04/2020	Expires: 03/15/2022	Amended: 07/17/2020	Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0201 Process Wastewater - Unregulated Cleaning water from peanut butter making & nut roasting

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 05-Aug-2021  
15-Feb-2022

Monitoring: 0201 14-Sep-2021  
0201 01-Dec-2021

Enforcement Actions:

## Framingham

<b>ADESA Boston</b>	Facility ID: 14101472
63 Western Avenue Framingham, MA 01702	

Permit: Issued: 05/11/2021 Expires: 02/15/2023 Amended: 08/18/2021  
Issued: 05/11/2021 Expires: 02/15/2023 Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Car reconditioning wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 06-Jul-2021  
12-Jan-2022

Monitoring: 0101 29-Jul-2021  
0101 22-Nov-2021  
0101 23-Nov-2021  
0101 22-Feb-2022  
9100 22-Feb-2022

Enforcement Actions:

**BlueTriton Brands, Inc.**

Facility ID: 14101520

105 Pennsylvania Avenue  
Framingham, MA 01701

<u>Permit:</u>	Issued: 06/05/2020	Expires: 05/15/2024	Amended: 08/17/2022	
	Issued: 06/05/2020	Expires: 05/15/2024	Amended: 08/18/2021	Termination: 08/16/2022
	Issued: 06/05/2020	Expires: 05/15/2024		Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

<u>Sample Locations:</u>	0101	OTHER_DESC	RO Reject/Softener
		Process Wastewater - Unregulated	Bottling processes

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 22-Oct-2021  
14-Apr-2022

Monitoring: 0101 20-Jul-2021

Enforcement Actions:

<b>Boston HeartDiagnostics</b>	Facility ID: 14404514
175 Crossing Boulevard Suite 100 Framingham, MA 01702	

Permit: Issued: 06/17/2021 Expires: 06/15/2023 Amended: 08/18/2021  
Issued: 06/17/2021 Expires: 06/15/2023 Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 24-May-2022

Monitoring: 0101 21-Jul-2021

Enforcement Actions:

**Boston HeartDiagnostics**

Facility ID: 14404606

200 Crossing Boulevard  
Framingham, MA 01702

Permit: Issued: 02/14/2022 Expires: 09/15/2023  
Issued: 10/28/2019 Expires: 09/15/2021

Termination: 02/13/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 05-Aug-2021  
11-Feb-2022

Monitoring: 0101 21-Jul-2021  
0101 28-Apr-2022

Enforcement Actions: 02-Apr-2021 Notice of Violation



**Commonwealth of MA DEP Northeast Region**

Facility ID: 14409074

133 -135 Leland Street  
Framingham, MA 01702

Permit: Issued: 07/15/2021 Expires: 06/15/2023 Amended: 08/18/2021  
Issued: 07/15/2021 Expires: 06/15/2023 Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated after treatment

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 24-May-2022

Monitoring:

Enforcement Actions:

**Genzyme Corporation, a Sanofi Company**

Facility ID: 14100249

76 New York Avenue  
Framingham, MA 01701

Permit: Issued: 06/06/2022 Expires: 06/15/2024  
Issued: 06/22/2020 Expires: 06/15/2022 Amended: 08/18/2021 Termination: 06/05/2022  
Issued: 06/22/2020 Expires: 06/15/2022 Termination: 08/18/2021

National Pretreatment Categorical Standards: 17-Jun-2005 to 439.16 A Pharmaceutical Manufacturing

MWRA Category: 01

<u>Sample Locations:</u>	0101	Process Wastewater - Unregulated	R&D lab and HA fermentation wastewater
	0102	Process Wastewater - Regulated	HA fermentation wastewater
	0104	Process Wastewater - Unregulated	Cell Culture Expansion process wastewater
	0105	Process Wastewater - Unregulated	passivation wastewater
	0106	Process Wastewater - Unregulated	laboratory wastewater

Reason for SIU Status: Is a Categorical Industrial User., Has a reasonable potential to violate MWRA limits., Flow greater than 25,000 gpd.

SNC: NO

Inspections: 20-Sep-2021  
19-Nov-2021  
17-Mar-2022  
04-May-2022

<u>Monitoring:</u>	0101	26-Jul-2021
	0101	27-Jul-2021
	0101	14-Oct-2021
	0101	15-Oct-2021
	0101	28-Mar-2022
	0102	19-Oct-2021
	0104	26-Jul-2021
	0104	27-Jul-2021
	0105	10-Sep-2021
	0105	14-Feb-2022
	0106	26-Jul-2021
	0106	27-Jul-2021
	9100	28-Mar-2022

Enforcement Actions: 26-Jan-2021 Notice of Violation

**Metrowest Medical Center - Framingham Union Hospital**

Facility ID: 14005736

115 Lincoln Street  
Framingham, MA 01702

<u>Permit:</u>	Issued: 06/06/2022	Expires: 06/15/2026		
	Issued: 06/18/2018	Expires: 06/15/2022	Amended: 08/18/2021	Termination: 06/05/2022
	Issued: 06/18/2018	Expires: 06/15/2022		Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

<u>Sample Locations:</u>	0201	OTHER_DESC	wastewater from medical laboratory
	0301	Process Wastewater - Unregulated	wastewater from cleaning of medical instruments

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 05-Nov-2021  
10-May-2022

<u>Monitoring:</u>	0201	19-Jul-2021
	0201	20-Jul-2021
	0301	19-Jul-2021

Enforcement Actions:

**P.P. Manufacturing Corporation**

Facility ID: 14102115

175 Crossing Boulevard Suite 200  
Framingham, MA 01702

Permit: Issued: 12/11/2018 Expires: 08/15/2022 Amended: 08/18/2021  
Issued: 12/11/2018 Expires: 08/15/2022 Amended: 02/07/2019 Termination: 08/18/2021

National Pretreatment Categorical Standards: 26-Oct-2012 to 439.17 A Pharmaceutical Manufacturing  
26-Oct-2012 to 439.27 B Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated Manufacturing of veterinary biologics (PPM)  
Process Wastewater - Unregulated Wastewater from LFB-USA

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 08-Sep-2021  
22-Apr-2022

Monitoring: 0101 21-Jul-2021  
0101 16-Mar-2022

Enforcement Actions:

<b>Thermo Fisher Scientific</b>	Facility ID: 14102417
1455 Concord Street Framingham, MA 01701	

Permit: Issued: 08/17/2022 Expires: 03/15/2026  
 Issued: 04/19/2018 Expires: 03/15/2022 Amended: 08/18/2021 Termination: 08/16/2022  
 Issued: 04/19/2018 Expires: 03/15/2022 Termination: 08/18/2021

National Pretreatment Categorical Standards: 15-Mar-2002 to 414.85 H Organic Chemicals, Plastics, and Synthetic Fibers

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated Mfg. of gene sequencing polymers

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 13-Aug-2021  
07-Feb-2022

Monitoring: 0101 13-Oct-2021  
0101 14-Oct-2021  
0101 02-Mar-2022

Enforcement Actions: 09-Jun-2022 Notice of Violation

## Holbrook

**Braintree Laboratories, Part of Sebelo Pharmaceuticals**

Facility ID: 16101023

270 Centre Street  
Holbrook, MA 02343

Permit: Issued: 01/28/2021 Expires: 11/15/2024 Amended: 08/18/2021  
Issued: 01/28/2021 Expires: 11/15/2024 Termination: 08/18/2021

National Pretreatment Categorical Standards: 06-Jun-2008 to 439.47 D Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated Pharmaceutical rinses

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 11-Jan-2022  
27-Apr-2022

Monitoring: 0101 07-Jul-2021  
0101 08-Jul-2021

Enforcement Actions:

<b>Preferred Services Company, Inc.</b>	Facility ID: 16100468
52 Plymouth Street Holbrook, MA 02343	

<u>Permit:</u>	Issued: 03/27/2019	Expires: 03/15/2023	Amended: 08/18/2021	
	Issued: 03/27/2019	Expires: 03/15/2023	Amended: 02/06/2020	Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: YES F3 Quarter: 4

Inspections: 10-Aug-2021  
02-Sep-2021  
10-Feb-2022

Monitoring: 0101 08-Jul-2021

<u>Enforcement Actions:</u>	10-Nov-2020	Notice of Violation
	02-Sep-2021	Notice of Violation
	28-Sep-2021	Notice of Violation

## Jamaica Plain

<b>Brigham &amp; Women's Faulkner Hospital</b>	Facility ID: 51005715
1153 Centre Street Jamaica Plain, MA 02130	

Permit: Issued: 03/30/2022 Expires: 12/15/2023  
Issued: 01/24/2020 Expires: 12/15/2021 Termination: 03/29/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	OTHER_DESC	hospital clinical laboratory
	0201	OTHER_DESC	Washers and sterilizer for hospital surgical instruments
	0202	OTHER_DESC	Washing of contaminated medical tools prior to sterilization
	0203	OTHER_DESC	Cleaning of medical tools prior to sterilization

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 15-Nov-2021  
20-Apr-2022

<u>Monitoring:</u>	0101	04-Nov-2021
	0101	05-Nov-2021
	0201	05-Nov-2021
	0201	14-Apr-2022
	0202	05-Nov-2021
	0203	05-Nov-2021
	0203	14-Apr-2022

Enforcement Actions:



**Commonwealth of Massachusetts Department of Public Health**

Facility ID: 51006016

305 South Street  
Jamaica Plain, MA 02130

<u>Permit:</u>	Issued: 06/01/2021	Expires: 05/15/2025	Amended: 08/20/2021	
	Issued: 06/01/2021	Expires: 05/15/2025	Amended: 08/10/2021	Termination: 08/20/2021
	Issued: 06/01/2021	Expires: 05/15/2025		Termination: 08/09/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0104 OTHER\_DESC Laboratory glassware washer and laboratory sinks.

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES B Quarter: 2

Inspections: 09-Nov-2021

<u>Monitoring:</u>	0104	27-Jul-2021
	0104	28-Jul-2021
	0104	11-Jan-2022

<u>Enforcement Actions:</u>	28-Dec-2020	Notice of Violation
	19-Jan-2021	Notice of Violation
	22-Jun-2022	Notice of Violation

**MBTA - Arborway Maintenance**

Facility ID: 51102177

3550 Washington Street  
Jamaica Plain, MA 02130

<u>Permit:</u>	Issued: 06/10/2022	Expires: 06/15/2024		
	Issued: 06/22/2020	Expires: 06/15/2022	Amended: 08/20/2021	Termination: 06/09/2022
	Issued: 06/22/2020	Expires: 06/15/2022		Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER\_DESC Bus washing

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 18-Oct-2021  
02-May-2022

Monitoring: 0101 12-Aug-2021  
0101 19-Jan-2022

Enforcement Actions:

**VA Boston Healthcare System - Jamaica Plain**

Facility ID: 51005733

150 S. Huntington Avenue S-138  
Jamaica Plain, MA 02130

<u>Permit:</u>	Issued: 10/05/2020	Expires: 08/15/2022	Amended: 04/28/2022	
	Issued: 10/05/2020	Expires: 08/15/2022	Amended: 08/20/2021	Termination: 04/27/2022
	Issued: 10/05/2020	Expires: 08/15/2022		Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0103	Process Wastewater - Unregulated	Waterwater from surgical tool cleaning in the SPD area
	0104	Process Wastewater - Unregulated	Cage washer in Building 1A
	0105	Process Wastewater - Unregulated	Steam sterilizer in Building 1A
	0107	Process Wastewater - Unregulated	Wastewater from the spigot situated in Room E4-112 on the fourth floor
	0108	Process Wastewater - Regulated	
	0109	Process Wastewater - Regulated	
	0301	Process Wastewater - Unregulated	Wastewater from animal cage washer on first floor in Building 7

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

<u>SNC:</u>	YES B	Quarter: 1
	F3	Quarter: 1
	B	Quarter: 2
	B	Quarter: 4

Inspections: 22-Jul-2021  
14-Jan-2022

<u>Monitoring:</u>	0103	27-Jul-2021
	0103	23-Nov-2021
	0103	24-Nov-2021
	0104	27-Jul-2021
	0105	20-Jan-2022
	0107	26-Jul-2021
	0108	23-Nov-2021

<u>Enforcement Actions:</u>	05-Jan-2021	Notice of Violation
	21-Dec-2021	Notice of Violation
	09-Jun-2022	Notice of Violation

## Lexington

***BAE Systems Information & Electronic Systems Integration***

Facility ID: 17001160

2 Forbes Road  
Lexington, MA 02421

Permit: Issued: 06/25/2019 Expires: 06/15/2023 Amended: 08/18/2021  
Issued: 06/25/2019 Expires: 06/15/2023 Termination: 08/18/2021

National Pretreatment Categorical Standards: 24-May-2007 to 469.18 A Electrical and Electronic Components

MWRA Category: 02

Sample Locations: 0115 Process Wastewater - Regulated Semiconductor manufacturing, research, and development wastewater

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 23-Aug-2021  
07-Feb-2022

Monitoring: 0115 15-Jul-2021

Enforcement Actions:

<b>M.I.T. Lincoln Laboratory</b>	Facility ID: 17100088
244 Wood Street Lexington, MA 02420	

Permit: Issued: 05/17/2022 Expires: 07/15/2023  
 Issued: 06/25/2019 Expires: 07/15/2021 Termination: 05/16/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	OTHER_DESC	Microelectronics research and development laboratories
	0102	OTHER_DESC	Microelectronics research and development laboratories
	0103	OTHER_DESC	Microelectronics research and development & biological research labo
	0104	OTHER_DESC	Microelectronics research and development laboratories

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 06-Oct-2021  
20-Apr-2022

<u>Monitoring:</u>	0101	12-Jul-2021
	0101	21-Oct-2021
	0102	12-Jul-2021
	0102	13-Jul-2021
	0103	12-Jul-2021
	0103	13-Jul-2021
	0103	22-Oct-2021
	0104	12-Jul-2021
	0104	13-Jul-2021
	0104	21-Oct-2021
	0104	22-Oct-2021
	0104	14-Feb-2022
	9100	14-Feb-2022

Enforcement Actions: 12-Nov-2021 Notice of Violation

**Shire Human Genetic Therapies, Inc.**

Facility ID: 17403364

300 Shire Way  
Lexington, MA 02421

<u>Permit:</u>	Issued: 05/18/2022	Expires: 03/15/2026		
	Issued: 05/22/2018	Expires: 03/15/2022	Amended: 08/18/2021	Termination: 05/17/2022
	Issued: 05/22/2018	Expires: 03/15/2022	Amended: 08/14/2018	Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

<u>Sample Locations:</u>	0101	OTHER_DESC	Process wastewater from biopharmaceutical manufacturing facility
	0201	Process Wastewater - Unregulated	biomedical tech waste water
	0301	Process Wastewater - Unregulated	biomedical tech waste water
	0501	Process Wastewater - Unregulated	biomedical tech waste water

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 10-Sep-2021  
09-Feb-2022

<u>Monitoring:</u>	0101	14-Jul-2021
	0101	15-Jul-2021
	0101	17-Aug-2021
	0201	19-Jul-2021
	0201	20-Jul-2021
	0301	14-Jul-2021
	0301	15-Jul-2021
	0301	16-Aug-2021
	0301	17-Aug-2021
	0301	26-Apr-2022
	0501	20-Jul-2021
	0501	16-Aug-2021

Enforcement Actions:

## Malden

***F.M. Callahan & Sons, Inc.***

Facility ID: 18005023

22 Sharon Street  
Malden, MA 02148

Permit: Issued: 01/11/2022  
Issued: 05/23/2019

Expires: 06/15/2023  
Expires: 06/15/2021

Termination: 01/10/2022

National Pretreatment Categorical Standards: 23-Apr-2013 to 433.17 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 OTHER\_DESC Metal plating and finishing  
0102 OTHER\_DESC 433 cyanide destruct

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 09-Nov-2021  
16-May-2022

Monitoring:

0101	13-Jul-2021
0101	15-Jul-2021
0101	16-Nov-2021
0101	21-Dec-2021
0101	22-Feb-2022
0101	21-Mar-2022
0102	16-Jul-2021
9100	21-Mar-2022

Enforcement Actions:

## Mattapan

**UMass Medical School - MassBiologics**

Facility ID: 52103302

458 460 Walk Hill Street  
Mattapan, MA 02126

Permit: Issued: 03/16/2022  
Issued: 04/30/2018

Expires: 10/15/2025  
Expires: 10/15/2021

Termination: 03/15/2022

National Pretreatment Categorical Standards: 24-Jun-2008 to 439.26 B Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 OTHER\_DESC Production of Monoclonal Antibodies  
0201 OTHER\_DESC R&D and Manufacturing

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 10-Sep-2021  
17-Mar-2022

Monitoring: 0101 04-Nov-2021  
0101 05-Nov-2021  
0101 29-Mar-2022  
0101 30-Mar-2022  
0201 04-Nov-2021  
0201 05-Nov-2021  
0201 29-Mar-2022  
0201 30-Mar-2022

Enforcement Actions: 08-Dec-2020 Notice of Violation



## Medford

<b>Boston Group</b>	Facility ID: 19000222
400 Riverside Avenue Medford, MA 02155	

Permit: Issued: 11/23/2020 Expires: 09/15/2025 Amended: 08/20/2021  
Issued: 11/23/2020 Expires: 09/15/2025 Termination: 08/20/2021

National Pretreatment Categorical Standards: 16-Nov-2005 to 433.15 A Metal Finishing

MWRA Category: 04

Sample Locations: 0104

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 13-Aug-2021

Monitoring:

Enforcement Actions: 21-Aug-2020 Notice of Violation  
25-Aug-2021 Notice of Violation  
01-Apr-2022 Notice of Violation

**MBTA Fellsway Bus Garage**

Facility ID: 19007805

447 Salem Street  
Medford, MA 02155

Permit: Issued: 05/04/2022 Expires: 04/15/2023  
Issued: 03/28/2019 Expires: 04/15/2021

Termination: 05/03/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 20-Sep-2021  
21-Mar-2022

Monitoring: 0101 14-Jul-2021

Enforcement Actions:

<b>MBTA Wellington Carhouse</b>	Facility ID: 19101411
37 Revere Beach Parkway Medford, MA 02155	

Permit: Issued: 05/19/2022 Expires: 06/15/2024  
Issued: 07/18/2018 Expires: 06/15/2020 Termination: 05/18/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER\_DESC Automated rail vehicle washer

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 22-Oct-2021  
02-May-2022

Monitoring:

Enforcement Actions:

**Monogram Gourmet Foods LLC**

Facility ID: 19409246

300 Middlesex Avenue  
Medford, MA 02155

Permit: Issued: 04/12/2022 Expires: 02/15/2026

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated Equipment washing, sanitation, and plant wash down

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 01-Dec-2021  
06-May-2022

Monitoring:

Enforcement Actions:

<b>Tufts University, Somerville_Medford Campus</b>	Facility ID: 19003634
419 Boston Avenue Medford, MA 02155	

Permit: Issued: 06/10/2022 Expires: 05/15/2024  
 Issued: 08/29/2019 Expires: 08/15/2021 Termination: 06/09/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0201 OTHER_DESC 0601 OTHER_DESC 0702 Process Wastewater - Unregulated 0801 Process Wastewater - Unregulated	Lab wastewater from Pearson & Michaels Building's discharge. Chemical engineering and optics lab wastewater discharge. Wastewater from labs of SEC Building. Physics labs
--------------------------	--	--

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 12-Jul-2021  
10-Jan-2022

<u>Monitoring:</u>	0201 17-Sep-2021 0201 12-Jan-2022 0201 13-Jan-2022 0601 16-Sep-2021 0601 17-Sep-2021 0601 08-Nov-2021 0601 09-Nov-2021 0601 10-Nov-2021 0702 16-Sep-2021 0702 17-Sep-2021 0702 27-Sep-2021 0702 30-Sep-2021 0702 01-Oct-2021 0801 16-Sep-2021 0801 09-Nov-2021
--------------------	--

<u>Enforcement Actions:</u>	21-Aug-2020 Notice of Violation 28-Oct-2020 Notice of Violation 11-Dec-2020 Notice of Violation
-----------------------------	---

## Melrose

**Churchill Corporation**

Facility ID: 20000775

344 Franklin Street  
Melrose, MA 02176

Permit: Issued: 06/28/2022 Expires: 03/15/2024  
Issued: 04/27/2020 Expires: 03/15/2022 Amended: 08/18/2021 Termination: 06/27/2022  
Issued: 04/27/2020 Expires: 03/15/2022 Termination: 08/18/2021

National Pretreatment Categorical Standards: 01-Apr-1991 to 433.15 A Metal Finishing

MWRA Category: 02

Sample Locations: 0101 OTHER\_DESC Chromating / iridite line

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 03-Aug-2021  
01-Feb-2022

Monitoring: 0101 02-Dec-2021  
0101 03-Dec-2021  
0101 14-Dec-2021  
0101 22-Feb-2022  
0101 21-Mar-2022  
9100 21-Mar-2022

Enforcement Actions:

**Hallmark Health Systems-Melrose\_Wakefield Healthcare, Inc.**

Facility ID: 20005760

585 Lebanon Street  
Melrose, MA 02176

Permit: Issued: 06/28/2019 Expires: 06/15/2023 Amended: 08/18/2021  
Issued: 06/28/2019 Expires: 06/15/2023 Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 OTHER\_DESC Hospital central sterilization area and clinical lab.

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 10-Jan-2022

Monitoring: 0101 03-Nov-2021  
0101 04-Nov-2021  
0101 14-Feb-2022  
0101 15-Feb-2022

Enforcement Actions:

## Milton

**Beth Israel Deaconess Hospital-Milton Inc.**

Facility ID: 21006031

199 Reedsdale Road  
Milton, MA 02186

Permit: Issued: 06/03/2020 Expires: 01/15/2024 Amended: 08/18/2021  
Issued: 06/03/2020 Expires: 01/15/2024 Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0202 Process Wastewater - Unregulated Clinical laboratory wastewater  
0301 Process Wastewater - Unregulated  
0302 Process Wastewater - Unregulated  
0303 Process Wastewater - Unregulated  
0304 Process Wastewater - Unregulated  
0305 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES A Quarter: 1  
B Quarter: 1  
B Quarter: 3  
B Quarter: 4

Inspections: 28-Jan-2022

Monitoring: 0202 02-Nov-2021  
0202 03-Nov-2021  
0301 02-Nov-2021  
0302 02-Nov-2021  
0303 03-Nov-2021  
0303 06-May-2022  
0304 01-Nov-2021  
0305 02-Nov-2021

Enforcement Actions: 19-Oct-2021 Notice of Violation  
28-Feb-2022 Notice of Violation



## Natick

**U.S. Army Soldier Systems Center**

Facility ID: 22001808

10 General Greene Avenue  
Natick, MA 01760

Permit: Issued: 05/06/2021  
Issued: 05/06/2021

Expires: 02/15/2023  
Expires: 02/15/2023

Amended: 08/18/2021

Termination: 08/18/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0501 Process Wastewater - Unregulated  
0601 Process Wastewater - Unregulated  
0801 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 17-Aug-2021  
23-Feb-2022

Monitoring: 0501 28-Jul-2021  
0501 29-Dec-2021  
0501 31-Jan-2022  
0601 29-Jul-2021  
0601 03-Feb-2022  
0801 28-Jul-2021  
0801 19-Jan-2022  
9100 31-Jan-2022

Enforcement Actions:

## Needham

**Fortune Metal Finishing Corp.**

Facility ID: 23002853

95 Hampton Street  
Needham, MA 02494

Permit: Issued: 03/16/2021 Expires: 01/15/2023 Amended: 08/19/2021  
Issued: 03/16/2021 Expires: 01/15/2023 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Tumbling & deburring effluent

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 09-Sep-2021  
20-Apr-2022

Monitoring: 0101 04-Nov-2021  
0101 17-May-2022

Enforcement Actions:

<b>Microwave Development Labs, Inc.</b>	Facility ID: 23002892
135 Crescent Road Needham, MA 02494	

Permit: Issued: 02/28/2022 Expires: 08/15/2023  
 Issued: 06/25/2019 Expires: 08/15/2021 Termination: 02/27/2022

National Pretreatment Categorical Standards: 01-Apr-1991 to 433.15 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated metal finishing of aluminum and copper

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 21-Jul-2021  
18-Jan-2022

Monitoring:

0101	30-Aug-2021
0101	31-Aug-2021
0101	25-Jan-2022
0101	14-Feb-2022
0101	29-Mar-2022
0101	30-Mar-2022
9100	14-Feb-2022

Enforcement Actions: 11-Jan-2021 Notice of Violation  
30-Aug-2021 Notice of Violation

## Newton

**MBTA Riverside Carhouse**

Facility ID: 24003508

325 Grove Street  
Newton, MA 02165

Permit: Issued: 02/07/2022  
Issued: 09/13/2019

Expires: 09/15/2023  
Expires: 09/15/2021

Termination: 02/06/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated wastewater from washing of trolleys

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 03-Aug-2021  
23-Feb-2022

Monitoring: 0101 29-Nov-2021  
0101 30-Nov-2021  
0101 23-Mar-2022  
0101 24-Mar-2022

Enforcement Actions:

**Materion Newton, Inc.**

Facility ID: 24003511

45 Industrial Place  
Newton, MA 02461

Permit: Issued: 03/17/2022 Expires: 08/15/2023 Amended: 04/28/2022  
Issued: 03/17/2022 Expires: 08/15/2023 Termination: 04/27/2022  
Issued: 10/10/2019 Expires: 08/15/2021 Termination: 03/16/2022

National Pretreatment Categorical Standards: 26-Jun-2007 to 421.115 K Nonferrous Metals Manufacturing  
26-Jun-2007 to 471.54 E Nonferrous Metals Forming and Metal Powders

MWRA Category: 01

<u>Sample Locations:</u>	0102	Process Wastewater - Unregulated	Ta powder washing operations
	0301	Process Wastewater - Unregulated	Lab (glassware/cleaning bath) sink discharge
	0401	Process Wastewater - Regulated	leaching of tantalum powder with hydrogen peroxide and H2SO4
	0602	Process Wastewater - Regulated	(n) large, medium, small Billcos washing units, intermediate mill ultras
		Process Wastewater - Regulated	(t) water jet cutter
		Process Wastewater - Regulated	(w) tubing ultrasonic test, tubing hydrostatic test, disc ultrasonic test
		Process Wastewater - Regulated	(o) large, medium, small Billcos, intermediate mill ultrasonic rinsing uni
	0603	Process Wastewater - Unregulated	wastewater from Ta milled products
	0901		

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 31-Aug-2021  
10-Jan-2022

<u>Monitoring:</u>	0102	28-Jan-2022
	0301	07-Dec-2021
	0401	07-Dec-2021
	0401	26-Jan-2022
	0401	28-Feb-2022
	0602	26-Jul-2021
	0602	28-Jul-2021
	0602	08-Nov-2021
	0603	26-Jul-2021

Enforcement Actions:

**Newton-Wellesley Hospital**

Facility ID: 24005761

2014 Washington Street  
Newton, MA 02462

Permit: Issued: 05/31/2022 Expires: 04/15/2024  
Issued: 04/27/2020 Expires: 04/15/2022 Amended: 08/19/2021 Termination: 05/30/2022  
Issued: 04/27/2020 Expires: 04/15/2022 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	Process Wastewater - Unregulated	Hospital laboratory wastewater
	0102	Process Wastewater - Unregulated	
	0133	Process Wastewater - Unregulated	
	0136	Process Wastewater - Unregulated	A steam sterilizer
	0137	Process Wastewater - Unregulated	
	0140	Process Wastewater - Unregulated	bank of 3 sinks
	0141	Process Wastewater - Unregulated	bank of 3 sinks
	0142	Process Wastewater - Unregulated	
	0143	Process Wastewater - Unregulated	
	0144	Process Wastewater - Unregulated	
	0145	Process Wastewater - Unregulated	
	0146	Process Wastewater - Unregulated	
	0147	Process Wastewater - Unregulated	
	0154	Process Wastewater - Unregulated	Ultrasonic, Endoscope, and Irrigator effluent

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 14-Sep-2021  
09-Mar-2022

<u>Monitoring:</u>	0101	25-Oct-2021
	0101	26-Oct-2021
	0101	16-Feb-2022
	0102	25-Oct-2021
	0133	27-Oct-2021
	0133	04-Nov-2021
	0136	28-Jun-2021
	0136	26-Oct-2021
	0137	25-Oct-2021
	0137	26-Oct-2021
	0140	17-Mar-2022
	0141	04-Nov-2021
	0141	15-Feb-2022
	0142	29-Nov-2021

**Newton-Wellesley Hospital**

Facility ID: 24005761

2014 Washington Street  
Newton, MA 02462

0143	26-Oct-2021
0144	17-Mar-2022
0145	25-Oct-2021
0146	25-Oct-2021
0147	25-Oct-2021
0153	27-Oct-2021
0153	04-Nov-2021
0153	17-Mar-2022
0154	27-Oct-2021

<u>Enforcement Actions:</u>	16-Nov-2020	Notice of Violation
	28-Dec-2020	Notice of Violation

## Norwood

**Absolute Metal Finishing, Inc.**

Facility ID: 25100244

90 Morse Street  
Norwood, MA 02062

Permit: Issued: 12/30/2021  
Issued: 08/28/2019

Expires: 09/15/2023  
Expires: 09/15/2021

Termination: 12/29/2021

National Pretreatment Categorical Standards: 03-Aug-2007 to 433.17 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 OTHER\_DESC Metal finishing operations  
0102 OTHER\_DESC cyanide treatment

Reason for SIU Status: Is a Categorical Industrial User., Has a reasonable potential to violate MWRA limits.

SNC: YES F3 Quarter: 3

Inspections: 10-Aug-2021  
17-Feb-2022

Monitoring: 0101 24-Aug-2021  
0101 28-Sep-2021  
0101 14-Feb-2022  
0102 24-Aug-2021  
9100 14-Feb-2022

Enforcement Actions: 31-Aug-2021 Notice of Violation



<b>Goldman Kolber, LLC (GK Jewelry Inc.)</b>	Facility ID: 25101050
185 Dean Street Norwood, MA 02062	

Permit: Issued: 10/03/2019 Expires: 10/15/2023 Amended: 08/20/2021  
 Issued: 10/03/2019 Expires: 10/15/2023 Termination: 08/20/2021

National Pretreatment Categorical Standards: 02-Jan-1996 to 433.17 A Metal Finishing

MWRA Category: 04

Sample Locations:

Reason for SIU Status: Is a CIU without flow.

SNC: YES F3 Quarter: 1  
 F3 Quarter: 3

Inspections: 26-Apr-2022

Monitoring:

Enforcement Actions: 31-Aug-2020 Notice of Violation  
 08-Sep-2021 Notice of Violation  
 26-Apr-2022 Notice of Violation

<b>Home Market Foods, Inc.</b>	Facility ID: 25103149
140 Morgan Drive Norwood, MA 02062	

Permit: Issued: 03/16/2022 Expires: 11/15/2023  
 Issued: 10/31/2019 Expires: 10/15/2021 Amended: 12/24/2019 Termination: 03/15/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER\_DESC Food processing wastewater

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 04-Oct-2021  
11-Mar-2022

Monitoring: 0101 17-Aug-2021  
0101 18-Aug-2021

Enforcement Actions: 16-Mar-2021 Notice of Violation  
22-Apr-2022 Notice of Violation

<b>Organogenesis Inc.</b>	Facility ID: 25407804
333 Providence Highway Norwood, MA 02062	

Permit: Issued: 03/03/2020 Expires: 01/15/2024 Amended: 08/19/2021  
 Issued: 03/03/2020 Expires: 01/15/2024 Termination: 08/19/2021

National Pretreatment Categorical Standards: 02-Jul-2019 to 439.47 D Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated pharmaceutical wastewater  
 0102 Process Wastewater - Unregulated Lab sinks and parts washer

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 28-Jan-2022  
 29-Jun-2022

Monitoring: 0102 04-Nov-2021  
 0102 05-Nov-2021

Enforcement Actions: 08-Jul-2020 Notice of Violation

**Steel Art Co., Inc.**

Facility ID: 25403864

189 Dean Street  
Norwood, MA 02062

Permit: Issued: 06/25/2021 Expires: 06/15/2026 Amended: 08/20/2021  
Issued: 06/25/2021 Expires: 06/15/2026 Termination: 08/20/2021

National Pretreatment Categorical Standards: 01-Jul-2012 to 433.17 A Metal Finishing

MWRA Category: 04

Sample Locations:

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 26-Apr-2022

Monitoring:

Enforcement Actions: 26-Feb-2021 Notice of Violation

<b>TE Connectivity</b>	Facility ID: 25102934
63 Nahatan Street Norwood, MA 02062	

Permit: Issued: 06/25/2021 Expires: 04/15/2023 Amended: 08/19/2021  
 Issued: 06/25/2021 Expires: 04/15/2023 Termination: 08/19/2021

National Pretreatment Categorical Standards: 03-Apr-2002 to 433.17 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated metal finishing  
 0102 Cyanide Waste Stream Cyanide finishing processes which result in wastewater that is treated

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 23-Mar-2022

Monitoring: 0101 24-Aug-2021  
 0101 28-Sep-2021  
 0101 22-Feb-2022  
 0102 23-Aug-2021  
 9100 22-Feb-2022

Enforcement Actions:

<b>TecMark Plating</b>	Facility ID: 25003993
61 Endicott Street Building #5 Norwood, MA 02062	

Permit: Issued: 10/19/2021 Expires: 08/15/2023  
 Issued: 07/15/2019 Expires: 08/15/2021 Termination: 10/18/2021

National Pretreatment Categorical Standards: 02-Apr-1991 to 433.17 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 OTHER\_DESC Circuit manufacturing

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 06-Jul-2021  
07-Mar-2022

Monitoring: 0101 25-Aug-2021  
0101 03-Nov-2021  
0101 14-Feb-2022  
9100 14-Feb-2022

Enforcement Actions:

## Quincy

<b>City of Quincy DPW (Truck Wash Facility)</b>	Facility ID: 26404189
55 -R Sea Street Quincy, MA 02169	

Permit: Issued: 03/17/2022 Expires: 10/15/2023  
Issued: 10/30/2019 Expires: 10/15/2021 Termination: 03/16/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Vehicle wash

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 19-Oct-2021  
22-Mar-2022

Monitoring: 0101 27-Jul-2021  
0101 28-Jul-2021  
0101 09-Dec-2021

Enforcement Actions:

**MBTA - Quincy Bus Garage**

Facility ID: 26101131

954 Hancock Street  
Quincy, MA 02169

Permit: Issued: 06/17/2021 Expires: 07/15/2023 Amended: 08/19/2021  
Issued: 06/17/2021 Expires: 07/15/2023 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 14-Dec-2021  
22-Jun-2022

Monitoring: 0101 28-Jul-2021  
0101 09-Jun-2022

Enforcement Actions:



<b>Quincy AutoAuction</b>	Facility ID: 26103080
196 Ricciuti Drive Quincy, MA 02169	

Permit: Issued: 06/16/2021 Expires: 04/15/2023 Amended: 08/19/2021  
 Issued: 06/16/2021 Expires: 04/15/2023 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER\_DESC Vehicle Washing with detergent

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 24-Mar-2022

Monitoring: 0101 13-Jul-2021  
 0101 14-Jul-2021  
 0101 01-Sep-2021

Enforcement Actions: 01-Feb-2021 Notice of Violation  
 16-Mar-2021 Notice of Violation

**South Shore Plating Co., Inc.**

Facility ID: 26005040

28 Forest Avenue  
Quincy, MA 02169

Permit: Issued: 06/01/2021 Expires: 02/15/2023 Amended: 08/19/2021  
Issued: 06/01/2021 Expires: 02/15/2023 Termination: 08/19/2021

National Pretreatment Categorical Standards: 10-Jul-1992 to 413.14 A Electroplating

MWRA Category: 01

Sample Locations: 0101 OTHER\_DESC Metal Finishing Operation

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 23-Aug-2021  
08-Feb-2022

Monitoring: 0101 14-Jul-2021  
0101 02-Sep-2021  
0101 14-Feb-2022  
9100 14-Feb-2022

Enforcement Actions:

***Twin Rivers Technologies Manufacturing Corporation***

Facility ID: 26101157

780 Washington Street  
Quincy, MA 02169

Permit: Issued: 03/17/2022 Expires: 11/15/2023  
Issued: 02/07/2020 Expires: 11/15/2021 Termination: 03/16/2022

National Pretreatment Categorical Standards: 23-Jul-1999 to 417.24 B Soap and Detergent Manufacturing

MWRA Category: 01

Sample Locations: 0101 OTHER\_DESC fatty acids and glycerin

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 05-Oct-2021  
19-Apr-2022

Monitoring: 0101 16-Aug-2021  
0101 17-Aug-2021  
0101 03-Jan-2022  
0101 04-Jan-2022

Enforcement Actions: 18-Mar-2022 Notice of Violation

## Randolph

**Accurate Metal Finishing, LLC**

Facility ID: 27001200

414 South Street  
Randolph, MA 02368

Permit: Issued: 01/13/2021 Expires: 10/15/2022 Amended: 08/19/2021  
Issued: 01/13/2021 Expires: 10/15/2022 Termination: 08/19/2021

National Pretreatment Categorical Standards: 14-Jun-2002 to 433.17 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 OTHER\_DESC Metal Finishing

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 02-Sep-2021  
01-Mar-2022

Monitoring: 0101 26-Aug-2021  
0101 02-Nov-2021  
0101 03-Nov-2021  
0101 31-Jan-2022  
9100 31-Jan-2022

Enforcement Actions: 01-Apr-2022 Notice of Violation

**BFI Waste Systems of North America, Inc.**

Facility ID: 27007148

62 Johnson Drive  
Randolph, MA 02368

Permit: Issued: 05/09/2019 Expires: 05/15/2023 Amended: 08/19/2021  
Issued: 05/09/2019 Expires: 05/15/2023 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 08-Jul-2021  
14-Jan-2022

<u>Monitoring:</u>	0101	16-Aug-2021
	0101	17-Aug-2021
	0101	21-Dec-2021
	0101	22-Dec-2021
	0101	14-Mar-2022
	0101	22-Mar-2022
	0101	23-Mar-2022
	9100	14-Mar-2022

Enforcement Actions:

**Flexcon Industries**

Facility ID: 27007231

300 Pond Street  
Randolph, MA 02368

Permit: Issued: 06/25/2021 Expires: 03/15/2025 Amended: 08/19/2021  
Issued: 06/25/2021 Expires: 03/15/2025 Termination: 08/19/2021

National Pretreatment Categorical Standards: 01-Jul-1990 to 433.17 A Metal Finishing

MWRA Category: 02

Sample Locations: 0101 OTHER\_DESC Phosphating Line

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 03-Nov-2021  
06-May-2022

Monitoring: 0101 26-Aug-2021  
0101 30-Sep-2021  
0101 24-Jan-2022  
9100 24-Jan-2022

Enforcement Actions: 09-Nov-2020 Notice of Violation

<b>Trelleborg Applied Technologies</b>	Facility ID: 27101860
24 Teed Drive Randolph, MA 02368	

Permit: Issued: 03/24/2022 Expires: 10/15/2023  
 Issued: 01/31/2020 Expires: 10/15/2021 Termination: 03/23/2022

National Pretreatment Categorical Standards: 20-Mar-1997 to 463.16 A Plastics Molding and Forming  
 20-Mar-1997 to 463.999 A Plastics Molding and Forming

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 18-Oct-2021  
09-Mar-2022

Monitoring: 0101 30-Sep-2021  
0101 01-Oct-2021  
0101 04-May-2022  
9100 04-May-2022

Enforcement Actions: 24-Aug-2021 Notice of Violation  
09- Nov-2021 Notice of Violation

## Roxbury

**BWSC Truck Wash Facility**

Facility ID: 54404742

980 Harrison Avenue  
Roxbury, MA 02119

Permit: Issued: 06/10/2022 Expires: 02/15/2024  
Issued: 05/07/2020 Expires: 02/15/2022 Amended: 08/20/2021 Termination: 06/09/2022  
Issued: 05/07/2020 Expires: 02/15/2022 Termination: 08/20/2021

National Pretreatment Categorical Standards:MWRA Category: 01Sample Locations: 0101 Process Wastewater - Unregulated truck washingReason for SIU Status: Has a reasonable potential to violate MWRA limits.SNC: NOInspections: 01-Jul-2021  
05-Jan-2022Monitoring: 0101 23-Nov-2021Enforcement Actions:



<b>MBTA Southamptn Street Maintenance Facility</b>	Facility ID: 54103220
240 Southamptn Street Roxbury, MA 02118	

Permit: Issued: 06/17/2021 Expires: 06/15/2023 Amended: 08/20/2021  
 Issued: 06/17/2021 Expires: 06/15/2023 Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER\_DESC bus washing

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 06-Dec-2021  
08-Jun-2022

Monitoring: 0101 31-Aug-2021  
0101 01-Sep-2021  
0101 19-Apr-2022  
0101 20-Apr-2022

Enforcement Actions:

<b>New England Baptist Hospital</b>	Facility ID: 54101786
125 Parker Hill Avenue Roxbury, MA 02120	

Permit: Issued: 05/23/2019 Expires: 06/15/2023 Amended: 08/20/2021  
 Issued: 05/23/2019 Expires: 06/15/2023 Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

<u>Sample Locations:</u>	0101	OTHER_DESC	Surgical Training and Histology
	0103	Process Wastewater - Unregulated	surgical instrument cleaning
	0201	OTHER_DESC	Medical laboratories

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 02-Dec-2021  
06-Jun-2022

<u>Monitoring:</u>	0101	20-Jan-2022
	0103	13-Jul-2021
	0103	14-Jul-2021
	0103	10-Aug-2021
	0103	11-Aug-2021
	0201	13-Jul-2021
	0201	02-Sep-2021

Enforcement Actions: 04-Feb-2021 Notice of Violation

<b>United Rentals (North America), Inc.</b>	Facility ID: 54102393
133 Southampton Street Roxbury, MA 02118	

<u>Permit:</u>	Issued: 06/06/2022	Expires: 06/15/2024		
	Issued: 05/04/2020	Expires: 06/15/2022	Amended: 08/20/2021	Termination: 06/05/2022
	Issued: 05/04/2020	Expires: 06/15/2022		Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0201 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 02-Nov-2021  
03-May-2022

Monitoring: 0201 31-Aug-2021  
0201 23-Jun-2022

Enforcement Actions:

## Somerville

<b>Century Linen East LLC</b>	Facility ID: 30103290
30 Innerbelt Road Somerville, MA 02143	

<u>Permit:</u>	Issued: 02/08/2019	Expires: 02/15/2023	Amended: 04/26/2022	
	Issued: 02/08/2019	Expires: 02/15/2023	Amended: 08/19/2021	Termination: 04/25/2022
	Issued: 02/08/2019	Expires: 02/15/2023		Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 01-Nov-2021  
06-May-2022

<u>Monitoring:</u>	0101	12-Jul-2021
	0101	13-Jul-2021
	0101	21-Oct-2021
	0101	12-Jan-2022
	0101	13-Jan-2022
	0101	31-Jan-2022
	0101	01-Feb-2022

<u>Enforcement Actions:</u>	11-May-2022	Notice of Violation
	11-May-2022	Notice of Violation

**Keolis Commuter Services, LLC**

Facility ID: 30102003

70 Rear Third Avenue  
Somerville, MA 02143

Permit: Issued: 05/11/2021 Expires: 03/15/2023 Amended: 08/19/2021  
Issued: 05/11/2021 Expires: 03/15/2023 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Train maintenance wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 12-Jul-2021  
14-Jan-2022

Monitoring: 0101 09-Nov-2021  
0101 10-Nov-2021  
0101 04-Jan-2022  
0101 05-Jan-2022

Enforcement Actions: 31-Aug-2020 Extension of NON/OTCA/EO/SOC/NPPR Letter  
16-Sep-2020 Extension of NON/OTCA/EO/SOC/NPPR Letter  
28-Sep-2021 Extension of NON/OTCA/EO/SOC/NPPR Letter

**Royal Hospitality Services, Inc.**

Facility ID: 30007496

520 Columbia Street  
Somerville, MA 02143

Permit: Issued: 06/06/2022 Expires: 04/15/2026  
Issued: 06/08/2018 Expires: 04/15/2022 Amended: 08/19/2021 Termination: 06/05/2022  
Issued: 06/08/2018 Expires: 04/15/2022 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated Laundry effluent

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 10-Sep-2021  
07-Mar-2022

Monitoring: 0101 13-Jul-2021  
0101 09-Nov-2021

Enforcement Actions:

<b>Tracer Technologies, Inc.</b>	Facility ID: 30006705
20 Assembly Square Drive Somerville, MA 02145	

Permit: Issued: 03/16/2019 Expires: 03/15/2024 Amended: 08/20/2021  
Issued: 03/16/2019 Expires: 03/15/2024 Termination: 08/20/2021

National Pretreatment Categorical Standards: 15-May-1992 to 461.55 E Battery Manufacturing

MWRA Category: 04

Sample Locations: 0101

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 21-Dec-2021

Monitoring:

Enforcement Actions:

## South Boston

**Great Eastern Seafood**

Facility ID: 55002326

88 Black Falcon Avenue Suite 160  
South Boston, MA 02210

<u>Permit:</u>	Issued: 08/30/2022	Expires: 08/15/2026		
	Issued: 06/28/2018	Expires: 08/15/2022	Amended: 08/20/2021	Termination: 08/29/2022
	Issued: 06/28/2018	Expires: 08/15/2022	Amended: 05/01/2019	Termination: 08/20/2021

National Pretreatment Categorical Standards:MWRA Category: 02Sample Locations:Reason for SIU Status: Flow greater than 25,000 gpd.SNC: NOInspections: 07-Feb-2022Monitoring: 0101 28-Jun-2022Enforcement Actions:



<b>MBTA - Cabot Yard</b>	Facility ID: 55100009
275 Dorchester Avenue South Boston, MA 02127	

Permit: Issued: 03/16/2022 Expires: 11/15/2023  
 Issued: 12/10/2019 Expires: 11/15/2021 Termination: 03/15/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated  
 0201 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 06-Oct-2021  
 15-Apr-2022

Monitoring: 0101 12-Aug-2021  
 0101 13-Aug-2021  
 0101 21-Mar-2022  
 0101 22-Mar-2022  
 0201 30-Jun-2022

Enforcement Actions:

**Mass Bay Brewing Company Inc.**

Facility ID: 55006785

306 Northern Avenue  
South Boston, MA 02210

<u>Permit:</u>	Issued: 02/25/2022	Expires: 02/15/2026		
	Issued: 05/14/2018	Expires: 02/15/2022	Amended: 08/20/2021	Termination: 02/24/2022
	Issued: 05/14/2018	Expires: 02/15/2022		Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated Cleaning and Sterilizing Ops.

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 21-Jul-2021  
03-Jan-2022

<u>Monitoring:</u>	0101	23-Aug-2021
	0101	24-Aug-2021
	0101	25-Apr-2022
	9100	25-Apr-2022

Enforcement Actions:

**Massachusetts Department of Transportation (S.Bos VB #1&5)**

Facility ID: 55103065

55 Dorchester Avenue Building 1  
South Boston, MA 02127

<u>Permit:</u>	Issued: 06/10/2022	Expires: 04/15/2024		
	Issued: 05/04/2020	Expires: 04/15/2022	Amended: 08/20/2021	Termination: 06/09/2022
	Issued: 05/04/2020	Expires: 04/15/2022		Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

<u>Sample Locations:</u>	0101	Process Wastewater - Unregulated
	0201	Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 25-Mar-2022

<u>Monitoring:</u>	0101	18-Sep-2021
	0101	22-Oct-2021
	0201	18-Sep-2021
	0201	09-Oct-2021
	0201	22-Oct-2021

Enforcement Actions:

**Massachusetts Department of Transportation (Ted W VB #6)**

Facility ID: 55008794

2 FID Kennedy Avenue VB #6  
South Boston, MA 02210

<u>Permit:</u>	Issued: 06/09/2022	Expires: 04/15/2026		
	Issued: 05/04/2020	Expires: 04/15/2022	Amended: 08/20/2021	Termination: 06/08/2022
	Issued: 05/04/2020	Expires: 04/15/2022		Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES A Quarter: 1  
B Quarter: 1  
A Quarter: 4  
B Quarter: 4

Inspections: 30-Mar-2022

Monitoring: 0101 18-Sep-2021  
0101 09-Oct-2021  
0101 22-Oct-2021

Enforcement Actions: 03-Jun-2021 Notice of Violation  
01-Dec-2021 Notice of Violation

**National Railroad Passenger Corporation (Amtrak)**

Facility ID: 55007691

2 Frontage Road  
South Boston, MA 02118

<u>Permit:</u>	Issued: 06/06/2022	Expires: 05/15/2024		
	Issued: 09/16/2019	Expires: 08/15/2021	Amended: 08/20/2021	Termination: 06/05/2022
	Issued: 09/16/2019	Expires: 08/15/2021		Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 27-Jul-2021  
21-Sep-2021

<u>Monitoring:</u>	0101	22-Nov-2021
	0101	21-Dec-2021
	0101	25-Apr-2022
	9100	25-Apr-2022

Enforcement Actions:

**North Coast Seafoods**

Facility ID: 55002026

5 Drydock Avenue  
South Boston, MA 02210

Permit: Issued: 03/16/2022 Expires: 11/15/2023  
Issued: 11/20/2019 Expires: 11/15/2021

Termination: 03/15/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 08-Oct-2021  
15-Apr-2022

Monitoring: 0101 07-Oct-2021  
0101 08-Oct-2021

Enforcement Actions:

<b>TEI Biosciences, Inc.</b>	Facility ID: 55101116
7 Elkins Street South Boston, MA 02127	

<u>Permit:</u>	Issued: 07/16/2021	Expires: 06/15/2023	Amended: 08/20/2021	
	Issued: 07/16/2021	Expires: 06/15/2023		Termination: 08/20/2021
	Issued: 04/30/2019	Expires: 03/15/2021		Termination: 07/15/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Operations, lab sinks

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 16-Jun-2022

Monitoring: 0101 18-Jan-2022

Enforcement Actions:

<b>The Gillette Company, LLC</b>	Facility ID: 55001985
One Gillette Park South Boston, MA 02127	

Permit: Issued: 02/01/2021 Expires: 08/15/2022 Amended: 08/20/2021  
 Issued: 02/01/2021 Expires: 08/15/2022 Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0105 Process Wastewater - Unregulated  
 1201 Process Wastewater - Unregulated

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 07-Feb-2022

Monitoring: 0105 17-Dec-2021  
 0105 24-Jan-2022  
 1201 22-Dec-2021  
 9100 24-Jan-2022

Enforcement Actions:



<b>Vertex Pharmaceuticals, Inc.</b>	Facility ID: 55404075
1 Harbor Street South Boston, MA 02210	

Permit: Issued: 06/06/2022 Expires: 10/15/2025  
 Issued: 04/30/2018 Expires: 10/15/2021 Amended: 08/20/2021 Termination: 06/05/2022  
 Issued: 04/30/2018 Expires: 10/15/2021 Termination: 08/20/2021

National Pretreatment Categorical Standards: 01-Oct-2013 to 439.47 D Pharmaceutical Manufacturing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated Pharmaceutical R&D lab wastewater  
 0102 Process Wastewater - Regulated

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 15-Nov-2021  
 29-Dec-2021

Monitoring: 0101 23-Aug-2021  
 0101 24-Aug-2021  
 0101 25-Apr-2022  
 9100 25-Apr-2022

Enforcement Actions:

## Stoughton

**Plain Street Water Treatment Plant**

Facility ID: 32406522

742 Plain Street  
Stoughton, MA 02072

<u>Permit:</u>	Issued: 09/03/2019	Expires: 07/15/2023	Amended: 09/09/2022	
	Issued: 09/03/2019	Expires: 07/15/2023	Amended: 08/31/2022	Termination: 09/08/2022
	Issued: 09/03/2019	Expires: 07/15/2023	Amended: 08/19/2021	Termination: 08/30/2022
	Issued: 09/03/2019	Expires: 07/15/2023		Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated water treatment plant residuals

Reason for SIU Status:

SNC: NO

Inspections: 10-Dec-2021  
08-Jun-2022

Monitoring: 0101 16-Dec-2021  
0101 24-Feb-2022  
0101 16-Jun-2022

Enforcement Actions:

<b>Tradebe Treatment and Recycling of Stoughton, LLC</b>	Facility ID: 32004859
441 R Canton Street Stoughton, MA 02072	

Permit: Issued: 06/14/2021 Expires: 04/15/2023 Amended: 08/19/2021  
 Issued: 06/14/2021 Expires: 04/15/2023 Termination: 08/19/2021

National Pretreatment Categorical Standards: 01-Mar-2009 to 437.47 D Centralized Waste Treatment

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated hazardous & nonhazardous waste treatment

Reason for SIU Status: Is a Categorical Industrial User., Has a reasonable potential to violate MWRA limits., Flow greater than 25,000 gpd.

SNC: NO

Inspections: 17-Sep-2021  
08-Mar-2022

Monitoring: 0101 18-Aug-2021  
 0101 29-Sep-2021  
 0101 04-Jan-2022  
 0101 14-Feb-2022  
 0101 15-Mar-2022  
 9100 14-Feb-2022

Enforcement Actions: 01-Mar-2021 Notice of Violation  
 24-Mar-2022 Notice of Violation  
 21-Apr-2022 Notice of Violation

## Wakefield

**Xyleco, Inc**

Facility ID: 33404577

360 Audubon Road  
Wakefield, MA 01880

Permit: Issued: 03/16/2022  
Issued: 12/10/2019

Expires: 11/15/2023  
Expires: 11/15/2021

Termination: 03/15/2022

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 OTHER\_DESC R&D and pilot production of sugar and sugar derivatives.

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 06-Oct-2021  
14-Apr-2022

Monitoring: 0101 13-Jan-2022  
0101 28-Mar-2022  
0101 29-Mar-2022

Enforcement Actions: 16-Apr-2021 Notice of Violation  
21-Apr-2022 Notice of Violation

## Walpole

<b>Hollingsworth &amp; Vose Company</b>	Facility ID: 34001921
112 Washington Street Walpole, MA 02032	

Permit: Issued: 07/15/2021 Expires: 02/15/2023 Amended: 08/19/2021  
Issued: 07/15/2021 Expires: 02/15/2023 Termination: 08/19/2021  
Issued: 02/15/2019 Expires: 02/15/2021 Termination: 07/14/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated wastewater from paper manufacturing

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 09-Jul-2021  
27-Jan-2022

Monitoring: 0101 27-Sep-2021  
0101 28-Sep-2021  
0101 03-Nov-2021  
0101 04-Nov-2021  
0101 24-Jan-2022  
9100 24-Jan-2022

Enforcement Actions:

## Waltham

**Acton Metal Processing Corporation**

Facility ID: 35004598

41 Athletic Field Road  
Waltham, MA 02451

Permit: Issued: 06/09/2022 Expires: 06/15/2024  
Issued: 06/22/2020 Expires: 06/15/2022 Amended: 08/19/2021 Termination: 06/08/2022  
Issued: 06/22/2020 Expires: 06/15/2022 Termination: 08/19/2021

National Pretreatment Categorical Standards: 30-Sep-2002 to 433.15 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 10-Nov-2021  
05-May-2022

Monitoring: 0101 28-Dec-2021  
0101 13-Jan-2022  
0101 31-Jan-2022  
9100 31-Jan-2022

Enforcement Actions:

**Brandeis University**

Facility ID: 35005368

415 South Street  
Waltham, MA 02454

Permit: Issued: 05/11/2021 Expires: 01/15/2023 Amended: 08/19/2021  
Issued: 05/11/2021 Expires: 01/15/2023 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	OTHER_DESC	General science and biochem labs on the top three floors of Kosow
	0103	OTHER_DESC	Chemistry, Biology, Life Science and Physics Laboratories
	0104	OTHER_DESC	Biology Laboratories
	0105	OTHER_DESC	Animal care facility
	0107	OTHER_DESC	Basic Medical Science Laboratories
	0108	Process Wastewater - Unregulated	
	0109	Process Wastewater - Unregulated	

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 06-Aug-2021  
22-Feb-2022

<u>Monitoring:</u>	0101	10-Mar-2022
	0103	17-Nov-2021
	0103	18-Nov-2021
	0103	27-Jan-2022
	0103	28-Jan-2022
	0103	23-Feb-2022
	0103	24-Feb-2022
	0104	26-Jan-2022
	0105	26-Jan-2022
	0107	18-Nov-2021
	0107	19-Nov-2021
	0107	27-Jan-2022
	0107	28-Jan-2022
	0108	08-Mar-2022
	0109	25-Jan-2022
	0109	26-Jan-2022

Enforcement Actions: 16-Jun-2022 Notice of Violation  
30-Jun-2022 Notice of Violation

<b>Giner, Inc.</b>	Facility ID: 35004157
89 Rumford Avenue Waltham, MA 02466	

Permit: Issued: 02/05/2020 Expires: 12/15/2023 Amended: 08/19/2021  
 Issued: 02/05/2020 Expires: 12/15/2023 Termination: 08/19/2021

National Pretreatment Categorical Standards: 04-Mar-1994 to 433.17 A Metal Finishing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated  
0104

Reason for SIU Status: Is a Categorical Industrial User.

SNC: YES B Quarter: 2

Inspections: 15-Oct-2021  
07-Apr-2022

Monitoring: 0101 29-Jul-2021  
0101 10-Jan-2022  
0101 14-Feb-2022  
0101 25-Mar-2022  
9100 14-Feb-2022

Enforcement Actions: 02-Apr-2021 Notice of Violation  
09-May-2022 Notice of Violation  
02-Jun-2022 Notice of Violation



**Light Metal Platers LLC**

Facility ID: 35004626

70 Clematis Avenue  
Waltham, MA 02453

Permit: Issued: 05/15/2020 Expires: 03/15/2022 Amended: 08/19/2021  
Issued: 05/15/2020 Expires: 03/15/2022 Termination: 08/19/2021

National Pretreatment Categorical Standards: 07-Apr-2009 to 433.17 A Metal Finishing

MWRA Category: 04

Sample Locations: 0101 Process Wastewater - Regulated

Reason for SIU Status:

SNC: YES B Quarter: 3

Inspections: 02-Aug-2021  
04-Oct-2021  
28-Feb-2022

Monitoring: 0101 29-Jul-2021

Enforcement Actions: 01-Oct-2020 Notice of Violation  
21-Jan-2021 Notice of Violation  
30-Jul-2021 Notice of Violation  
06-Oct-2021 Notice of Violation

<b>Nova Biomedical Corporation</b>	Facility ID: 35006361
200 Prospect Street Waltham, MA 02454	

Permit: Issued: 09/19/2022 Expires: 10/15/2024  
 Issued: 12/15/2020 Expires: 10/15/2022 Amended: 07/13/2022 Termination: 09/18/2022  
 Issued: 12/15/2020 Expires: 10/15/2022 Termination: 07/12/2022

National Pretreatment Categorical Standards: 21-May-2010 to 433.17 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated  
 Process Wastewater - Unregulated  
 0105 Process Wastewater - Unregulated  
 0107

Reason for SIU Status: Is a Categorical Industrial User.

SNC: YES B Quarter: 1  
 F3 Quarter: 1  
 B Quarter: 2

Inspections: 04-Aug-2021  
 27-Sep-2021  
 14-Mar-2022

Monitoring: 0101 28-Sep-2021  
 0101 29-Sep-2021  
 0101 24-Jan-2022  
 0101 27-Apr-2022  
 0101 28-Apr-2022  
 0105 29-Sep-2021  
 0105 27-Apr-2022  
 9100 24-Jan-2022

Enforcement Actions: 14-Mar-2022 Notice of Violation

**Plating for Electronics, Inc.**

Facility ID: 35006562

94 Calvary Street  
Waltham, MA 02453

Permit: Issued: 04/26/2022 Expires: 12/15/2023  
Issued: 11/07/2019 Expires: 12/15/2021 Termination: 04/25/2022

National Pretreatment Categorical Standards: 16-May-2007 to 433.15 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated  
0102 Cyanide Waste Stream

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 08-Nov-2021  
10-Mar-2022

Monitoring: 0101 14-Jul-2021  
0101 15-Jul-2021  
0101 11-Jan-2022  
0101 12-Jan-2022  
0101 31-Jan-2022  
0101 01-Mar-2022  
0102 14-Jul-2021  
9100 31-Jan-2022

Enforcement Actions:

<b>Queen Screw &amp; Mfg. Inc.</b>	Facility ID: 35100124
60 Farwell Street Waltham, MA 02453	

Permit: Issued: 03/24/2022 Expires: 11/15/2026  
Issued: 12/08/2016 Expires: 11/15/2021 Termination: 03/23/2022

National Pretreatment Categorical Standards: 01-Nov-2016 to 433.17 A Metal Finishing

MWRA Category: 04

Sample Locations: 0101

Reason for SIU Status: Is a CIU without flow.

SNC: YES F3 Quarter: 1

Inspections: 07-Oct-2021

Monitoring:

Enforcement Actions:

## West Roxbury

**VA Boston Healthcare System**

Facility ID: 56005702

1400 VFW Parkway 138-S  
West Roxbury, MA 02132

Permit: Issued: 06/26/2019 Expires: 07/15/2023 Amended: 08/20/2021  
Issued: 06/26/2019 Expires: 07/15/2023 Termination: 08/20/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

<u>Sample Locations:</u>	0101	OTHER_DESC	Clinical and research labs.
	0102	OTHER_DESC	Clinical and research labs.
	0103	Process Wastewater - Unregulated	Surgical instrument cleaning
	0104	Process Wastewater - Unregulated	Animal Cage Washer
	0105	Process Wastewater - Unregulated	Sterilizer, Building 21
	0206	Process Wastewater - Unregulated	
	0207	Process Wastewater - Unregulated	

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES B Quarter: 3  
F3 Quarter: 3

Inspections: 11-Aug-2021  
23-Mar-2022

<u>Monitoring:</u>	0101	27-Sep-2021
	0101	30-Sep-2021
	0101	24-May-2022
	0101	25-May-2022
	0102	29-Sep-2021
	0102	30-Sep-2021
	0102	24-May-2022
	0102	25-May-2022
	0103	30-Sep-2021
	0103	01-Oct-2021
	0104	27-Sep-2021
	0104	24-May-2022
	0105	27-Sep-2021
	0206	15-Nov-2021

Enforcement Actions: 10-Nov-2021 Notice of Violation  
12-Nov-2021 Notice of Violation

## Westwood

<b>Romanow Container</b>	Facility ID: 38101644
346 University Avenue Westwood, MA 02090	

Permit: Issued: 03/16/2021 Expires: 01/15/2023 Amended: 08/19/2021  
Issued: 03/16/2021 Expires: 01/15/2023 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Ink wastewater from treatment system

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: YES B Quarter: 1

Inspections: 07-Dec-2021

Monitoring:

0101	09-Nov-2021
0101	19-Jan-2022
0101	20-Jan-2022
0101	31-Jan-2022
9100	31-Jan-2022

Enforcement Actions:

16-Dec-2021	Notice of Violation
17-May-2022	Notice of Violation

## Weymouth

**Calpine Fore River Energy Center, LLC**

Facility ID: 39102547

9 Bridge Street  
Weymouth, MA 02191

Permit: Issued: 01/06/2022 Expires: 08/15/2023  
Issued: 09/24/2019 Expires: 08/15/2021 Amended: 11/05/2019 Termination: 01/05/2022

National Pretreatment Categorical Standards: 21-May-2007 to 423.17 N/A Steam Electric Power Generating

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated power plant discharge

Reason for SIU Status: Is a Categorical Industrial User., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 06-Jul-2021  
10-Jan-2022

Monitoring: 0101 22-Nov-2021  
0101 11-Jan-2022  
0101 04-May-2022  
9100 04-May-2022

Enforcement Actions:

**South Shore Hospital**

Facility ID: 39005749

55 Fogg Road  
Weymouth, MA 02190

Permit: Issued: 04/05/2019 Expires: 12/15/2023 Amended: 08/19/2021  
Issued: 04/05/2019 Expires: 12/15/2023 Amended: 05/09/2019 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0501 OTHER\_DESC Clinical laboratory wastewater  
0601 OTHER\_DESC Washwater from stainless steel hospital carts  
0701 Process Wastewater - Unregulated lab wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 04-Apr-2022  
12-May-2022

Monitoring: 0501 04-Jan-2022  
0501 05-Jan-2022  
0601 03-Jan-2022  
0701 03-Jan-2022

Enforcement Actions:



## Wilmington

**Allcoat Technology, Inc.**

Facility ID: 40003193

100 Eames Street  
Wilmington, MA 01887

Permit: Issued: 08/26/2020 Expires: 05/15/2025 Amended: 08/20/2021  
Issued: 08/26/2020 Expires: 05/15/2025 Termination: 08/20/2021

National Pretreatment Categorical Standards: 15-Mar-1996 to 414.45 D Organic Chemicals, Plastics, and Synthetic Fibers  
15-Mar-1996 to 414.55 E Organic Chemicals, Plastics, and Synthetic Fibers

MWRA Category: 04

Sample Locations: 0105 OTHER\_DESC Non-discharging fed cat process

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 23-Dec-2021

Monitoring:

Enforcement Actions:

**Analog Devices, Inc./Wilmington Manufacturing**

Facility ID: 40005633

1 Analog Way  
Wilmington, MA 01887-3462

Permit: Issued: 06/25/2021 Expires: 04/15/2023 Amended: 08/19/2021  
Issued: 06/25/2021 Expires: 04/15/2023 Termination: 08/19/2021

National Pretreatment Categorical Standards: 01-Apr-1991 to 433.17 A Metal Finishing  
01-Apr-1991 to 469.16 A Electrical and Electronic Components

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated Semiconductor manufacturing discharge  
Process Wastewater - Unregulated Incoming water treatment discharge  
0105 Process Wastewater - Regulated Semiconductor manufacturing discharge  
Process Wastewater - Regulated Metal plating operations

Reason for SIU Status: Is a Categorical Industrial User., Has a reasonable potential to violate MWRA limits., Flow greater than 25,000 gpd.

SNC: NO

Inspections: 27-Aug-2021

Monitoring: 0101 16-Sep-2021  
0101 17-Sep-2021  
0101 20-Dec-2021  
0101 21-Dec-2021  
0101 22-Feb-2022  
0105 16-Sep-2021  
0105 22-Nov-2021  
0105 20-Dec-2021  
0105 21-Dec-2021  
0105 25-Jan-2022  
9100 22-Feb-2022

Enforcement Actions:

**Conformis, Inc.**

Facility ID: 40404506

600 Research Drive  
Wilmington, MA 01887

Permit: Issued: 04/02/2020 Expires: 03/15/2025 Amended: 08/19/2021  
Issued: 04/02/2020 Expires: 03/15/2025 Amended: 06/16/2021 Termination: 08/19/2021

National Pretreatment Categorical Standards: 13-Sep-2019 to 433.17 A Metal Finishing

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated Metal Parts Passivation Line  
0102 Process Wastewater - Regulated Final parts cleaning line  
0103 Process Wastewater - Regulated Non-discharging federally regulated operations

Reason for SIU Status: Is a Categorical Industrial User.

SNC: YES F1 Quarter: 3  
F2 Quarter: 3

Inspections: 30-Sep-2021  
03-Mar-2022

Monitoring: 0101 26-Aug-2021  
0102 26-Aug-2021

Enforcement Actions: 23-Nov-2021 Notice of Violation

**Covestro, LLC**

Facility ID: 40004688

730 Main Street  
Wilmington, MA 01887

Permit: Issued: 01/15/2021 Expires: 10/15/2022 Amended: 06/22/2022  
Issued: 01/15/2021 Expires: 10/15/2022 Termination: 06/21/2022

National Pretreatment Categorical Standards: 29-Jan-1993 to 414.45 D Organic Chemicals, Plastics, and Synthetic Fibers  
29-Jan-1993 to 414.55 E Organic Chemicals, Plastics, and Synthetic Fibers

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated Process wastewater from organic coating, resin, and chemical manufa

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 12-Oct-2021  
12-Apr-2022

Monitoring: 0101 09-Jul-2021  
0101 27-Aug-2021  
0101 23-Mar-2022  
0101 20-Apr-2022  
9100 20-Apr-2022

Enforcement Actions: 02-Apr-2021 Notice of Violation  
07- Apr-2022 Notice of Violation

<b>Koch Separation Solutions, Inc.</b>	Facility ID: 40000409
850 Main Street Wilmington, MA 01887	

Permit: Issued: 06/25/2021 Expires: 07/15/2023 Amended: 08/19/2021  
 Issued: 06/25/2021 Expires: 07/15/2023 Termination: 08/19/2021

National Pretreatment Categorical Standards:

23-May-2009	to	463.16 A Plastics Molding and Forming
23-May-2009	to	463.26 B Plastics Molding and Forming
23-May-2009	to	463.36 C Plastics Molding and Forming
23-May-2009	to	463.999 A Plastics Molding and Forming

MWRA Category: 01

Sample Locations: 0103 OTHER\_DESC Filter manufacturing discharge

Reason for SIU Status: Flow greater than 25,000 gpd., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 07-Dec-2021  
23-Jun-2022

Monitoring:

0103	08-Jul-2021
0103	25-Aug-2021
0103	26-Aug-2021
0103	24-Jan-2022
9100	24-Jan-2022

Enforcement Actions:

**Lubrizol Advanced Materials, Inc.**

Facility ID: 40103056

207 Lowell Street  
Wilmington, MA 01887

Permit: Issued: 05/22/2019 Expires: 05/15/2023 Amended: 08/19/2021  
Issued: 05/22/2019 Expires: 05/15/2023 Amended: 07/16/2019 Termination: 08/19/2021

National Pretreatment Categorical Standards: 08-May-2007 to 414.55 E Organic Chemicals, Plastics, and Synthetic Fibers  
08-May-2007 to 463.15 A Plastics Molding and Forming

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated Polyurethane pellets contact cooling wastewater  
0102 Process Wastewater - Regulated Polyurethane tubing contact cooling wastewater

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 04-Oct-2021  
28-Apr-2022

Monitoring: 0101 09-Aug-2021  
0101 10-Aug-2021  
0102 09-Aug-2021

Enforcement Actions:

**Monogram Gourmet Foods. LLC**

Facility ID: 40103339

330 Ballardvale Street  
Wilmington, MA 01887

Permit: Issued: 08/16/2018 Expires: 08/15/2022 Amended: 08/19/2021  
Issued: 08/16/2018 Expires: 08/15/2022 Amended: 03/18/2019 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Unregulated Food manufacturing wastewater

Reason for SIU Status: Flow greater than 25,000 gpd.

SNC: NO

Inspections: 08-Oct-2021  
14-Apr-2022

Monitoring: 0101 23-Sep-2021  
0101 24-Sep-2021

Enforcement Actions:

11-Sep-2020	Notice of Violation
22-Jan-2021	Notice of Violation
04-Feb-2021	Notice of Violation
14-Apr-2021	Notice of Violation
23-Aug-2021	Notice of Noncompliance
24-Sep-2021	Extension of NON/OTCA/EO/SOC/NPPR Letter
08-Oct-2021	Notice of Violation
08-Oct-2021	Notice of Violation
18-Oct-2021	Notice of Violation
19-Jan-2022	Notice of Violation
20-Jan-2022	Extension of NON/OTCA/EO/SOC/NPPR Letter
18-Mar-2022	Notice of Violation
13-Apr-2022	Extension of NON/OTCA/EO/SOC/NPPR Letter
09-Jun-2022	Returned to Permit Letter
14-Jun-2022	Notice of Violation

**Scully Signal Company**

Facility ID: 40003195

70 Industrial Way  
Wilmington, MA 01887

Permit: Issued: 05/10/2019 Expires: 03/15/2024 Amended: 08/20/2021  
Issued: 05/10/2019 Expires: 03/15/2024 Termination: 08/20/2021

National Pretreatment Categorical Standards: 26-Jun-1992 to 464.45 D Metal Molding and Casting

MWRA Category: 04

Sample Locations: 0103

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 21-Dec-2021

Monitoring:

Enforcement Actions:



<b>Tecomet</b>	Facility ID: 40005637
115 Eames Street Wilmington, MA 01887	

Permit: Issued: 08/26/2020 Expires: 07/15/2024 Amended: 08/19/2021  
 Issued: 08/26/2020 Expires: 07/15/2024 Termination: 08/19/2021

National Pretreatment Categorical Standards:

04-Oct-2005	to	471.34 C Nonferrous Metals Forming and Metal Powders
04-Oct-2005	to	471.64 F Nonferrous Metals Forming and Metal Powders
04-Oct-2005	to	471.94 I Nonferrous Metals Forming and Metal Powders

MWRA Category: 02

Sample Locations:

0104	Process Wastewater - Regulated	Dye penetrant testing of parts
0109	OTHER_DESC	Non-discharging metal finishing operations

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 17-Aug-2021  
03-Feb-2022

Monitoring:

0104	09-Nov-2021
0104	20-Apr-2022
9100	20-Apr-2022

Enforcement Actions:

## Winchester

***Ceramic to Metal Seals, Inc.***

Facility ID: 41403622

33 East Street  
Winchester, MA 01890

Permit: Issued: 06/08/2021  
Issued: 06/08/2021

Expires: 04/15/2026  
Expires: 04/15/2026

Amended: 08/20/2021

Termination: 08/20/2021

National Pretreatment Categorical Standards: 25-May-2011 to 433.17 A Metal Finishing

MWRA Category: 04

Sample Locations: 0101 Process Wastewater - Unregulated

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 15-Mar-2022

Monitoring:

Enforcement Actions:

<b>Olympic Systems Corporation</b>	Facility ID: 41007116
15 Lowell Avenue Winchester, MA 01890	

Permit: Issued: 03/12/2021 Expires: 01/15/2025 Amended: 08/20/2021  
Issued: 03/12/2021 Expires: 01/15/2025 Termination: 08/20/2021

National Pretreatment Categorical Standards: 17-Dec-1991 to 433.17 A Metal Finishing

MWRA Category: 04

Sample Locations: 0101

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 09-Dec-2021  
11-May-2022

Monitoring:

Enforcement Actions:

## Woburn

<b>Abiomed Inc</b>	Facility ID: 43406797
15 Presidential Way Woburn, MA 01801	

Permit: Issued: 08/26/2019 Expires: 01/15/2023 Amended: 09/19/2022  
Issued: 08/26/2019 Expires: 01/15/2023 Amended: 08/19/2021 Termination: 09/18/2022  
Issued: 08/26/2019 Expires: 01/15/2023 Amended: 02/21/2020 Termination: 08/19/2021

National Pretreatment Categorical Standards: 01-Feb-2016 to 469.18 A Electrical and Electronic Components

MWRA Category: 02

Sample Locations: 0102 Process Wastewater - Regulated Semiconductor Operations

Reason for SIU Status: Is a Categorical Industrial User.

SNC: YES F3 Quarter: 3

Inspections: 16-Dec-2021

Monitoring: 0102 09-Aug-2021

Enforcement Actions: 26-Aug-2020 Notice of Violation  
01-Jul-2021 Notice of Violation  
03-Sep-2021 Notice of Violation

**Aero Brazing Corp.**

Facility ID: 43003757

223 New Boston Street  
Woburn, MA 01801

Permit: Issued: 06/29/2020 Expires: 06/15/2022 Amended: 08/19/2021  
Issued: 06/29/2020 Expires: 06/15/2022 Termination: 08/19/2021

National Pretreatment Categorical Standards: 10-Apr-2013 to 413.64 F Electroplating

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Regulated Metal Finishing Wastewater

Reason for SIU Status: Is a Categorical Industrial User., Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 08-Dec-2021

Monitoring: 0101 15-Jul-2021  
0101 16-Dec-2021  
0101 19-Jan-2022  
0101 24-Jan-2022  
9100 24-Jan-2022

Enforcement Actions: 11-Jan-2022 Notice of Violation  
11-May-2022 Notice of Violation  
27-May-2022 Notice of Noncompliance

**Atlantic Power Cleaning Corp.**

Facility ID: 43404836

92 Merrimac Street  
Woburn, MA 01801

Permit: Issued: 01/15/2021 Expires: 12/15/2022 Amended: 08/19/2021  
Issued: 01/15/2021 Expires: 12/15/2022 Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

Sample Locations: 0101 Process Wastewater - Unregulated Equipment and truck wash wastewater

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 14-Jun-2022

Monitoring: 0101 28-Jun-2021  
0101 09-Nov-2021  
0101 23-Mar-2022  
0101 24-Mar-2022

Enforcement Actions: 23-Sep-2020 Notice of Violation  
25-Mar-2021 Notice of Violation

**High Precision Devices, Inc**

Facility ID: 43404134

225 Wildwood Avenue  
Woburn, MA 01801

Permit: Issued: 07/16/2018 Expires: 07/15/2023 Amended: 09/26/2022  
Issued: 07/16/2018 Expires: 07/15/2023 Amended: 08/20/2021 Termination: 09/25/2022  
Issued: 07/16/2018 Expires: 07/15/2023 Amended: 03/31/2021 Termination: 08/20/2021

National Pretreatment Categorical Standards: 19-Jul-2013 to 433.17 A Metal Finishing

MWRA Category: 04

Sample Locations: 0101 OTHER\_DESC Non-dishcharging fed cat

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 14-Oct-2021

Monitoring:

Enforcement Actions: 01-Jun-2021 Notice of Violation

<b>Horn Pond Water Treatment Plant</b>	Facility ID: 43103716
5 Cove Street Woburn, MA 01801	

<u>Permit:</u>	Issued: 06/06/2022	Expires: 04/15/2024		
	Issued: 04/27/2020	Expires: 04/15/2022	Amended: 08/19/2021	Termination: 06/05/2022
	Issued: 04/27/2020	Expires: 04/15/2022		Termination: 08/19/2021

National Pretreatment Categorical Standards:

MWRA Category: 01

<u>Sample Locations:</u>	0101	Process Wastewater - Regulated	WTP filter backwash
	0102	OTHER_DESC	Drinking Water Auto-Analyzer Discharge

Reason for SIU Status: Has a reasonable potential to violate MWRA limits.

SNC: NO

Inspections: 09-Mar-2022

<u>Monitoring:</u>	0101	24-Sep-2021
	0101	16-Nov-2021
	0101	17-Nov-2021
	0101	19-Jan-2022
	0101	04-Mar-2022
	0102	23-Sep-2021
	0102	24-Sep-2021

Enforcement Actions:



***II-VI Photonics (US), Inc.***

Facility ID: 43103058

78 - A Olympia Avenue  
Woburn, MA 01801

Permit: Issued: 12/19/2018 Expires: 11/15/2022 Amended: 08/19/2021  
Issued: 12/19/2018 Expires: 11/15/2022 Termination: 08/19/2021

National Pretreatment Categorical Standards: 05-Nov-2002 to 469.16 A Electrical and Electronic Components

MWRA Category: 02

Sample Locations: 0101 OTHER\_DESC Semiconductor manufacturing

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 14-Jun-2022

Monitoring: 0101 24-Jan-2022

Enforcement Actions:

<b>Parker Hannifin - Chomerics Division</b>	Facility ID: 43005063
8 Commonwealth Avenue Woburn, MA 01801	

Permit: Issued: 02/28/2022 Expires: 10/15/2023  
 Issued: 06/25/2019 Expires: 08/15/2021 Termination: 02/26/2022

National Pretreatment Categorical Standards: 06-Apr-2011 to 433.17 A Metal Finishing

MWRA Category: 01

Sample Locations: 0106 Process Wastewater - Regulated

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 15-Jul-2021  
14-Jan-2022

Monitoring: 0106 28-Sep-2021  
 0106 30-Sep-2021  
 0106 14-Mar-2022  
 9100 14-Mar-2022

Enforcement Actions: 20-Apr-2021 Notice of Violation  
 09-Sep-2021 Notice of Violation

**Photonwares, Inc. (formerly Agiltron Corporation)**

Facility ID: 43403224

15 Presidential Way  
Woburn, MA 01801

Permit: Issued: 06/28/2019 Expires: 03/15/2023 Amended: 01/26/2022  
Issued: 06/28/2019 Expires: 03/15/2023 Termination: 01/25/2022

National Pretreatment Categorical Standards: 25-Oct-2018 to 469.18 A Electrical and Electronic Components

MWRA Category: 04

Sample Locations: 0102 OTHER\_DESC Non-dishcharging fed cat

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 15-Dec-2021

Monitoring:

Enforcement Actions: 09-Dec-2020 Notice of Violation

<b>Skyworks Solutions, Inc.</b>	Facility ID: 43001045
20 Sylvan Road Woburn, MA 01801	

Permit: Issued: 09/13/2022 Expires: 07/15/2024  
 Issued: 06/28/2018 Expires: 07/15/2022 Amended: 08/19/2021 Termination: 09/12/2022  
 Issued: 06/28/2018 Expires: 07/15/2022 Termination: 08/19/2021

National Pretreatment Categorical Standards: 03-Oct-2005 to 433.15 A Metal Finishing  
 03-Oct-2005 to 469.26 B Electrical and Electronic Components

MWRA Category: 02

Sample Locations: 0101 Process Wastewater - Regulated  
 0105

Reason for SIU Status: Is a Categorical Industrial User., Flow greater than 25,000 gpd.

SNC: NO

Inspections: 14-Jun-2022

Monitoring: 0101 16-Sep-2021  
 0101 17-Sep-2021  
 0101 02-Mar-2022  
 0101 03-Mar-2022  
 0101 20-Apr-2022  
 9100 20-Apr-2022

Enforcement Actions:

<b>Tecomet, Inc.</b>	Facility ID: 43101316
170 New Boston Street Woburn, MA 01801	

Permit: Issued: 06/28/2021 Expires: 07/15/2023 Amended: 08/19/2021  
 Issued: 06/28/2021 Expires: 07/15/2023 Termination: 08/19/2021

National Pretreatment Categorical Standards: 24-Apr-2007 to 433.15 A Metal Finishing

MWRA Category: 01

Sample Locations: 0101 OTHER\_DESC Metal finishing  
 0102 OTHER\_DESC cyanide destruct

Reason for SIU Status: Is a Categorical Industrial User.

SNC: NO

Inspections: 13-Dec-2021

Monitoring: 0101 22-Sep-2021  
 0101 11-Jan-2022  
 0101 31-Jan-2022  
 0102 21-Sep-2021  
 9100 31-Jan-2022

Enforcement Actions: 01-Mar-2021 Notice of Violation  
 10-Nov-2021 Notice of Violation

<b>Ultra Electronics</b>	Facility ID: 43005100
10 Sonar Drive Woburn, MA 01801	

Permit: Issued: 06/06/2022 Expires: 05/15/2026  
 Issued: 05/22/2018 Expires: 05/15/2022 Amended: 03/08/2022 Termination: 06/05/2022  
 Issued: 05/22/2018 Expires: 05/15/2022 Termination: 03/07/2022

National Pretreatment Categorical Standards: 04-May-2001 to 433.15 A Metal Finishing

MWRA Category: 04

Sample Locations: 0105

Reason for SIU Status: Is a CIU without flow.

SNC: YES F3 Quarter: 1

Inspections: 28-Apr-2022

Monitoring:

Enforcement Actions: 15-Jul-2020 Notice of Violation  
 07-Apr-2022 Notice of Violation  
 31-May-2022 Notice of Violation

<b>Winfield Brooks Company Inc.</b>	Facility ID: 43004753
70 Conn Street Woburn, MA 01801	

Permit: Issued: 05/01/2018 Expires: 01/15/2023 Amended: 08/20/2021  
Issued: 05/01/2018 Expires: 01/15/2023 Termination: 08/20/2021

National Pretreatment Categorical Standards: 29-May-1992 to 414.45 D Organic Chemicals, Plastics, and Synthetic Fibers

MWRA Category: 04

Sample Locations: 0102

Reason for SIU Status: Is a CIU without flow.

SNC: NO

Inspections: 10-Jun-2022

Monitoring:

Enforcement Actions:

**Data Source:**

FISCAL\_YEAR

**Parameters:**

Fiscal\_Year: 2022



## KEY to Appendix B

**Industry:**

**Industry address:**

**#: Permit number Category:** *MWRA category-see description of MWRA categories below*

**Current Sampling Requirements:** *Sample location numbers and descriptions; current permit sampling requirements (frequency and parameter)*

**Discharge Violations:** *Discharge violations occurring during the fiscal year: sample date, parameter, test result and MWRA limit*

**Enforcement Actions:** *Enforcement actions taken during the fiscal year: enforcement action Date and description*

**Notes:** This appendix lists all non-significant industrial users which were permitted during the year. Most of these facilities meet the requirements of MWRA's Low Flow/Low Pollutant General Permit and are thus permitted as Category 10 facilities. These facilities are required to comply with all applicable regulations and the terms of their permits, but due to the nature and/or volume of their discharges, they are not required to conduct periodic self-monitoring, and MWRA does not typically sample their wastewater.

The newly issued Dental Discharges permits are included at the end of Appendix B.

Some violations reported in this appendix happened during the latter part of the year, and show no enforcement actions. This is most often due to the lag of time between when a sample is collected and when the data is submitted to MWRA for input into PIMS. Because sample analysis takes three weeks or more, the violation does not appear on the weekly violation report for some time after the violation occurs. Enforcement actions have been taken early in the year for those violations, but are not reported in this report.

Some industries have enforcement actions but no discharge violations. In some cases, the enforcement actions were related to violations occurring prior to the start of the fiscal year. In others, the enforcement actions were related to reporting violations that are not listed in this appendix.

### MWRA Category:

- Category 1:** A sewer user whose process results in a discharge containing one or more substances in a concentration or quantity requiring pretreatment to meet the requirements of 360 CMR 10.021 through 10.025 and who does not have a Group, General, or Combined Permit for the Discharge.
- Category 2:** A sewer user whose process results in a discharge containing one or more substances regulated by 360 CMR 10.021 through 10.025 at a concentration and quantity not requiring pretreatment to meet the requirements of 360 CMR 10.021 through 10.025 and who does not have a Group, General, or Combined Permit for the Discharge.
- Category 3:** A sewer user whose process results in a discharge not containing a substance regulated by 360 CMR 10.021 through 10.025 and who does not have a Group, General, or Combined Permit for the Discharge.
- Category 4:** An SIU without an Industrial Waste Discharge to the Authority Sewerage System or any tributary thereto.
- Category 6:** A person with a Septage Discharge permit.
- Category 10:** A person with a General Permit for Low Flow and Low Pollutant Dischargers.
- Category 12:** A person with a Temporary Construction Site Dewatering permit.
- Category C1:** A person with a Combined Permit.

**Category D1:** A person with a Group Permit for Dental Discharges.

**Category G1:** A person with a Group Permit for Photo Processing, Printing, and Low Flow Operations.

**Category G2:** A person with a Group Permit for Food Processing.

**Possible Enforcement Actions:**

The type of enforcement action selected to respond to a violation depends on a variety of factors including, but not necessarily limited to: magnitude of the violations, duration of the violations, compliance history of the sewer user, perceived good faith of the user, clarity of the user’s responsibility, and, where such issues arise, the effects of the violation on the receiving waters and/or the treatment works.

*TRAC’s enforcement options found in this report include:*

**Notice of Violation (NOV)**

This enforcement action is a letter to the user describing the violation and asking the user to identify the reason for the violation and what steps it will take to ensure that the violation will not recur.

**Notice of Noncompliance/Order to Take Corrective Action (NON/OTCA)**

This formal, written notice and order identifies which requirements the user has violated and specifies deadlines by which the user must come into compliance. It requires increased sampling and reporting of discharges by the user and the submission of a detailed report by the user on how and when it intends to achieve and maintain compliance with MWRA regulations.

**Enforcement Order (EO):**

Issued by the MWRA to an industry outlining violations, and the steps that the Authority will take to enforce them.

**Penalty Assessment Notice (PAN):**

Formal, written notice to an industry assessing civil monetary penalties.

**Supplemental Order to Comply (SOC):**

A further order, usually issued after a previous order fails to bring an industry into compliance. Often issued with a Penalty Assessment Notice (PAN)

**Administrative Orders (AO):**

These formal written orders include Enforcement Orders, Supplemental Orders, Orders to Take Corrective Action, Orders to Comply, and Cease and Desist Orders. They are sent as follow-ups to NON/OTCA’s as new information is obtained, or are sent in other instances where violations of MWRA regulations are taking place or threaten to take place. They often require increased sampling and reporting of discharges by the user and detailed schedules to achieve or maintain compliance with MWRA requirements. They may contain an order to stop a discharge or a violation.

**Notice of Proposed Permit Revocation (NPPR):**

Issued to an industry when violations are so egregious, that the MWRA must resort to revoking the industry’s permit.

**Notice of Proposed Permit Suspension (NPPS):**

Issued to an industry with outstanding charges due.

**Ruling on Request for Reconsideration of NON/OTCA/EO/SOC/NPPR**

In response to an industry’s appeal of an order or permit revocation, the Authority will issue its decision in the form of a Ruling on Request for Reconsideration of the order or permit revocation.

**Compliance Schedule:**

Issued by the MWRA in a permit or a settlement agreement. It lists dates and milestones that an industry must meet to achieve compliance.

**Settlement Agreement:**

A formal document resolving administratively, violations and enforcement actions.

**Return to Permit Letter:**

Notice to an industry that the industry has been relieved, in part or in full, of the sampling and reporting requirements of a prior enforcement action and can, therefore, return to those of its permit.

**Stipulated Penalties Under Agreement:**

Penalties which the settling parties agreed to pay for certain types of violations during the period of a settlement agreement.

**Interim Ruling on Req. for Reconsideration:**

These rulings resolve some but not all, issues appealed by an industry. A formal ruling will be issued later.

**Emergency Suspension:**

Sewer service may be immediately suspended after informal notice to the user if the discharge reasonably appears to present an imminent danger to health, public welfare or the environment, or if it threatens to interfere with the operation of the sewer system.

**Civil Court Action:**

TRAC may refer a case to the Attorney general for action in civil court, including injunctive relief, the collection of penalties, and the recovery of expenses. Referrals are seldom made because TRAC can issue and enforce administrative orders and financial penalties without court action.

**Criminal Action:**

TRAC may refer a case to the Attorney General's Office and the Environmental Crimes Strike Force for criminal charges to be brought against a user. Referrals are made for serious and intentional violations.

THIS PAGE WAS INTENTIONALLY LEFT BLANK

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Allston Dental Associates 196 Harvard Avenue Allston, MA 02134 #: 44405529 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Allston Family Dental PC 127 Harvard Avenue Allston, MA 02134 #: 44405528 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dentistar 205 Harvard Avenue Allston, MA 02134 #: 44407153 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
DoubleTree Suites 400 Soldiers Field Road Allston, MA 02134 #: 44101792 Category: 02	0101	<i>Washing machine effluent at the drain in the floor trench</i>			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>	Oil and Grease pH						
Harvard Univ. - Pagluica Life Lab - Allston 127 Western Avenue Allston, MA 02134 #: 44404932 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Harvard University - Allston Campus 224 Western Avenue Allston, MA 02134 #: 44005958 Category: C1	0104	<i>Photoprocessing in the Saunders Studio</i>			No Discharge Violations			No Enforcement Actions
	<b>Annual Self-Monitoring</b>	Silver (Total) Silver (Total) pH						
Harvard University - Science & Engineering Complex 150 Western Avenue Allston, MA 02134 #: 44408281 Category: 02	0101	<i>SEC wastewater</i>			No Discharge Violations		13-Jul-2021 Notice of Violation 25-Aug-2021 Notice of Violation	
	<b>Quarterly Self-Monitoring</b>	Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Houghton Chemical Corp. 52 Cambridge Street Allston, MA 02134 #: 44000211 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Planned Parenthood League of Massachusetts 1055 Commonwealth Avenue Allston, MA 02215 #: 44102664 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Arlington Dental 43 Broadway Arlington, MA 02474 #: 01405545 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Arlington Dental Care 347 Massachusetts Avenue Arlington, MA 02474 #: 01405541 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Arlington Dental Group 22 Mill Street Suite 202 Arlington, MA 02476 #: 01405539 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Arlington Family Dental PC 101 Massachusetts Avenue Arlington, MA 02474 #: 01405532 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Arlington Smiles P.C. 1064 Massachusetts Avenue Unit 1 Arlington, MA 02476 #: 01405533 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Barbara A Lawnicki DMD 1068 Massachusetts Avenue Arlington, MA 02476 #: 01405534 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental Associates of Arlington 22 Mill Street Suite 104 Arlington, MA 02476 #: 01407693 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
First Impression Dental 281 Massachusetts Avenue Arlington, MA 02474 #: 01407341 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Gentle Dental Arlington 725 Massachusetts Avenue Arlington, MA 02476 #: 01405547 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
George Vosgerichian DDS 1365 Massachusetts Avenue Arlington, MA 02476 #: 01405536 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Homewood Suites by Hilton - Boston/Cambridge/Arlington 1 Massachusetts Avenue Arlington, MA 02474 #: 01408242 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Michael F. Fitzpatrick DMD 22 Mill Street Suite 002 Arlington, MA 02476 #: 01405538 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Michael S Garber DMD DBA 100 Park Avenue Arlington, MA 02476 #: 01405531 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
New England Family Dental 63 Massachusetts Avenue Arlington, MA 02474 #: 01405546 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Pat Machalinski DMD PC 1188 Massachusetts Avenue Arlington, MA 02476 #: 01405535 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Perkins Family Dental 375 Massachusetts Avenue Arlington, MA 02474 #: 01405544 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
TRAC TEST DENTAL 201 Main Street Arlington, MA 02155 #: 01408258 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
TRAC TEST DENTAL 2 main street Arlington, MA 02148 #: 01409452 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
TetraGenetics, Inc. 91 Mystic Street Unit 1 Arlington, MA 02474 #: 01403711 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Ashland Dental Care 300 Eliot Street #5 Ashland, MA 01721 #: 02407162 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Ashland Elite Dental 171 Main Street Suite 100 Ashland, MA 01721 #: 02405549 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Ashland Family Dental PC 171 Main Street Suite 102 Ashland, MA 01721 #: 02405548 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Ashland Family and Implant Dentistry 37 Main Street Ashland, MA 01721 #: 02405553 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
BioSurfaces, Inc. 200 Homer Avenue Unit 1P Ashland, MA 01721 #: 02404809 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Boston BioProducts Inc. 159 Chestnut Street Ashland, MA 01721 #: 02103041 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
MatTek Corporation 200 Homer Avenue Ashland, MA 01721 #: 02103043 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Metrowest Dental Care 214 Main Street Ashland, MA 01721 #: 02405550 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Practice of Family & Cosmetic Dentistry, LLP 30 Main Street Suite 2 Ashland, MA 01721 #: 02405551 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Smile Magic 39 Pond Street Ashland, MA 01721 #: 02407159 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
The Family Pet Hospital Inc. 300 Eliot Street Ashland, MA 01721 #: 02103039 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
VetCor of Ashland LLC dba Ashland Animal Hospital 10 Fountain Street Ashland, MA 01721 #: 02102549 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Zen Family Dental 5 Homer Avenue Ashland, MA 01721 #: 02408931 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
66th Medical Squadron 90 Vandenberg Drive Building 1900 Bedford, MA 01731 #: 03407509 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
BCPF One Patriots Park LLC One Patriots Park Bedford, MA 01730 #: 03406668 Category: 02	0101	<i>sampling spigot on discharge line after pH neutralization system</i>			No Discharge Violations		04-Aug-2021	Notice of Violation
	<b>Semi-Annual Self-Monitoring</b>							
		Chromium (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Bedford Dental Associates 50 Loomis Street Bedford, MA 01730 #: 03405562 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Bedford Systems, LLC 201 Burlington Road Floor 1 Bedford, MA 01730 #: 03404601 Category: 10	0101	<i>Laboratory wastewater pH neutralization tank</i>			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		pH						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Chestnut Dental Associates 41 North Road Suite 110 Bedford, MA 01730 #: 03405560 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cisbio US, Inc. 135 South Road Bedford, MA 01730 #: 03403185 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Conagen, Inc. 13 -15 DeAngelo Drive Bedford, MA 01730 #: 03404340 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Counterpoint Health Solutions_IXCELA, Inc. 135 South Road Bedford, MA 01730 #: 03403987 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dale Engineering 3 Alfred Circle Bedford, MA 01730 #: 03404191 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dianne M Bridgeman DDS 41 North Road Unit 107 Bedford, MA 01730 #: 03405559 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Discovery Labware, Inc. 2 Oak Park Drive Bedford, MA 01730 #: 03006194 Category: 02	0101	LABORATORY PROCESS WASTEWATER			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b> Cyanide (Total) Cyanide (Total) Formaldehyde Formaldehyde TTO (Volatile Organic Fraction) TTO (Volatile Organic Fraction) pH pH						
Doubletree Bedford Glen Hotel 44 Middlesex Turnpike Bedford, MA 01730 #: 03103552 Category: 02		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
EMD Millipore Corporation 80 Ashby Road Bedford, MA 01730 #: 03003418 Category: 02	0102	Treated process wastewater Building M - spigot on neut sys in Building D			No Discharge Violations		15-Feb-2022	Notice of Violation
		<b>Semi-Annual Self-Monitoring</b> Butanol						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
		Dimethyl Formamide						
		Dimethylacetamide						
		Ethanol						
		Isopropanol						
		Methanol						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		pH						
	0105	<i>pH neutralization system in Building F</i>						
	<b>Semi-Annual Self-Monitoring</b>							
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		pH						
	0202	<i>Limestone chiptank in Bldg D in Repair Depot</i>						
	<b>Semi-Annual Self-Monitoring</b>							
		pH						
EMD Millipore Corporation 75 Wiggins Avenue Bedford, MA 01730 #: 03102595 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
ENRM VA Hospital 200 Springs Road Bedford, MA 01730 #: 03006922 Category: 02	0101	<i>SAMPLE SPIGOT AFTER LIMSTONE CHIP TANK</i>	0601	<i>sampling spigot on common disch. line of two washing machines</i>			03-Aug-2021	Notice of Violation
	<b>Annual</b>	<b>Self-Monitoring</b>	17-Aug-2021	Mercury (Total)	0.0061 mg/l	DYMX < 0.001	09-Sep-2021	Notice of Violation
		Copper (Total)	17-Aug-2021	Copper (Total)	1.99 mg/l	DYMX < 1	06-Jan-2022	Notice of Violation
		Formaldehyde	17-Aug-2021	Lead (Total)	0.48 mg/l	DYMX < 0.2	21-Mar-2022	Notice of Violation
		Silver (Total)	17-Aug-2021	Zinc (Total)	7.95 mg/l	DYMX < 1		
		TTO (Volatile Organic Fraction)	21-Dec-2021	Zinc (Total)	3.09 mg/l	DYMX < 1		
		Temperature	21-Dec-2021	Lead (Total)	0.24 mg/l	DYMX < 0.2		
		pH	21-Dec-2021	Mercury (Total)	0.0028 mg/l	DYMX < 0.001		
	0401	<i>SAMPLE SPIGOT AFTER pH NEUTRALIZATION SYSTEM</i>						
	<b>Annual</b>	<b>Self-Monitoring</b>						
		Mercury (Total)						
		TTO (Volatile Organic Fraction)						
		Temperature						
		pH						
	0501	<i>Wastewater from the sterilizers in Sterilization Processing Services</i>						
	<b>Annual</b>	<b>Self-Monitoring</b>						
		Mercury (Total)						
		Temperature						
		pH						
	0502	<i>Wastewater from the autoclaves in Sterilization Processing Services</i>						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----	-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----		
	Frequency    Parameter	Date	Parameter	Result	Limit	Date	Actions	
Great Meadows Dental Group 56 Great Road Bedford, MA 01730 #: 03407176 Category: D1	<b>Annual</b> <b>Self-Monitoring</b> Mercury (Total) Temperature pH  0503 <i>Wastewater from the ultrasonic cleaners in Sterilization Processing Services</i>  <b>Annual</b> <b>Self-Monitoring</b> Mercury (Total) Temperature pH  0504 <i>Wastewater from the backup ultrasonic cleaner in Sterile Processing Services</i>  <b>Annual</b> <b>Self-Monitoring</b> Mercury (Total) Temperature pH  0601 <i>sampling spigot on common disch. line of two washing machines</i>  <b>Semi-Annual Self-Monitoring</b> Copper (Total) Lead (Total) Mercury (Total) Oil and Grease Temperature Zinc (Total) pH  0701 <i>common discharge trough drain of four washing machines</i>  <b>Semi-Annual Self-Monitoring</b> Copper (Total) Lead (Total) Mercury (Total) Oil and Grease Temperature Zinc (Total) pH	No Reporting Requirements	No Discharge Violations				No Enforcement Actions	
Hanscom Air Force Base 120 Grenier Street Building 1810 Hanscom AFB, MA 01731-1910 #: 03102735 Category: 10	No Reporting Requirements	No Discharge Violations				No Enforcement Actions		

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Infraredx, Inc. - Bedford 28 Crosby Drive Suite 100 Bedford, MA 01730 #: 03407680 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Integral BioSystems 23 Crosby Drive Suite 100A Bedford, MA 01730 #: 03406616 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Kennedy Family and Cosmetic Dentistry 200 The Great Road Suite 243 Bedford, MA 01730 #: 03405556 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Labcorp Bedford LLC (formerly Toxikon Corporation) 15 Wiggins Avenue Bedford, MA 01730 #: 03101286 Category: 02	0101	Neutralization system for Chemistry and Histology labs			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Copper (Total) Formaldehyde Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
	0102	Toxicology Lab cage-washer effluent						
Labcorp Bedford LLC (formerly Toxikon Corporation) 25 Wiggins Avenue Bedford, MA 01730 #: 03103296 Category: 02		Semi-Annual Self-Monitoring pH			No Discharge Violations			No Enforcement Actions
	0102	CAGEWASHER SIDE-STREAM MONITORING TANK			No Discharge Violations			No Enforcement Actions
Mayada Najim DMD 143 Great Road Bedford, MA 01730 #: 03405555 Category: D1		Semi-Annual Self-Monitoring pH			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Medica Corporation 5 Oak Park Drive Bedford, MA 01730 #: 03006383 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ocular Therapeutix 15 Crosby Drive Bedford, MA 01730 #: 03404917 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Pramand, LLC 201 Burlington Road Bedford, MA 01730 #: 03408984 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Reliance Dental Care 363 Great Road Suite 205 Bedford, MA 01730 #: 03405558 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
The Mitre Corporation 202 Burlington Road Bedford, MA 01730-1420 #: 03004803 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Thermo Fisher Scientific 35 Wiggins Avenue Bedford, MA 01730 #: 03102197 Category: 02	0201	<i>PROCESS WASTEWATER FROM MFG. AND LABORATORY OPERATIONS.</i>						No Enforcement Actions
	<b>Annual</b>	<b>Self-Monitoring</b>						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		pH						
Xenon Property, LLC (45 Wiggins Ave) 45 Wiggins Avenue Bedford, MA 01730 #: 03404855 Category: 02	0101	<i>R&amp;D laboratory wastewater</i>	0101	<i>R&amp;D laboratory wastewater</i>				13-Sep-2021 Notice of Violation 24-Mar-2022 Notice of Violation
	<b>Semi-Annual Self-Monitoring</b>		1-Sep-2021	Cyanide (Total)	1.7	mg/l	DYMx < 0.5	
		Arsenic (Total)	10-Mar-2022	Mercury (Total)	0.0012	mg/l	DYMx < 0.001	
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Xenon Property, LLC (47 Wiggins Ave.) 47 Wiggins Avenue Bedford, MA 01730 #: 03405047 Category: 02	0101	<i>R&amp;D Lab Wastewater</i>						No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
		Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
iRobot Corporation 8 Crosby Drive Bedford, MA 01730 #: 03403602 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
rHEALTH LLC 1 Oak Park Drive Floor 1 Bedford, MA 01730 #: 03405259 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
AMG Family Dental 71 Concord Avenue Belmont, MA 02478 #: 04405583 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Belmont Dental Esthetics 84 Leonard Street Belmont, MA 02478 #: 04405585 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Belmont Dental Group 57 Concord Avenue Belmont, MA 02478 #: 04405580 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Belmont Orthodontics & Pediatric Dentist 11 Alexander Avenue Belmont, MA 02478 #: 04405565 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Brachowicz Dental LLC dba Belmont Family Dentistry 75 Trapelo Road Belmont, MA 02478 #: 04405584 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental Restorative Group at Belmont 385 Concord Avenue Belmont, MA 02478 #: 04405576 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Digital Silver Imaging LLC 9 Brighton Street Belmont, MA 02478 #: 04103681 Category: G1	0101	PHOTO			No Discharge Violations			No Enforcement Actions
	<b>Annual</b>	<b>Self-Monitoring</b> Silver (Total)						
Eagle Endodontics Belmont 18 Moore Street Suite 100 Belmont, MA 02478 #: 04408938 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Elis Papparisto Family Dentistry 6 Hawthorne Street Belmont, MA 02478 #: 04405581 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gentle Dental Center of Belmont 250 Trapelo Road Belmont, MA 02478 #: 04405571 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Joan E Horgan Family Dentistry/Kendall Dental 233 Waverly Street Belmont, MA 02478 #: 04405570 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Karessa A. Kuntz DDS 66 Leonard Street Belmont, MA 02478 #: 04407189 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Mayani Dental Belmont LLC 385 Concord Avenue Suite 001 Belmont, MA 02478 #: 04405577 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
McLean Hospital 115 Mill Street Belmont, MA 02478 #: 04006836 Category: 02	0101	Spigot on Oaks Building pH Neutralization system discharge line			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b> Formaldehyde Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
	0201	Spigot on Mailman Research Building pH Neutralization system discharge line						
	<b>Quarterly</b>	<b>Self-Monitoring</b> Formaldehyde Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction)						



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Mondovi Dental 18 Moore Street Suite 200 Belmont, MA 02478 #: 04405567 Category: D1		pH No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Paul Davin DDS 68 Trapelo Road Belmont, MA 02478 #: 04405582 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pleasant Street Dental 363 Pleasant Street Belmont, MA 02478 #: 04405573 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Prathima Bayisetty DMD 161 Belmont Street Belmont, MA 02478 #: 04405566 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Scall Dental Associates 425 Trapelo Road Belmont, MA 02478 #: 04405579 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Schrott Perio Implants 93 Concord Avenue Unit 6 Belmont, MA 02478 #: 04407192 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Vetcor of Fresh Pond LLC dba Fresh Pond Animal Hos 15 Flanders Road Belmont, MA 02478 #: 04103262 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Waverly Dental Care 333 Trapelo Road Belmont, MA 02478 #: 04405572 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
125 Lincoln Street (DE) LLC and Turner Construction Co. 125 Lincoln Street Boston, MA 02111 #: 45409218 Category: 12	0101 Monthly	Stormwater catch basin #451 on Tufts St Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction)			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>	<u>-----DISCHARGE VIOLATIONS-----</u>	<u>-----ENFORCEMENT ACTIONS-----</u>
	<u>Frequency</u> <u>Parameter</u>	<u>Date</u> <u>Parameter</u> <u>Result</u> <u>Limit</u>	<u>Date</u> <u>Actions</u>
	TTO (Volatile Organic Fraction) Total Suspended Solids pH		
	0102 <i>Stormwater catch basin #163 near intersection Lincoln and Beach Streets</i>		
	<b>Monthly</b> <b>Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH		
	0201 <i>Stormwater catch basin #316 on Beach St</i>		
	<b>Monthly</b> <b>Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH		
AC Hotel Boston Downtown 225 Albany Street Boston, MA 02118 #: 45406606 Category: 10	No Reporting Requirements	No Discharge Violations	No Enforcement Actions
Advanced Cosmetic & Implant Dentistry 156 State Street Floor 4 Boston, MA 02109 #: 45407195 Category: D1	No Reporting Requirements	No Discharge Violations	No Enforcement Actions
Anjum A Ansari DMD LLC 50 Staniford Street Floor 8 Boston, MA 02114 #: 45405658 Category: D1	No Reporting Requirements	No Discharge Violations	No Enforcement Actions
Arch Street Dental 103 Arch Street Boston, MA 02116 #: 45407829 Category: D1	No Reporting Requirements	No Discharge Violations	No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Atlantic Avenue Dental Group 183 Essex Street Boston, MA 02111 #: 45407201 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Atrius Health - Harvard Vanguard Medical Associates 133 Brookline Avenue Boston, MA 02215 #: 45102774 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Atrius Health Harvard Vanguard Post Office Square 147 Milk Street Boston, MA 02109 #: 45405009 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
B Central Dental Associates 180 Cambridge Street Boston, MA 02114 #: 45407200 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Back Bay Dental Associates 745 Boylston Street Suite 206 Boston, MA 02116 #: 45409283 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Bao Min Yee, DMD of Boston PC 109 Beach Street Boston, MA 02111 #: 45405594 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Beacon Hill Dental Associates 77 Beacon Street Boston, MA 02108 #: 45405673 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Bio-Medical Applications of Massachusetts dba Kidney Center 888 Commonwealth Avenue Boston, MA 02215 #: 45101466 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Boston Center for Oral Health 400 Commonwealth Avenue Boston, MA 02215 #: 45405648 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Boston Chinatown Dental Center 65 Harrison Avenue Suite 306 Boston, MA 02111 #: 45405667 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Boston City Dental Center 65 Harrison Avenue Suite 508 Boston, MA 02111 #: 45409346 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Dental 36 Chauncy Street Boston, MA 02111 #: 45405643 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Dental 35 Court Street Boston, MA 02110 #: 45407217 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Dental Design 10 Post Office Square Suite 655 Boston, MA 02109 #: 45405589 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Dental Restorative Group 25 New Chardon Street Boston, MA 02114 #: 45405623 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Endodontics 5 Longfellow Place Suite 205 Boston, MA 02114 #: 45405655 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Harbor Hotel 70 Rowes Wharf Boston, MA 02110 #: 45404958 Category: 02	0101	<i>Laundry wastewater</i>			No Discharge Violations		09-Sep-2021 Notice of Violation 03-May-2022 Notice of Violation	
	<b>Semi-Annual Self-Monitoring</b>	Oil and Grease Zinc (Total) pH						
Boston Marriott Copley Place 110 Huntington Avenue Boston, MA 02116 #: 45006629 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Medical Center One Boston Medical Center Place Boston, MA 02118 #: 45005924 Category: 02	1101	<i>Process wastewater from the Menino Building CPD (clean side)</i>			No Discharge Violations		No Enforcement Actions	
	<b>Quarterly Self-Monitoring</b>	Copper (Total) Mercury (Total) pH						
	1102	<i>Menino Pavilion CPD (dirty side) wastewater</i>						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
		<b>Semi-Annual Self-Monitoring</b> Copper (Total) Lead (Total) Nickel (Total) Zinc (Total) pH						
Boston Park Dental Group 128 A Tremont Street Floor 3 Boston, MA 02108 #: 45409028 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Park Plaza 50 Park Plaza Boston, MA 02116 #: 45005782 Category: 02	0101	Laundry effluent from two 65-lb Electrolux washers			No Discharge Violations		09-Sep-2021 Notice of Violation 03-May-2022 Notice of Violation	
		<b>Semi-Annual Self-Monitoring</b> Oil and Grease Zinc (Total) pH						
Boston Pre Release Center 430 Canterbury Street Boston, MA 02131 #: 45405651 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Premier Dentistry, P.C. 10 Tremont Street Suite 402 Boston, MA 02108 #: 45407825 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Boston Prosthodontics Dental 50 Staniford Street Floor 5 Boston, MA 02114 #: 45407226 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brito Family Dental 272 W. Broadway Boston, MA 02118 #: 45407210 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Capital One, National Association and James W Flett Co. Inc. 711 Boylston Street Boston, MA 02116 #: 45409416 Category: 12	0101  Monthly	BWSC catch basin 271 at intersection of Boylston St. and Exeter St.  <b>Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Carol L Aiken DDS 77 Franklin Street Suite 808 Boston, MA 02110 #: 45405674 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Charlesmark Hotel 655 Boylston Street Boston, MA 02116 #: 45405087 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Chinamerica Food Manufacture Inc. 81 -A Tyler Street Boston, MA 02111 #: 45103224 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
CitiDental Tremont 32 Tremont Street Boston, MA 02108 #: 45405636 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Citidental High Street 10 High Street Suite 333 Boston, MA 02110 #: 45407697 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Citidental PC 63 Court Street Boston, MA 02108 #: 45405665 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
CitizenM Hotels 70 Causeway Street Boston, MA 02114 #: 45409103 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
City of Boston - Spectacle Island Spectacle Island Boston Harbor, MA 02201 #: 45103504 Category: 02	0101  Quarterly	8 inch connection on Long Island  Self-Monitoring Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Lead (Total) Mercury (Total) Nickel (Total) Salinity Silver (Total) Zinc (Total) pH			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>	<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>
	<u>Frequency</u> <u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u> <u>Actions</u>
City of Boston and Turner Construction Company 900 Washington Street Boston, MA 02111 #: 45409234 Category: 12	0101 <i>BWSC catch basin #320 located on Pine St, north of the site.</i>  <b>Monthly</b> <b>Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH			No Discharge Violations		No Enforcement Actions
	0201 <i>BWSC catch basin #53 located on Marginal Rd, southwestern corner of the site.</i>  <b>Monthly</b> <b>Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH					
	0202 <i>BWSC catch basin #73 located on Marginal Rd, southeastern corner of the site.</i>  <b>Monthly</b> <b>Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH					
Clarendon Residences dba Hotel 140 140 Clarendon Street Boston, MA 02116 #: 45405181 Category: 10	No Reporting Requirements			No Discharge Violations		No Enforcement Actions
Club Quarters Hotel 161 Devonshire Street Boston, MA 02110 #: 45404946 Category: 10	No Reporting Requirements			No Discharge Violations		No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Cogliano Dental 105 Atlantic Avenue Boston, MA 02110 #: 45407699 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Colortek of Boston 727 Atlantic Avenue Boston, MA 02111 #: 45100134 Category: G1	0101	PHOTO			No Discharge Violations			No Enforcement Actions
	<b>Annual</b>	<b>Self-Monitoring</b> Silver (Total)						
Commonwealth Dental Group 400 Commonwealth Avenue Floor 3 Boston, MA 02215 #: 45405647 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Congress Dental Group 160 Federal Street Floor 1 Boston, MA 02110 #: 45405605 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Copley Square Hotel 47 Huntington Avenue Boston, MA 02116 #: 45405329 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Copley View Dental Associates PC 575 Boylston Street Suite 5-R Boston, MA 02116 #: 45405660 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Courtyard Boston Downtown 275 Tremont Street Boston, MA 02116 #: 45103247 Category: 02	0101	Laundry operation discharge			No Discharge Violations			10-Aug-2021 Notice of Violation 19-May-2022 Notice of Violation
		<b>Semi-Annual Self-Monitoring</b> Mercury (Total) Oil and Grease Zinc (Total) pH						
Courtyard Marriott Hotel Copley Square 88 Exeter Street Boston, MA 02116 #: 45405183 Category: 02	0101	Laundry wastewater			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b> Copper (Total) Oil and Grease Zinc (Total) pH						
DPB at Charles River LLC 50 Staniford Street Suite 303 Boston, MA 02114 #: 45405656 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Daniel J Bley DDS 2 Center Plaza Boston, MA 02108 #: 45405615 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Davita Boston 660 Harrison Avenue Boston, MA 02118 #: 45101058 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Decibel Therapeutics 1325 Boylston Street Floor 5 Boston, MA 02215 #: 45405110 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental Arts of Boston 26 Marlborough Street Boston, MA 02116 #: 45407814 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental Associates of New England 585 Boylston Street Unit 2 Boston, MA 02116 #: 45407232 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental Group at Post Office Square, LLC 3 Post Office Square Floor 9 Boston, MA 02109 #: 45405631 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental Partners of Boston 800 Boylston Street Suite 200 Boston, MA 02199 #: 45405677 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dentology 330 Congress Street Floor 1 Boston, MA 02210 #: 45407216 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Devonshire Dental Associates 185 Devonshire Street Suite 410 Boston, MA 02110 #: 45405612 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dialysis Clinic, Inc. - Tufts Medical Ctr. 35 Kneeland Street Floor 5 Boston, MA 02111 #: 45407718 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Diba Dastjerdi, DMD dba Carr & Associates 68 New Edgerly Road Boston, MA 02115 #: 45405668 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
DoubleTree by Hilton Hotel Boston - Downtown 821 Washington Street Boston, MA 02111 #: 45405222 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Downtown Boston Dental 21 Merchants Row Suite 2A Boston, MA 02109 #: 45405619 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Downtown Dental Center 333 Washington Street Suite 341 Boston, MA 02108 #: 45405640 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dr. James R. Seligman 1180 Washington Street Unit 102 Boston, MA 02118 #: 45405595 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Emmanuel College 400 The Fenway Boston, MA 02115 #: 45004514 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Fairmont Copley Plaza Hotel 138 Saint James Avenue Boston, MA 02116 #: 45102966 Category: 10	No Reporting Requirements				No Discharge Violations		23-Sep-2021 Notice of Violation	
Faneuil Hall Dental Associates 177 State Street Boston, MA 02109 #: 45405610 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Fenway Health Center 1340 Boylston Street Boston, MA 02215 #: 45405601 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Fiorillo Dental 437 Boylston Street Floor 5 Boston, MA 02116 #: 45405653 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Found Hotel 78 Charles Street S Boston, MA 02116 #: 45405238 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Four Seasons Hotel 200 Boylston Street Boston, MA 02116 #: 45102868 Category: 02	0101	<i>Laundry operation discharge.</i>			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b> Oil and Grease Zinc (Total) pH						
G&D Smiles; dba Geoffrey Davis DMD 581 Boylston Street Suite 401 Boston, MA 02116 #: 45405662 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gentle Dental Tremont St. 131 Tremont Street Boston, MA 02111 #: 45408705 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Giangrasso Dental LLC 279 Hanover Street Boston, MA 02113 #: 45405627 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Great Hill Dental Boston 1610 Tremont Street Boston, MA 02120 #: 45405607 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
HHLP Bulfinch Lessee, LLC dba The Boxer 107 Merrimac Street Boston, MA 02114 #: 45403860 Category: 02	0101	<i>Laundry effluent</i>			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b> Oil and Grease Zinc (Total) pH						
Harborside Inn Boston 185 State Street Boston, MA 02109 #: 45404943 Category: 02	0101	<i>Wastewater from the laundry operation.</i>			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b> Oil and Grease Zinc (Total) pH						
Harmony 410 Tremont Street Boston, MA 02116 #: 45407221 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Harmony Dental Care, LLC 128 A Tremont Street Floor 5 Boston, MA 02108 #: 45405598 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Harvard School of Dental Medicine 188 Longwood Avenue Boston, MA 02115 #: 45405613 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Helen K Foo DMD 922 Beacon Street Boston, MA 02215 #: 45405681 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hilton Boston Back Bay 40 Dalton Street Boston, MA 02115 #: 45006401 Category: 02	0101 Hotel laundry wastewater				No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b> Mercury (Total) Oil and Grease pH							
Hilton Boston Downtown/Faneuil Hall 89 Broad Street Boston, MA 02110 #: 45103264 Category: 02	0101 Laundry wastewater discharge		0101	Laundry wastewater discharge			01-Jul-2021 Notice of Violation 25-Apr-2022 Notice of Violation	
	<b>Quarterly Self-Monitoring</b> Oil and Grease Zinc (Total) pH		29-Mar-2022	Zinc (Total)	1.22 mg/l	DYMX < 1		
Hirshberg Dental Associates of Boston PC 12 Post Office Square Boston, MA 02109 #: 45405596 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hotel Commonwealth 500 Commonwealth Avenue Boston, MA 02215 #: 45405322 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hotel Indigo Boston Garden 280 Friend Street Boston, MA 02114 #: 45404976 Category: 02	0101 Laundry effluent				No Discharge Violations		01-Jul-2021 Notice of Violation 03-Mar-2022 Notice of Violation 19-May-2022 Notice of Violation	
	<b>Semi-Annual Self-Monitoring</b> Copper (Total) Mercury (Total) Oil and Grease Zinc (Total) pH							
Intercontinental Boston 510 Atlantic Avenue Boston, MA 02210 #: 45407273 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Intercontinental Real Estate Corporation 4 Blackfan Street Boston, MA 02115 #: 45406654 Category: 02	0101	<i>Lab effluent from sinks, glass washing facilities</i>			No Discharge Violations			No Enforcement Actions
	Quarterly	<b>Self-Monitoring</b> Mercury (Total) Silver (Total) TTO (Volatile Organic Fraction) pH						
James M. Stein, DMD 50 Staniford Street Floor 10 Boston, MA 02114 #: 45407225 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Joseph J Milavec DMD 400 Commonwealth Avenue Suite 104D Boston, MA 02215 #: 45405649 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Joseph P Nore DDS 586 Tremont Street Boston, MA 02118 #: 45405663 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Joslin Diabetes Center One Joslin Place Boston, MA 02215 #: 45006018 Category: 02	0101	<i>Wastewater effluent from the neutralization system.</i>			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b> Formaldehyde Formaldehyde Mercury (Total) Mercury (Total) Phenol Silver (Total) Silver (Total) TTO (Volatile Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) Zinc (Total) pH pH						
Kowa Holdings America, Inc. 3 Blackfan Circle Floor 17 Boston, MA 02115 #: 45403358 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lewis Wharf Dental 237 Lewis Wharf Boston, MA 02113 #: 45407206 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Limited to Endodontics 2 Center Plaza Suite 230 Boston, MA 02108 #: 45405616 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
MCAF Winthrop LLC and Suffolk Construction 115 Federal Street Boston, MA 02110 #: 45405372 Category: 12	0101  Monthly	<i>Dewatering discharged to CB #198 on Devonshire Street</i>  <b>Self-Monitoring</b> Lead (Total) Mercury (Total) Oil and Grease PCB's TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH			No Discharge Violations			No Enforcement Actions
MCPHS University 179 Longwood Avenue Boston, MA 02115 #: 45004517 Category: 02	0301	<i>Process wastewater from educational and research laboratories</i>  <b>Semi-Annual Self-Monitoring</b> Mercury (Total) Phenol TTO (Volatile Organic Fraction) Zinc (Total) pH			No Discharge Violations			No Enforcement Actions
MGH Dental Group 165 Cambridge Street Suite 401 Boston, MA 02114 #: 45405608 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Mass Dental Associates 770 Tremont Street Boston, MA 02118 #: 45405675 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Massachusetts College of Art and Design 621 Huntington Avenue Boston, MA 02115 #: 45006884 Category: C1	0101  Annual	<i>PHOTO and studio wastewater</i>  <b>Self-Monitoring</b> Silver (Total)			No Discharge Violations			No Enforcement Actions
Massachusetts Eye & Ear Infirmary 243 Charles Street Boston, MA 02114 #: 45005735 Category: 02	0107  Quarterly	<i>Lab discharge from main &amp; connector buildings</i>  <b>Self-Monitoring</b> Formaldehyde Mercury (Total) pH TTO (Volatile Organic Fraction)			No Discharge Violations			No Enforcement Actions
	0201	<i>Lab discharge from 325 Cambridge Street building</i>  <b>Annual Self-Monitoring</b>						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Massachusetts Eye & Ear Infirmary - Schepens 20 Staniford Street Boston, MA 02114 #: 45102333 Category: 02	0101  Semi-Annual Self-Monitoring	Laboratory and cage wash effluent  TTO (Volatile Organic Fraction) Mercury (Total) pH			No Discharge Violations		No Enforcement Actions	
Massachusetts Eye and Ear Infirmary - Longwood Campus 800 Huntington Avenue Boston, MA 02115 #: 45404778 Category: 02	0101  Semi-Annual Self-Monitoring	Process wastewater from Central Processing Department and OR flash sterilizers  Copper (Total) Zinc (Total) pH			No Discharge Violations		No Enforcement Actions	
Matthew S. Ginsburg, DMD 31 St. James Avenue Suite 780 Boston, MA 02116 #: 45407214 Category: D1		No Reporting Requirements			No Discharge Violations		No Enforcement Actions	
Merck Sharp & Dohme LLC 33 Avenue Louis Pasteur Boston, MA 02115 #: 45103268 Category: 02	0101  Quarterly	Laboratory wastewater  Self-Monitoring Copper (Total) Cyanide (Total) Mercury (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH			No Discharge Violations		No Enforcement Actions	
Micro Endodontics 10 Post Office Square Suite 1101 Boston, MA 02109 #: 45409366 Category: D1		No Reporting Requirements			No Discharge Violations		No Enforcement Actions	
Millenium Dental, LLC 177 Tremont Street Floor 6 Boston, MA 02111 #: 45407828 Category: D1		No Reporting Requirements			No Discharge Violations		No Enforcement Actions	
Mint 200 Lincoln Street Suite 500 Boston, MA 02111 #: 45407204 Category: D1		No Reporting Requirements			No Discharge Violations		No Enforcement Actions	

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Nevins Dental Center 3 Center Plaza Suite 310 Boston, MA 02108 #: 45407818 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
New England Aquarium 250 Atlantic Avenue Boston, MA 02110 #: 45006091 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Newbury Dental Associates LLC 274 Newbury Street Boston, MA 02116 #: 45407822 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Nine Zero Hotel 90 Tremont Street Boston, MA 02108 #: 45405010 Category: 10		No Reporting Requirements			No Discharge Violations		02-Feb-2022	Notice of Violation
North End Waterfront Health Center 332 Hanover Street Boston, MA 02113 #: 45405639 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Northeastern University - Forsyth Institute 140 The Fenway Boston, MA 02115 #: 45403630 Category: 02	0101 <i>Process wastewater from pharmaceutical research                      laboratory operations.</i>  Annual <b>Self-Monitoring</b> Mercury (Total) TTO (Volatile Organic Fraction) pH  0201 <i>Process wastewater from pharmaceutical research                      laboratory operations.</i>  Semi-Annual <b>Self-Monitoring</b> Mercury (Total) TTO (Volatile Organic Fraction) pH				No Discharge Violations			No Enforcement Actions
Oliver Dental Associates 295 Devonshire Street Suite 301 Boston, MA 02110 #: 45405630 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Omni Parker House Hotel 60 School Street Boston, MA 02108 #: 45005644 Category: 02	0201 <i>Laundry wastewater</i>  Semi-Annual <b>Self-Monitoring</b> Lead (Total) Mercury (Total) Oil and Grease Zinc (Total)		0201 <i>Laundry wastewater</i>  15-Dec-2021    Lead (Total)		0.22    mg/l    DYMx    < 0.2		25-Jan-2022	Notice of Violation



## Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----		
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions	
One Post Office Square LLC and John Moriarty & Associates One Post Office Square Boston, MA 02109 #: 45408043 Category: 12	0101	Sampling spigot on the final discharge line						No Enforcement Actions	
	Monthly	Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH							
	0102	Sampling spigot on the final discharge line							
	Monthly	Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH							
	0201	Sampling spigot on the final discharge line							
	Monthly	Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH							
		No Reporting Requirements							No Enforcement Actions
	Osorio Dental Group 60 Federal Street Boston, MA 02110 #: 45407233 Category: D1								No Enforcement Actions
		No Reporting Requirements							No Enforcement Actions
	Parkside Dental Care 37 Newbury Street Suite 3 Boston, MA 02116 #: 45407218 Category: D1								No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>		
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>	
Pat Kinsel and Jill Ozzie and Sea-Dar Construction 10 Union Park Boston, MA 02118 #: 45409375 Category: 12	0101  Monthly	18" line on southwest side of 10 Union Park beneath Public Alley No. 701  Self-Monitoring Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH	No Discharge Violations					No Enforcement Actions	
Prudential Dental Associates 575 Boylston Street Floor 7 Boston, MA 02116 #: 45405661 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions		
Rago Veal 124 Newmarket Square Boston, MA 02118 #: 45102999 Category: G2	No Reporting Requirements		No Discharge Violations				No Enforcement Actions		
Residence Inn Boston Back Bay/Fenway 125 Brookline Avenue Boston, MA 02215 #: 45405229 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions		
Revere Hotel - NKOTB, LLC 200 Stuart Street Boston, MA 02116 #: 45103217 Category: 02	0101  Semi-Annual	Laundry discharge  Self-Monitoring Mercury (Total) Oil and Grease Zinc (Total) pH	No Discharge Violations				25-Aug-2021 Notice of Violation		

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Riley Dental Associates LLC 10 Hawthorne Place Suite 102 Boston, MA 02114 #: 45405588 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Shriners Hospital for Children 51 Blossom Street Boston, MA 02114 #: 45101038 Category: 02	0101	Research lab wastewater			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>	Formaldehyde Mercury (Total) Silver (Total) TTO (Volatile Organic Fraction) pH						
Simmons University 300 The Fenway Boston, MA 02115 #: 45004519 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Smile Design Boston 21 Custom House Street Boston, MA 02110 #: 45407824 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
South Cove Community Health Care 145 South Street Boston, MA 02111 #: 45405603 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
South End Community Health Center Hass Center 400 Shawmut Avenue Boston, MA 02118 #: 45409267 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
South End Community Health Center SECHC 1601 Washington Street Boston, MA 02118 #: 45405606 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
South End Dental Arts 544 Tremont Street Boston, MA 02116 #: 45407230 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
StayPineapple Boston - Pineapple Hospitality 26 Chandler Street Boston, MA 02116 #: 45405109 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	<b>-----CURRENT SAMPLING REQUIREMENTS-----</b>		<b>-----DISCHARGE VIOLATIONS-----</b>				<b>-----ENFORCEMENT ACTIONS-----</b>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Stone Photo and Copy Inc. 160 Federal Street Boston, MA 02110 #: 45007301 Category: G1	0101	PHOTO			No Discharge Violations			No Enforcement Actions
	<b>Annual</b>	<b>Self-Monitoring</b> Silver (Total)						
Stuparich & Nouel Dental Associates LLP 321 Columbus Avenue Boston, MA 02116 #: 45405637 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Suffolk County HOC Dental Suite 20 Bradston Street Boston, MA 02108 #: 45405617 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Suffolk Dental Group 128 A Tremont Street Floor 2 Boston, MA 02108 #: 45405599 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Suffolk University 20 Somerset Street Boston, MA 02108 #: 45004524 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
The Eliot Hotel 370 Commonwealth Avenue Boston, MA 02215 #: 45405027 Category: 02	0101	Laundry wastewater			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual</b>	<b>Self-Monitoring</b> Oil and Grease pH						
The Inn at Longwood Medical 342 Longwood Avenue Boston, MA 02115 #: 45405113 Category: 02	0101	Laundry wastewater			No Discharge Violations		09-Sep-2021 Notice of Violation 02-Feb-2022 Notice of Violation 16-Mar-2022 Notice of Violation	
	<b>Semi-Annual</b>	<b>Self-Monitoring</b> Copper (Total) Lead (Total) Mercury (Total) Oil and Grease Zinc (Total) pH						
The Langham Hotel 250 Franklin Street Boston, MA 02110 #: 45404945 Category: 02	0101	Laundry wastewater			No Discharge Violations			No Enforcement Actions
	<b>Quarterly</b>	<b>Self-Monitoring</b> Copper (Total) Lead (Total) Mercury (Total) Oil and Grease Zinc (Total) pH						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
The Onyx Hotel 155 Portland Street Boston, MA 02114 #: 45103329 Category: 02	0101	Wastewater from the laundry operation			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Mercury (Total) Oil and Grease Zinc (Total) pH Mercury (Total) Oil and Grease Zinc (Total) pH						
The Ritz-Carlton, Boston 10 Avery Street Boston, MA 02111 #: 45005643 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
The Verb Hotel 1271 Boylston Street Boston, MA 02215 #: 45405108 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
The Whitney Hotel 170 Charles Street Boston, MA 02114 #: 45408164 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Tower Dental Associates 336 -A Tremont Street Boston, MA 02116 #: 45405641 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Trade Center Dental Associates 2 Boylston Street Suite 202 Boston, MA 02116 #: 45405614 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Tremont Family Dentistry 951 Tremont Street Boston, MA 02120 #: 45407237 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Triple Ring Technologies 38 Wareham Street Suite 300 Boston, MA 02118 #: 45407120 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Trustees of Tufts College - Tufts Univ. Boston SMFA Campus 230 The Fenway Boston, MA 02115 #: 45102442 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Tufts University School Dental Medicine 1 Kneeland Street Boston, MA 02111 #: 45405587 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Turning Leaf Dental 328 Newbury Street Boston, MA 02115 #: 45405638 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
USCG HSWL Base Boston Dental Clinic 427 Commercial Street Boston, MA 02109 #: 45405650 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
USDA Human Nutrition Research Center 711 Washington Street Boston, MA 02111 #: 45006784 Category: 02	0101	<i>Laboratory wastewater</i>			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Copper (Total)						
		Formaldehyde						
		Mercury (Total)						
		Silver (Total)						
		TTO (Volatile Organic Fraction)						
		pH						
Valdemar Welz DMD 398 Commonwealth Avenue Boston, MA 02215 #: 45405646 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Vasilidis Mourmoutis, DMD PC 359 Boylston Street Boston, MA 02116 #: 45405642 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Vicinity Energy Boston, Inc.- Scotia Street Station 19 - 27 Scotia Street Boston, MA 02116 #: 45005931 Category: 02	0102	<i>Effluent from steam generation operation</i>	0102	<i>Effluent from steam generation operation</i>			14-Mar-2022 Notice of Violation	
	<b>Quarterly</b>	<b>Self-Monitoring</b>	8-Feb-2022	Copper (Total)	2.8	mg/l	DYMx < 1	
		Copper (Total)						
		Copper (Total)						
		Mercury (Total)						
		Zinc (Total)						
		Zinc (Total)						
		pH						
		pH						
W Hotel Boston 100 Stuart Street Boston, MA 02116 #: 45405026 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
WM Jacob Murray DMD 100 Charles Street S Boston, MA 02116 #: 45405591 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Warshauer & Samtalaria 396 Commonwealth Avenue Boston, MA 02215 #: 45407220 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wayne B Yong DDS 28 Atlantic Avenue Boston, MA 02110 #: 45405628 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wentworth Institute of Technology 550 Huntington Avenue Boston, MA 02115 #: 45403851 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Westin Copley Place Boston 10 Huntington Avenue Boston, MA 02116 #: 45006413 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
William B Chan DMD 886 Washington Street Boston, MA 02111 #: 45405680 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wyndham Boston Beacon Hill 5 Blossom Street Boston, MA 02114 #: 45005659 Category: 02	0101	Laundry wastewater effluent			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b> Oil and Grease Zinc (Total) pH						
Allen Dental Associates 382 Grove Street Braintree, MA 02184 #: 06405691 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Arthur E Brown DDS 367 Washington Street Braintree, MA 02184 #: 06405689 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Atlas High Purity Solutions, LLC 100 Messina Drive Suite 105 Braintree, MA 02184 #: 06404646 Category: 02	0101	Regeneration of resins and cleaning of membranes			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b> Copper (Total)						

## Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----			-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter		Date	Parameter	Result	Limit	Date	Actions
Blue Hills Dental Associates 340 Wood Road Suite 288 Braintree, MA 02184 #: 06407242 Category: D1		Lead (Total) Zinc (Total) pH	No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Braintree Dental Group 369 Washington Street Braintree, MA 02184 #: 06407244 Category: D1			No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Braintree Dentistry and Braces 292 Grove Street Braintree, MA 02184 #: 06407241 Category: D1			No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Braintree Family Dental 381 Washington Street Braintree, MA 02184 #: 06405690 Category: D1			No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Braintree Printing Inc. 230 Wood Road Braintree, MA 02184 #: 06103121 Category: 10			No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dunkin Brands, Inc. (University) 589 Granite Street Braintree, MA 02184 #: 06405210 Category: G2			No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Earl R Marrow III DMD 409 Pond Street Suite 7 Braintree, MA 02184 #: 06405693 Category: D1			No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Extended Stay America #1029 Braintree 20 Rockdale Street Braintree, MA 02184 #: 06404931 Category: 10			No Reporting Requirements			No Discharge Violations		28-Oct-2021 Notice of Noncompliance 05- May-2022 PenaltyAssessment Notice 05-May-2022 PenaltyAssessment Notice	
Family Dental Health Center 222 Forbes Road Suite 1105 Braintree, MA 02184 #: 06406171 Category: D1			No Reporting Requirements			No Discharge Violations			No Enforcement Actions



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Financial Graphic Services, Inc. 1 Rex Drive Braintree, MA 02184 #: 06009461 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Fireking Baking Company 185 Campanelli Drive Braintree, MA 02184 #: 06102573 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gentle Dental Braintree 102 /103 Pearl Street Braintree, MA 02184 #: 06405686 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
George Salem DMD & Associates PC 60 Adams Street Braintree, MA 02184 #: 06405699 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Great Hill Dental Braintree 100 Grossman Drive Suite 210 Braintree, MA 02184 #: 06405685 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hampton Inn Boston/Braintree 215 Wood Road Braintree, MA 02184 #: 06103119 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Harvard Vanguard Medical Associates 111 Grossman Drive Braintree, MA 02184 #: 06006710 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hersey Dental PC 1150 Washington Street Braintree, MA 02184 #: 06405687 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hub Pen Company 1525 Washington Street Braintree, MA 02184 #: 06103647 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Jack and Jill Pediatric Dentists 340 Wood Road Suite 288 Braintree, MA 02184 #: 06407243 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
John C Kimble DMD 545 Washington Street Braintree, MA 02184 #: 06405697 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Konditor Meister 32 Wood Road Braintree, MA 02184 #: 06405125 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Local Motion, Inc. 77 Rocsam Park Road Braintree, MA 02184 #: 06404798 Category: 02	0101	<i>Bus wash waste water</i>			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Oil and Grease						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Marr Crane & Rigging Co. 201 Commerce Drive Braintree, MA 02184 #: 06408366 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Montillo Dental Associates of Braintree 420 Washington Street Suite 101 Braintree, MA 02184 #: 06405695 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Norfolk Hospitality LLC, dba Best Western 190 Wood Road Braintree, MA 02184 #: 06101810 Category: 02	0101	<i>Wastewater from laundry</i>			No Discharge Violations			No Enforcement Actions
	<b>Annual</b>	<b>Self-Monitoring</b>						
		Copper (Total)						
		Lead (Total)						
		Oil and Grease						
		Zinc (Total)						
		pH						
Oliva Dentistry 14 Wood Road Suite 104 Braintree, MA 02184 #: 06405875 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Peterson Linen Rental & Sales, Inc. 215 Shaw Street Braintree, MA 02184 #: 06007387 Category: 02	0101	Washing machine effluent			No Discharge Violations		23-Nov-2021	Notice of Violation
	Quarterly	Self-Monitoring Oil and Grease pH Oil and Grease pH						
Pinnacle Dental 10 Forbes Road Suite 230 Braintree, MA 02184 #: 06405684 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Residence Inn Boston-Braintree 180 Forbes Road Braintree, MA 02184 #: 06405373 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Richard F. Struzziero 575 Washington Street Braintree, MA 02184 #: 06405698 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Richard J Baker DMD 409 Pond Street Unit 6 Braintree, MA 02184 #: 06405694 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Smilistic Dental Care LLC 250 Granite Street Suite 1060 Braintree, MA 02184 #: 06409309 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sonesta Simply Suites 235 Wood Road Braintree, MA 02184 #: 06103118 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
South Shore Dental Group 350 Granite Street Braintree, MA 02184 #: 06405688 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
South Shore Smiles 44 Adams Street Braintree, MA 02184 #: 06405696 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
United Rentals 115 Wood Road Braintree, MA 02184 #: 06405488 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
United Rentals (North America), Inc. 131 Messina Drive Braintree, MA 02184 #: 06405269 Category: 02	0101	<i>Washwater from equipment washbay from OWS inlet pipe</i>			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Lead (Total)						
		Nickel (Total)						
		Oil and Grease						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Widowmaker Brewing Co. 220 Wood Road Braintree, MA 02184 #: 06405225 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Wollaston Alloys, Inc. 205 Wood Road Braintree, MA 02184 #: 06000965 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Zanfaly Dental 400 Washington Street Suite 103 Braintree, MA 02184 #: 06407251 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
AM Dental Group 1576 Commonwealth Avenue Brighton, MA 02135 #: 46405700 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Amity Dental Center 637 Washington Street Brighton, MA 02135 #: 46405711 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Brighton Dental Associates 367 Washington Street Brighton, MA 02135 #: 46407256 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Brighton Dental Group LLC 1607 Commonwealth Avenue Unit 3 Brighton, MA 02135 #: 46405701 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Brighton Family Dental Group LLP 77 Warren Street Brighton, MA 02135 #: 46405712 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Cambridge Biomedical Inc. 1320 Soldiers Field Road Brighton, MA 02135 #: 46101954 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Charles River Community Health 495 Western Avenue Brighton, MA 02135 #: 46405708 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Franciscan Hospital for Children 30 Warren Street Brighton, MA 02135 #: 46405705 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gentle Dental Brighton 320 Washington Street Brighton, MA 02135 #: 46405706 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Ice Box, LLC 80 Guest Street Brighton, MA 02135 #: 46406531 Category: 02	0101	<i>Neutralized effluent from R&amp;D labs</i>			No Discharge Violations		30-Mar-2022 Notice of Violation	
	<b>Annual</b>	<b>Self-Monitoring</b> Copper (Total) Formaldehyde Lead (Total) Mercury (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Ilya Ginzburg DMD 2001 Beacon Street Suite 102 Brighton, MA 02135 #: 46405702 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Maria Vasilakis DMD 438 Washington Street Brighton, MA 02135 #: 46405707 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
NanoView Biosciences, Inc. 1380 Soldiers Field Road Suite 1000 Brighton, MA 02135 #: 46408214 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
New Balance Athletics, Inc. 145 Newton Street Brighton, MA 02135 #: 46000969 Category: 02	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Alan Sasson DMD 12 Webster Street Brookline, MA 02446 #: 07405726 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Alpha Plus Dental Center 185 Harvard Street Brookline, MA 02446 #: 07405753 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Ascend Dental Studio, PLLC 1051 Beacon Street Suite 408 Brookline, MA 02446 #: 07405719 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Beacon Dental Center 1842 Beacon Street Suite 206 Brookline, MA 02446 #: 07407286 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Beacon Family Dental 1691 Beacon Street Suite 104 Brookline, MA 02446 #: 07407279 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Beacon Place Dental Group 1371 Beacon Street Suite 101 Brookline, MA 02446 #: 07405733 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Beacon Street Dental Care 1678 Beacon Street Suite 1 Brookline, MA 02445 #: 07405744 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Boris Urman DMD 1149 Beacon Street Brookline, MA 02446 #: 07405721 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Brigham & Women's Ambulatory Care Center 850 Boylston Street Chestnut Hill, MA 02467 #: 07102508 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Brook House Dental Associates 77 Pond Avenue Brookline, MA 02445 #: 07405771 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Brookline Dental Associates 209 Harvard Street Suite 502 Brookline, MA 02446 #: 07407856 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Brookline Dental Center 1199 Beacon Street Unit 1 Brookline, MA 02446 #: 07405725 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Brookline Dental Specialists 21 Longwood Avenue Brookline, MA 02446 #: 07407298 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Brookline Dental Studio 1247 A Beacon Street Brookline, MA 02446 #: 07405728 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Brookline Denture Center 1842 Beacon Street Suite 102 Brookline, MA 02445 #: 07407285 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Brookline Endodontic Associates 1 Brookline Place Brookline, MA 02445 #: 07405713 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Brookline Progressive Dental Team 1842 Beacon Street Suite 301 Brookline, MA 02445 #: 07405749 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Brookline Village Dental 33 Pond Avenue Suite 103 Brookline, MA 02445 #: 07405765 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
CDS of Boston 209 Harvard Street Suite 302 Brookline, MA 02446 #: 07407294 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Center for Pediatric Dental Care 209 Harvard Street Floor 2 Brookline, MA 02446 #: 07405739 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Citidental Brookline 637 Washington Street Suite 210 Brookline, MA 02446 #: 07405770 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Cleveland Circle Dental Associates, PC 1798 Beacon Street Brookline, MA 02445 #: 07407281 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
DaVita Inc. - Brookline Dialysis 322 Washington Street Brookline, MA 02445 #: 07101085 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Darel Moss DDS PC 1682 Beacon Street Brookline, MA 02445 #: 07405745 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
David A. Chemin DMD 284 Harvard Street Brookline, MA 02446 #: 07405764 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental Partners of Brookline 1540 Beacon Street Brookline, MA 02446 #: 07405738 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dr. Alex Verbitsky DMD 1415 Beacon Street Suite 321 Brookline, MA 02446 #: 07405736 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Dr. Robert J. Maloney and Dr. Patrick J. Joyce 1051 Beacon Street Suite 204 Brookline, MA 02446 #: 07405718 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Eash Dental 1247 -A Beacon Street Brookline, MA 02446 #: 07407857 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Elovic Dental Care 209 Harvard Street Suite 501 Brookline, MA 02446 #: 07405757 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Fenway Communications Group 870 Commonwealth Avenue Boston, MA 02215 #: 07404839 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gary R Login 209 Harvard Street Suite 402 Brookline, MA 02446 #: 07405761 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gentle Dental Center of Brookline 1037 -A Beacon Street Brookline, MA 02446 #: 07405716 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Jamie L Wong DDS 1330 Beacon Street Suite 261 Brookline, MA 02446 #: 07405730 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Kenneth L Krowne DMD 209 Harvard Street Brookline, MA 02446 #: 07405760 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lawrence L Phan DMD PC 1330 Beacon Street Suite 353 Brookline, MA 02446 #: 07405731 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lee Dental Associates 1368 Beacon Street Brookline, MA 02446 #: 07405732 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Limited to Endodontics 209 Harvard Street Suite 500 Brookline, MA 02446 #: 07405755 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Longo Dental Associates 1037 Beacon Street Suite 2 Brookline, MA 02446 #: 07405715 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Longwood Dental Group 1842 Beacon Street Suite 100 Brookline, MA 02445 #: 07405748 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Mira Zinger & Associates 81 School Street Brookline, MA 02446 #: 07405773 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Nicholas G. Tsakos, DDS 1842 Beacon Street Suite 306 Brookline, MA 02445 #: 07405752 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
OG Dental Group 1330 Beacon Street Suite 228 Brookline, MA 02446 #: 07407268 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Pine Manor College 400 Heath Street Brookline, MA 02467 #: 07006028 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Po Po Isa Chui DMD 1051 Beacon Street Suite 102 Brookline, MA 02446 #: 07405717 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Po Po Isa Chui, DMD, LLC 1712 Beacon Street Brookline, MA 02445 #: 07405747 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Robert Guen DMD 1035 A Beacon Street Brookline, MA 02446 #: 07405714 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Robert S. Hutner, DMD 1842 Beacon Street Suite 405 Brookline, MA 02445 #: 07405751 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Routed Dental Company PLLC 1371 Beacon Street Suite 201 Brookline, MA 02446 #: 07405734 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Royal Dental Boston 1051 Beacon Street Suite 514 Brookline, MA 02446 #: 07405720 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Sahani Dental LLC 33 Pond Avenue Suite 100 Brookline, MA 02445 #: 07405723 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Sahara Dental Center 364 Harvard Street Suite 1C Brookline, MA 02446 #: 07405766 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Sara Stock DDS PC 1425 Beacon Street Brookline, MA 02446 #: 07405737 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Smile Solutions 1051 Beacon Street Suite 409 Brookline, MA 02446 #: 07407261 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
SmileBoston Cosmetic & Implant Dentistry 1180 Beacon Street Suite 2B Brookline, MA 02446 #: 07405724 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
The Dental Office at 367 Harvard St. 367 Harvard Street Brookline, MA 02446 #: 07405768 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
The Inn at Brookline 1200 Beacon Street Brookline, MA 02446 #: 07101824 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Theodore Swerdlick 389 Harvard Street Brookline, MA 02446 #: 07405769 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Whiteman Dental Associates LLC 8 Alton Place Suite 1 Brookline, MA 02446 #: 07405772 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
A Step Ahead Prosthetics Boston LLC 21 A Street Burlington, MA 01803 #: 08404246 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
AbPro, Inc. 15 A Street Burlington, MA 01803 #: 08404789 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Abbott Laboratories 23 Fourth Avenue Burlington, MA 01803 #: 08103259 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Advanced Dental Care 388 Cambridge Street Burlington, MA 01803 #: 08405786 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Air Purchases Incorporated 24 Blanchard Road Burlington, MA 01803 #: 08005553 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Albion Dental Care 23 -C Cambridge Street Burlington, MA 01803 #: 08405778 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
American Boronite Corp. (Boronite) 11 Cypress Drive Burlington, MA 01803 #: 08404787 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
American Food Systems, Inc. 30 B Street Burlington, MA 01867 #: 08006692 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Atrius Health - Harvard Vanguard Medical Associates 20 Wall Street Burlington, MA 01803 #: 08008981 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Bliss Dental 83 Cambridge Street Suite 3A Burlington, MA 01803 #: 08405789 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Burlington Center Dental Associates 30 Chestnut Avenue Floor 2 Burlington, MA 01803 #: 08405785 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Burlington Children's Dental 131 Cambridge Street Floor 1 Burlington, MA 01803 #: 08407311 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Burlington Family Dental 51 Winn Street Burlington, MA 01803 #: 08405787 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Burlington Smiles Dental 279 Cambridge Street Suite 9 Burlington, MA 01803 #: 08408118 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental Bright of Burlington 11 Cambridge Street Burlington, MA 01803 #: 08407300 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental Care of Burlington 113 Terrace Hall Avenue Burlington, MA 01803 #: 08407303 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Derek Song, DMD 281 Cambridge Street Burlington, MA 01803 #: 08407937 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Desktop Metal, Inc. 63 Third Avenue Burlington, MA 01803 #: 08405013 Category: 10	No Reporting Requirements				No Discharge Violations		23-Sep-2021	Notice of Violation

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>	<u>-----DISCHARGE VIOLATIONS-----</u>			<u>-----ENFORCEMENT ACTIONS-----</u>		
	<u>Frequency</u> <u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
EMD Millipore Corporation 400 Summit Drive Burlington, MA 01803 #: 08405325 Category: 02	0101 <i>pH neutralization tank building 400</i>  <b>Semi-Annual Self-Monitoring</b> Copper (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH			No Discharge Violations			No Enforcement Actions
Extended Stay America #9664 Boston-Burlington 40 South Avenue Burlington, MA 01803 #: 08102142 Category: 10	0103 <i>pH neutralization tank building 600</i>  <b>Semi-Annual Self-Monitoring</b> Copper (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH		No Reporting Requirements	No Discharge Violations			No Enforcement Actions
FDR Center for Prosthetics & Orthotics 8 Ray Avenue Burlington, MA 01803 #: 08404482 Category: 10	No Reporting Requirements		No Reporting Requirements	No Discharge Violations			No Enforcement Actions
Gentle Dental Burlington 184 Cambridge Street Burlington, MA 01803 #: 08405777 Category: D1	No Reporting Requirements		No Reporting Requirements	No Discharge Violations			No Enforcement Actions
Glaukos Corp. (formerly Avedro, Inc.) 30 North Avenue Burlington, MA 01803 #: 08406549 Category: 10	No Reporting Requirements		No Reporting Requirements	No Discharge Violations			No Enforcement Actions
Goodway Graphics of MA dba Goodway Group of MA, Inc. 16 A Street Burlington, MA 01803 #: 08004919 Category: 10	No Reporting Requirements		No Reporting Requirements	No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Hyatt House Boston/Burlington 2 Van De Graaff Drive Burlington, MA 01803 #: 08102133 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
James P Kostas DMD PC 165 Bedford Street Suite 2 Burlington, MA 01803 #: 08407165 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
James W Quinn DMD 279 Cambridge Street Burlington, MA 01803 #: 08405780 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Janiene Gresla DDS PC 120 Cambridge Street Suite 13 Burlington, MA 01803 #: 08405775 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Joseph A Spinali DMD 279 Cambridge Street Floor 2 Burlington, MA 01803 #: 08405781 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Keurig Doctor Pepper 63 South Avenue Burlington, MA 01803 #: 08404160 Category: 02	0101	<i>Wastewater from the coffee brewer R&amp;D labs</i>	0101	<i>Wastewater from the coffee brewer R&amp;D labs</i>				28-Jul-2021 Notice of Violation 01-Sep-2021 Notice of Violation 16-Feb-2022 Notice of Noncompliance
		<b>Semi-Annual Self-Monitoring</b>	10-Aug-2021	Copper (Total)	1.29	mg/l DYMX < 1		
		Arsenic (Total)						
		Chromium (Total)						
		Copper (Total)						
		Nickel (Total)						
		Oil and Grease						
		Zinc (Total)						
		pH						
LeMaitre Vascular, Inc. 63 Second Avenue Burlington, MA 01803 #: 08403541 Category: 02	0101	<i>pH neutralization system</i>			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b>						
		Copper (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0201	<i>latex balloon DI water baths (7) discharge to sink</i>						
		<b>Annual Self-Monitoring</b>						
		TTO (Volatile Organic Fraction)						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Middlesex Endodontics 172 Cambridge Street Suite 201 Burlington, MA 01803 #: 08405776 Category: D1	No Reporting Requirements	pH			No Discharge Violations			No Enforcement Actions
Modern Smiles Dental Care 120 Cambridge Street # 11 Burlington, MA 01803 #: 08407306 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Natural Pharmacia International, Inc. 121 Middlesex Turnpike Burlington, MA 01803 #: 08404478 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Northeastern University - Burlington Campus 145 S Bedford Street Burlington, MA 01803 #: 08008982 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Paul Lombardo DMD 104 Winn Street Burlington, MA 01803 #: 08405774 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Sarepta Therapeutics 55 Blue Sky Drive Burlington, MA 01803 #: 08406823 Category: 02	0101	sampling spigot after pH neutralization			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>	Copper (Total) Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Super Smiles Dental 54 Middlesex Turnpike Burlington, MA 01803 #: 08405788 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Surmet Corporation 18 A Street Burlington, MA 01803 #: 08403416 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Tayari Dental 265 Winn Street Suite 204 Burlington, MA 01803 #: 08405779 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	<b>-----CURRENT SAMPLING REQUIREMENTS-----</b>		<b>-----DISCHARGE VIOLATIONS-----</b>				<b>-----ENFORCEMENT ACTIONS-----</b>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
VulcanForms Inc. 20 North Avenue Burlington, MA 01803 #: 08408260 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wayne's Drains Inc. 36 Grant Avenue Unit 5 Burlington, MA 01803 #: 08103411 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
24M Technologies, Inc. 130 Brookline Street Suite 200 Cambridge, MA 02139 #: 09404270 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
620 Memorial Leasehold LLC 620 Memorial Drive Cambridge, MA 02139 #: 09404466 Category: 02	0101	<i>pH neutralization system</i>			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b> Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Molybdenum Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
AC Hotel by Marriott Boston/Cambridge 10 Acom Park Drive Cambridge, MA 02141 #: 09405168 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
ARE Laboratory Specialists LLC - The Science Hotel 790 Memorial Drive Cambridge, MA 02139 #: 09102944 Category: 02	0101	<i>Sample port after the pH neutralization tank</i>	0101	<i>Sample port after the pH neutralization tank</i>				12- Apr-2022 Notice of Violation
		<b>Semi-Annual Self-Monitoring</b> Cadmium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH	22-Mar-2022	Cyanide (Total)	1.7	mg/l DYMX < 0.5		

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	<b>-----CURRENT SAMPLING REQUIREMENTS-----</b>	<b>-----DISCHARGE VIOLATIONS-----</b>	<b>-----ENFORCEMENT ACTIONS-----</b>
	<u>Frequency</u> <u>Parameter</u>	<u>Date</u> <u>Parameter</u> <u>Result</u> <u>Limit</u>	<u>Date</u> <u>Actions</u>
ARE-MA Region No. 45, LLC 100 Binney Street Cambridge, MA 02142 #: 09405495 Category: 02	0101 <i>Laboratory R&amp;D effluent from the 6th &amp; 7th floors.</i>  <b>Semi-Annual Self-Monitoring</b> Antimony (Total) Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Formaldehyde Lead (Total) Mercury (Total) Molybdenum Nickel (Total) Selenium (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH	0101 <i>Laboratory R&amp;D effluent from the 6th &amp; 7th floors.</i>  7-Dec-2021    Formaldehyde                      10.1                      mg/l                      DYMX < 9 7-Jun-2022    Formaldehyde                      22                      mg/l                      DYMX < 9 7-Jun-2022    Chloroform (Trichloromethane)                      1.6                      mg/l                      DYMX < 1	23-Jul-2021    Notice of Violation 20-Dec-2021    Notice of Violation 22-Jun-2022    Notice of Violation
ARE-MA Region No. 59, LLC One Kendall Square Suite B1400 Cambridge, MA 02139 #: 09403452 Category: 02	0101 <i>Building 1400 3rd floor incubator lab effluent</i>  <b>Semi-Annual Self-Monitoring</b> Mercury (Total) TTO (Volatile Organic Fraction) pH  0301 <i>Building 700 pH adjustment system</i>  <b>Semi-Annual Self-Monitoring</b> Copper (Total) Mercury (Total) Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH  0302 <i>Sampling spigots on discharge piping after pH adjustment system #4</i>  <b>Semi-Annual Self-Monitoring</b> Cyanide (Total) Formaldehyde Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH  0401 <i>399 Binney Street pH adjustment system</i>  <b>Semi-Annual Self-Monitoring</b> Copper (Total)	No Discharge Violations	No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>	<u>-----DISCHARGE VIOLATIONS-----</u>	<u>-----ENFORCEMENT ACTIONS-----</u>				
<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
	Formaldehyde Mercury (Total) Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	0501 <i>Building 200 pH adjustment system</i>  <b>Semi-Annual Self-Monitoring</b> Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	0502 <i>Laboratory wastewater from 3rd floor of building 200</i>  <b>Semi-Annual Self-Monitoring</b> Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
ARE-Tech Square LLC (100 Tech Sq) 100 Technology Square Cambridge, MA 02139 #: 09103122 Category: 02	0101 <i>Sample port on the pH neutralization system discharge line</i>  <b>Semi-Annual Self-Monitoring</b> Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total)	No Discharge Violations	No Enforcement Actions				

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
AZENTA 733 Concord Avenue Cambridge, MA 02138 #: 09403418 Category: 02	0101	Standpipe on Discharge Piping after pH Adjustment  Semi-Annual Self-Monitoring Copper (Total) Lead (Total) Mercury (Total) TTO (Volatile Organic Fraction) Zinc (Total) pH			No Discharge Violations		No Enforcement Actions	
Acceleron Pharma, Inc. 128 Sidney Street Cambridge, MA 02139 #: 09103277 Category: 02	0101	Sample port on the neutralization system discharge line at 149 Sidney St  Semi-Annual Self-Monitoring Copper (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Volatile Organic Fraction) pH			No Discharge Violations		No Enforcement Actions	
	0201	Sample port on the neutralization system discharge line at 128 Sidney St  Semi-Annual Self-Monitoring Copper (Total) Mercury (Total) Silver (Total) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	0401	Sample port on the neutralization system discharge line at 167 Sidney St  Annual Self-Monitoring Formaldehyde pH						
Agios Pharmaceuticals Inc. 88 & 64 Sidney Street Cambridge, MA 02139 #: 09103308 Category: 10		No Reporting Requirements			No Discharge Violations		No Enforcement Actions	
Albert R Duarte DMD PC 2130 Massachusetts Avenue Suite 1A Cambridge, MA 02140 #: 09405806 Category: D1		No Reporting Requirements			No Discharge Violations		No Enforcement Actions	

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>	<u>-----DISCHARGE VIOLATIONS-----</u>	<u>-----ENFORCEMENT ACTIONS-----</u>
	<u>Frequency</u> <u>Parameter</u>	<u>Date</u> <u>Parameter</u> <u>Result</u> <u>Limit</u>	<u>Date</u> <u>Actions</u>
Alnylam Pharmaceuticals, Inc. 675 West Kendall Street Cambridge, MA 02142 #: 09103256 Category: 02	<p>0101    <i>Sample spigot(s) on the pH neutralization system effluent line.</i></p> <p><b>Semi-Annual Self-Monitoring</b></p> <ul style="list-style-type: none"> <li>Copper (Total)</li> <li>Cyanide (Total)</li> <li>Mercury (Total)</li> <li>Nickel (Total)</li> <li>TTO (Extractable Organic Fraction)</li> <li>TTO (Volatile Organic Fraction)</li> <li>Zinc (Total)</li> <li>pH</li> </ul> <p>0201    <i>Sample spigot(s) on the pH neutralization system effluent line</i></p> <p><b>Quarterly Self-Monitoring</b></p> <ul style="list-style-type: none"> <li>Cyanide (Total)</li> <li>Mercury (Total)</li> <li>TTO (Extractable Organic Fraction)</li> <li>TTO (Volatile Organic Fraction)</li> <li>Zinc (Total)</li> <li>pH</li> </ul>	No Discharge Violations	No Enforcement Actions
Alnylam Pharmaceuticals, Inc. 665 Concord Avenue Cambridge, MA 02138 #: 09403820 Category: 10	No Reporting Requirements	No Discharge Violations	No Enforcement Actions
Alvarez Dental Group 403 Cambridge Street Cambridge, MA 02141 #: 09405815 Category: D1	No Reporting Requirements	No Discharge Violations	No Enforcement Actions
American Dental Cambridge 2335 Massachusetts Avenue Cambridge, MA 02140 #: 09407347 Category: D1	No Reporting Requirements	No Discharge Violations	No Enforcement Actions
Amgen Cambridge Real Estate Holdings, Inc. (ACREH) 360 Binney Street Cambridge, MA 02142 #: 09102684 Category: 02	<p>0101    <i>Spigots on 4" piping downstream of ejector pit and perfusion waste connection</i></p> <p><b>Quarterly Self-Monitoring</b></p> <ul style="list-style-type: none"> <li>Antimony (Total)</li> <li>Arsenic (Total)</li> <li>Cadmium (Total)</li> <li>Chromium (Total)</li> <li>Cyanide (Total)</li> <li>Formaldehyde</li> <li>Lead (Total)</li> <li>Mercury (Total)</li> <li>Nickel (Total)</li> <li>Selenium (Total)</li> <li>Silver (Total)</li> </ul>	No Discharge Violations	No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Avastus Preclinical Services 359 Allston Street Cambridge, MA 02139 #: 09404997 Category: 10	No Reporting Requirements	TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Temperature Zinc (Total) pH						No Enforcement Actions
Avastus Preclinical Services LLC 44 Spinelli Place Cambridge, MA 02138 #: 09406892 Category: 10	No Reporting Requirements							No Enforcement Actions
Axcella Health, Inc. 840 Memorial Drive Floor 3 Cambridge, MA 02139 #: 09403579 Category: 10	No Reporting Requirements							No Enforcement Actions
BMR - 325 Vassar Street LLC 325 Vassar Street Cambridge, MA 02139 #: 09403618 Category: 02	0101 <i>research waste water</i>  Semi-Annual <b>Self-Monitoring</b> Cadmium (Total) Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						07-Jul-2021 Notice of Violation 06-Aug-2021 Notice of Violation	
Be Fresh Dental of Cambridge 777 Concord Avenue Suite 303 Cambridge, MA 02138 #: 09405822 Category: D1	No Reporting Requirements							No Enforcement Actions
Beam Therapeutics 26 Landsdowne Street Cambridge, MA 02139 #: 09406670 Category: 10	No Reporting Requirements							No Enforcement Actions
Biogen, Inc. 125 Broadway Cambridge, MA 02142 #: 09102730 Category: 02	0101 <i>Spigot on the pH neutralization system discharge line</i>  Quarterly <b>Self-Monitoring</b> Cadmium (Total)							No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Bioscience Research Associates, Inc. 767 C Concord Avenue Cambridge, MA 02138 #: 09103458 Category: 10		Chromium (Total) Copper (Total) Formaldehyde Mercury (Total) Nickel (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Bolton Street Partners, LLC 85 Bolton Street Cambridge, MA 02140 #: 09403580 Category: 02	0101	<i>research wastewater after pH neutralization system</i>						27-Aug-2021 Notice of Violation
	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Boston Biochem, Inc. 840 Memorial Drive Suite 3 Cambridge, MA 02139 #: 09103139 Category: 10		<b>Semi-Annual Self-Monitoring</b> Cadmium (Total) Chromium (Total) Copper (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Boston Scientific 125 Cambridgepark Drive Suite 600 Cambridge, MA 02140 #: 09406946 Category: 10								
	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Brammer Bio 250 Binney Street Cambridge, MA 02142 #: 09005998 Category: 02	0101	<i>Spigot on discharge line of the pH neutralization system in Bldg 6A</i>						11-Aug-2021 Notice of Violation
	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
	<b>Annual</b>	<b>Self-Monitoring</b> 1,2-Dichlorobenzene 1,2-Dichloroethane 4-Methyl-2-Pentanone (MIBK) Acetone Ammonia-Nitrogen AsN Benzene Biochemical Oxygen Demand (5 Day) Chlorobenzene						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
<u>INDUSTRY</u>	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
		Chloroform (Trichloromethane)						
		Cyanide (Total)						
		Diethylamine						
		Ethyl Acetate						
		Isobutyraldehyde						
		Isopropyl Acetate						
		Isopropyl Ether						
		Methyl Cellulosolve						
		Methyl Formate						
		Methylene Chloride (Dichloromethane)						
		N-Amyl Acetate						
		N-Butyl Acetate						
		N-Heptane						
		N-Hexane						
		Sulfate						
		Tetrahydrofuran						
		Toluene						
		Triethylamine						
		Xylenes 2235						
		Antimony (Total)						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Broad Institute 415 Main Street Cambridge, MA 02142 #: 09103391 Category: 02	0101	<i>Spigot on the pH neutralization system discharge line at 415 Main Street</i>						
		<b>Semi-Annual Self-Monitoring</b>						
		Antimony (Total)						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
					No Discharge Violations			No Enforcement Actions



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>	<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>
<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u> <u>Actions</u>
	Zinc (Total) pH					
	0201 <i>Bioomedical research wastewater from the 75 Ames St. Building</i>					
	<b>Semi-Annual Self-Monitoring</b> Antimony (Total) Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH					
Broad Institute Inc. 320 Charles Street Cambridge, MA 02142 #: 09101882 Category: 02	0101 <i>SAMPLE PORT ON THE pH NEUTRALIZATION SYSTEM DISCHARGE LINE</i>			No Discharge Violations		No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b> Formaldehyde Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH					
Camberville Dental 825 Cambridge Street Cambridge, MA 02141 #: 09405823 Category: D1	No Reporting Requirements			No Discharge Violations		No Enforcement Actions
Cambridge Brewing Company 1 Kendall Square Suite B-1102 Cambridge, MA 02139 #: 09405174 Category: 10	No Reporting Requirements			No Discharge Violations		No Enforcement Actions
Cambridge Dental Annex 897 Massachusetts Avenue Cambridge, MA 02139 #: 09405827 Category: D1	No Reporting Requirements			No Discharge Violations		No Enforcement Actions
Cambridge Dental Group 126 Inman Street Cambridge, MA 02139 #: 09405794 Category: D1	No Reporting Requirements			No Discharge Violations		No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Cambridge Endodontics 1692 Massachusetts Avenue Cambridge, MA 02138 #: 09405801 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cambridge Health Alliance - Cambridge Hospital 1493 Cambridge Street Cambridge, MA 02139 #: 09005730 Category: 02	0101	<i>Spigot on discharge line of pH neutralization system</i>			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>	Copper (Total) Cyanide (Total) Formaldehyde Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
Cambridge Marriott Hotel 50 Broadway Cambridge, MA 02142 #: 09103239 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cambridgeport Dental 10 Magazine Street Suite D Cambridge, MA 02139 #: 09407333 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cambridgeside Dental 77 Hurley Street Cambridge, MA 02141 #: 09405820 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cambridgeside Galleria Associates Trust and John Moriarty & 80 First Street Cambridge, MA 02141 #: 09409374 Category: 12	0101	<i>Manhole D03DMH1100 located on Edwin Land Blvd</i>			No Discharge Violations			No Enforcement Actions
	<b>Monthly</b>	<b>Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
	0102	<i>Catchbasin D03CBN0147 located along Cambridgeside Place</i>						
	<b>Monthly</b>	<b>Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total)						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH								
Center for Human Genetics, Inc. 840 Memorial Drive Suite 101 Cambridge, MA 02139 #: 09403914 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Central Square Dental 14 Pleasant Street Floor 1 Cambridge, MA 02139 #: 09405797 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Chang Shing Tofu, Inc. 37 -39 Rogers Street Cambridge, MA 02142 #: 09103465 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Charles W Malta DDS (Cambridge) 538 Cambridge Street Cambridge, MA 02141 #: 09405816 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Clear Scientific, Inc. 735 Concord Avenue Cambridge, MA 02138 #: 09102758 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Commonwealth Fusion Systems 148 Sidney Street Cambridge, MA 02139 #: 09408820 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Courtyard Dental 842 Massachusetts Avenue Cambridge, MA 02139 #: 09405824 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Cycleron Therapeutics, Inc. 301 Binney Street Cambridge, MA 02142 #: 09103693 Category: 02	0101	SPIGOT ON THE pH NEUTRALIZATION SYSTEM DISCHARGE LINE						No Enforcement Actions
	Semi-Annual Self-Monitoring							
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
		Nickel (Total) Selenium (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
DaVita Northeast Cambridge Dialysis 799 Concord Avenue Cambridge, MA 02138 #: 09103261 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
DePrimo's Dental 121 Charles Street Cambridge, MA 02141 #: 09405793 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental Restorative Group @ Cambridge 1751 Massachusetts Avenue Cambridge, MA 02138 #: 09405810 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental Services PC 1696 Massachusetts Avenue Cambridge, MA 02138 #: 09405802 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dermbiont, Inc. 19 Blackstone Street Cambridge, MA 02139 #: 09408790 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dr. Dental of Cambridge, PC 714 Massachusetts Avenue Cambridge, MA 02139 #: 09407357 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Eagle Pharmaceuticals, Inc. 47 Moulton Street Cambridge, MA 02138 #: 09407087 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Eutropics Pharmaceuticals, Inc. 767 -C Concord Avenue Floor 2 Cambridge, MA 02138 #: 09403557 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
FAEC 35 CPD, LLC 35 Cambridgepark Drive Cambridge, MA 02138 #: 09406802 Category: 02	0101 <i>Spigots and Access on Discharge Piping after pH Adjustment</i>  Semi-Annual Self-Monitoring Copper (Total)		0101 <i>Spigots and Access on Discharge Piping after pH Adjustment</i> 22-Dec-2021 24-May-2022	Cyanide (Total) Cyanide (Total)	1.5 1.2	mg/l mg/l	DYMX < 0.5 DYMX < 0.5	13- Jan-2022 Notice of Violation

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>	
	Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH							
	0201	Spigots on Discharge Piping after pH Adjustment						
	<b>Semi-Annual Self-Monitoring</b>							
	Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH							
FogPharma 30 Acorn Park Drive Cambridge, MA 02140 #: 09405002 Category: 02	0101	Sample spigot on discharge piping after pH adjustment		No Discharge Violations		29-Mar-2022	Notice of Violation	
	<b>Semi-Annual Self-Monitoring</b>							
	Copper (Total) Formaldehyde Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH							
Forsyth Institute 245 First Street Cambridge, MA 02142 #: 09405813 Category: D1		No Reporting Requirements		No Discharge Violations			No Enforcement Actions	
Francis Scimone, DDS 872 Massachusetts Avenue Suite 2-4 Cambridge, MA 02141 #: 09407359 Category: D1		No Reporting Requirements		No Discharge Violations			No Enforcement Actions	
Freepoint Hotel 220 Alewife Brook Parkway Cambridge, MA 02138 #: 09103237 Category: 10		No Reporting Requirements		No Discharge Violations			No Enforcement Actions	

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Fresh Pond Dental 180 Alewife Brook Parkway Cambridge, MA 02138 #: 09407342 Category: D1		No Reporting Requirements						No Enforcement Actions
Fulcrum Therapeutics, Inc. 26 Landsdowne Street Cambridge, MA 02139 #: 09404799 Category: 02	0101	Spigots on discharge piping after pH adjustment					02-Feb-2022 Notice of Violation 21-Mar-2022 Notice of Violation	
		<b>Semi-Annual Self-Monitoring</b> Formaldehyde TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
GENOSCO 767 -C Concord Avenue Floor 2 Cambridge, MA 02142 #: 09403538 Category: 10		No Reporting Requirements						No Enforcement Actions
GVD Corporation 45 Spinelli Place Cambridge, MA 02138 #: 09103124 Category: 10		No Reporting Requirements						No Enforcement Actions
Generation Bio 301 Binney Street Cambridge, MA 02139 #: 09407270 Category: 10		No Reporting Requirements						No Enforcement Actions
Gentle Dental Center of Cambridge 19 White Street Cambridge, MA 02140 #: 09405805 Category: D1		No Reporting Requirements						No Enforcement Actions
GlaxoSmithKline 200 Cambridge Park Drive Cambridge, MA 02140 #: 09102720 Category: 10		No Reporting Requirements						No Enforcement Actions
GrabCAD 9 Camp Street Cambridge, MA 02140 #: 09404612 Category: 10		No Reporting Requirements						No Enforcement Actions
Hampton Inn by Hilton - Boston/Cambridge 191 Monsignor O'Brien Highway Cambridge, MA 02141 #: 09103243 Category: 02	0102	Hotel laundry operation effluent						No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b> Copper (Total) Lead (Total) Mercury (Total) Oil and Grease Zinc (Total) pH						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Harbinger Oncology, Inc. 25 Spinelli Place Cambridge, MA 02138 #: 09409181 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Harvard Street Dental 287 Harvard Street Cambridge, MA 02139 #: 09405814 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Harvard University Health Services 114 Mount Auburn Street Cambridge, MA 02138 #: 09405792 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
HiFiBio Therapeutics 19 Blackstone Street Cambridge, MA 02139 #: 09407121 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Holiday Inn Express and Suites Cambridge 250 Monsignor O'Brien Highway Cambridge, MA 02141 #: 09103238 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hotel Veritas 1 Remington Street Cambridge, MA 02141 #: 09405169 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hyperion Catalysis International, Inc. 38 Smith Place Cambridge, MA 02138 #: 09007176 Category: 02					No Discharge Violations			No Enforcement Actions
	0101	<i>Riser pipe on the chip tank effluent line</i>						
		<b>Semi-Annual Self-Monitoring</b>						
			Chromium (Total)					
			Copper (Total)					
			Cyanide (Total)					
			Formaldehyde					
			Lead (Total)					
			Mercury (Total)					
			Molybdenum					
			Nickel (Total)					
			Silver (Total)					
			TTO (Volatile Organic Fraction)					
			Zinc (Total)					
			pH					
	0201	<i>Plastic extrusion contact cooling water</i>						
		<b>Semi-Annual Self-Monitoring</b>						
			TTO (Extractable Organic Fraction)					
			TTO (Volatile Organic Fraction)					
			pH					

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
	0202	Wastewater from nanotubule oxidation process						
	<b>Semi-Annual Self-Monitoring</b>							
		TTO (Volatile Organic Fraction)						
		pH						
Iggy's Bread, Ltd. 130 Fawcett Street Cambridge, MA 02138 #: 09102766 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Intellia Therapeutics, Inc. (130 Brookline Street) 130 Brookline Street Floor 2 Cambridge, MA 02139 #: 09404460 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ipsen Innovation Center/BioLabs 650 East Kendall Street Floor 2 Cambridge, MA 02142 #: 09404289 Category: 02	0102	Spigot on Discharge Piping after pH Adjustment			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Jeffrey E. Greenberg, DMD, P.C (dba Sweet Spot Dental) 763 Massachusetts Avenue Suite 1 Cambridge, MA 02139 #: 09405819 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Kendall Hotel 350 Main Street Cambridge, MA 02142 #: 09103236 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Kendall Square Dental Associates 1 Kendall Square Suite 3104 Cambridge, MA 02139 #: 09405790 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Kronos Bio., Inc. 301 Binney Street Floor 2 Cambridge, MA 02142 #: 09408655 Category: 02	0101	Sample spigots on discharge piping			No Discharge Violations		02-Aug-2021 Notice of Violation 14-Sep-2021 Notice of Violation	
	<b>Semi-Annual Self-Monitoring</b>							
		Copper (Total)						
		Formaldehyde						
		Mercury (Total)						
		TTO (Volatile Organic Fraction)						
		pH						



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>	<u>-----DISCHARGE VIOLATIONS-----</u>	<u>-----ENFORCEMENT ACTIONS-----</u>
	<u>Frequency</u> <u>Parameter</u>	<u>Date</u> <u>Parameter</u> <u>Result</u> <u>Limit</u>	<u>Date</u> <u>Actions</u>
LS 400/500 CDP, LLC 20 Acorn Park Drive Cambridge, MA 02140 #: 09408148 Category: 02	0101 <i>Sample spigot on discharge piping after pH adjustment</i>  <b>Semi-Annual Self-Monitoring</b> Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH	No Discharge Violations	13-Sep-2021 Notice of Violation
LabCentral 700 Main Street Cambridge, MA 02139 #: 09404113 Category: 02	0101 <i>Laboratory R&amp;D wastewater from 700 Main Street</i>  <b>Semi-Annual Self-Monitoring</b> Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH  0201 <i>Laboratory R&amp;D wastewater from 610 Main Street</i>  <b>Semi-Annual Self-Monitoring</b> Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH	No Discharge Violations	No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Lesley University 1801 Massachusetts Avenue Cambridge, MA 02138 #: 09103338 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Life Biosciences Inc. 45 Moulton Street Cambridge, MA 02138 #: 09406647 Category: 02		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
LifeCanvas Technologies 1035 Cambridge Street Suite 6 Cambridge, MA 02141 #: 09406651 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
MIT Dental Service 77 Massachusetts Avenue Cambridge, MA 02139 #: 09405821 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Marie B Jean-Mary DMDLCC dba Alegria Dental Group 1058 Cambridge Street Cambridge, MA 02139 #: 09407335 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Massachusetts General Hospital Corporation 38 Sidney Street Suite 100 Cambridge, MA 02139 #: 09102987 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Merck Sharp & Dohme LLC 320 Bent Street Cambridge, MA 02141 #: 09102677 Category: 02	0201	wastewater discharge from biomedical research			No Discharge Violations			No Enforcement Actions
	<b>Annual</b>	<b>Self-Monitoring</b> Cadmium (Total) Copper (Total) Formaldehyde Mercury (Total) Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	0202	Spigot on pH neutralization discharge line						
	<b>Semi-Annual Self-Monitoring</b> Cadmium (Total) Copper (Total) Formaldehyde Mercury (Total) Nickel (Total) TTO (Extractable Organic Fraction)							

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Mersana Therapeutics, Inc. 840 Memorial Drive Cambridge, MA 02139 #: 09103409 Category: 10	No Reporting Requirements	TTO (Volatile Organic Fraction) Zinc (Total) pH						No Enforcement Actions
Metalmark Innovations 767 Concord Avenue Suite 2-1 Cambridge, MA 02138 #: 09408604 Category: 10	No Reporting Requirements							No Enforcement Actions
Michael J. Bane, DDS 2179 Massachusetts Avenue Cambridge, MA 02140 #: 09405808 Category: D1	No Reporting Requirements							No Enforcement Actions
MolecularMD 840 Memorial Drive Floor 1 Cambridge, MA 02139 #: 09403802 Category: 10	No Reporting Requirements							No Enforcement Actions
Mount Auburn Hospital 330 Mount Auburn Street Cambridge, MA 02138 #: 09005756 Category: 02	0101 <b>Quarterly</b>	<i>EFFLUENT FROM PH NEUTRALIZATION SYSTEM</i>  Self-Monitoring Cyanide (Total) Formaldehyde Mercury (Total) TTO (Volatile Organic Fraction) pH					27-Aug-2021 Notice of Violation	No Enforcement Actions
	0201 <b>Semi-Annual Self-Monitoring</b>	<i>EFFLUENT FROM CENTRAL PROCESSING OPERATIONS</i>  Chromium (Total) Nickel (Total) Zinc (Total) pH						
North Cambridge Dental 2331 Massachusetts Avenue Cambridge, MA 02141 #: 09407345 Category: D1	No Reporting Requirements							No Enforcement Actions
Novartis Institutes for BioMedical Research 700 Main Street Cambridge, MA 02139 #: 09404370 Category: 02	0101 <b>Semi-Annual Self-Monitoring</b>	<i>biomedical research waste water</i>  Formaldehyde Mercury (Total) TTO (Volatile Organic Fraction)						No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Novartis Institutes for BioMedical Research 181 Massachusetts Avenue Cambridge, MA 02139 #: 09404634 Category: 02	0101  Quarterly	181 Mass Ave - biomedical research waste water  Self-Monitoring Mercury (Total) TTO (Volatile Organic Fraction) pH						No Discharge Violations  No Enforcement Actions
	0201  Semi-Annual	22 Windsor St - biomedical research waste water  Self-Monitoring Mercury (Total) TTO (Volatile Organic Fraction) pH						
Novartis Institutes for BioMedical Research, Inc. 250 Massachusetts Avenue Cambridge, MA 02139 #: 09103233 Category: 02	0101  Semi-Annual	SPIGOT ON NORTH PH NEUTRALIZATION SYSTEM DISCHARGE LINE  Self-Monitoring Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						No Discharge Violations  No Enforcement Actions
	0201  Semi-Annual	SPIGOT ON SOUTH PH NEUTRALIZATION SYSTEM DISCHARGE LINE  Self-Monitoring Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
NovoBiotic Pharmaceuticals, LLC 767 C Concord Street Cambridge, MA 02138 #: 09103303 Category: 10	No Reporting Requirements							No Discharge Violations  No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	<b>-----CURRENT SAMPLING REQUIREMENTS-----</b>		<b>-----DISCHARGE VIOLATIONS-----</b>				<b>-----ENFORCEMENT ACTIONS-----</b>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
One Hundred Inman L.P. 100 Inman Street Cambridge, MA 02139 #: 09103487 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Partners Healthcare System 65 Landsdowne Street Cambridge, MA 02139 #: 09102849 Category: 02	0101	<i>EFFLUENT DISCHARGED FROM PH NEUTRALIZATION</i>	No Discharge Violations				No Enforcement Actions	
	<b>Semi-Annual Self-Monitoring</b>							
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Mercury (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Paula Sones, DDS, PC dba Smiles 2400 Massachusetts Avenue Cambridge, MA 02140 #: 09405811 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Peter J. McDonald, DMD 872 Massachusetts Avenue Suite 2-6 Cambridge, MA 02139 #: 09407354 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Pfizer, Inc. 610 Main Street Cambridge, MA 02139 #: 09403775 Category: 02	0201	<i>One Portland Street R&amp;D wastewater neutralization system</i>	0201	<i>One Portland Street R&amp;D wastewater neutralization system</i>		03-Sep-2021 Notice of Violation		
		<b>Semi-Annual Self-Monitoring</b>	11-Aug-2021	Cyanide (Total)	0.78	mg/l	DYMX	< 0.5
		Cadmium (Total)	0301	<i>610 Main Street R&amp;D wastewater neutralization system</i>				
		Copper (Total)	11-Aug-2021	Cyanide (Total)	1.61	mg/l	DYMX	< 0.5
		Cyanide (Total)						
		Formaldehyde						
		Phenol						
		Silver (Total)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0301	<i>610 Main Street R&amp;D wastewater neutralization system</i>						
	<b>Semi-Annual Self-Monitoring</b>							
		Cadmium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Mercury (Total)						
		Phenol						
		Silver (Total)						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Philips Medical Systems 222 Jacobs Street Cambridge, MA 02141 #: 09408084 Category: 10	No Reporting Requirements	TTO (Volatile Organic Fraction) Zinc (Total) pH						No Enforcement Actions
Polyjoule, Inc. 148 Sidney Street Cambridge, MA 02139 #: 09404250 Category: 10	No Reporting Requirements							No Enforcement Actions
Porter Square Family Dental 14 Upland Road Cambridge, MA 02140 #: 09405798 Category: D1	No Reporting Requirements							No Enforcement Actions
Prospect Dental Group 30 Prospect Street Cambridge, MA 02139 #: 09407351 Category: D1	No Reporting Requirements							No Enforcement Actions
QnA Dx, LLC 99 -A Erie Street Cambridge, MA 02139 #: 09404166 Category: 02	0101	neutralization system  <b>Semi-Annual Self-Monitoring</b> Copper (Total) Lead (Total) Mercury (Total) Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH					07-Feb-2022 Notice of Violation 28-Mar-2022 Notice of Violation	
Quad 75 Moulton Street & 20 Wilson Road, LLC 75 Moulton Street Cambridge, MA 02138 #: 09406704 Category: 02	0101	Spigot on Discharge Piping  <b>Semi-Annual Self-Monitoring</b> Copper (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH					No Enforcement Actions	

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>	<u>-----DISCHARGE VIOLATIONS-----</u>			<u>-----ENFORCEMENT ACTIONS-----</u>		
	<u>Frequency</u> <u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Ra Pharmaceuticals, Inc. 87 Cambridge Park Drive Floor 1 Cambridge, MA 02140 #: 09403443 Category: 02	0101 <i>Biomedical research wastewater</i>  <b>Semi-Annual Self-Monitoring</b> Formaldehyde TTO (Volatile Organic Fraction) pH			No Discharge Violations			No Enforcement Actions
Ragon Institute 400 Tech Square 400 Technology Square Floor 7,8,9,basemnt Cambridge, MA 02139 #: 09403940 Category: 02	0101 <i>biomedical research waste water</i>  <b>Semi-Annual Self-Monitoring</b> Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH			No Discharge Violations			No Enforcement Actions
Repertoire Immune Medicine 26 Landsdowne Street Cambridge, MA 02139 #: 09406641 Category: 10	No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Residence Inn Boston Cambridge 120 Broadway Cambridge, MA 02142 #: 09006929 Category: 10	No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Rheos Medicines, Inc. 245 First Street Cambridge, MA 02142 #: 09408666 Category: 10	No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Richard S. Brown DMD 14 Concord Avenue Suite 203 Cambridge, MA 02138 #: 09405796 Category: D1	No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Rowland Institute at Harvard 100 Edwin H. Land Boulevard Cambridge, MA 02142 #: 09006099 Category: 10	No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Royal Sonesta Hotel 40 Edwin H Land Boulevard Cambridge, MA 02142 #: 09405160 Category: 10	No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	<b>-----CURRENT SAMPLING REQUIREMENTS-----</b>		<b>-----DISCHARGE VIOLATIONS-----</b>				<b>-----ENFORCEMENT ACTIONS-----</b>		
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>	
Russell L Forman DMD PC 875 Massachusetts Avenue Suite 63 Cambridge, MA 02139 #: 09405826 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions		
Sanofi Aventis US, Inc. 270 Albany Street Cambridge, MA 02139 #: 09103554 Category: 02	0101	<i>Sample port on the pH neutralization system discharge line</i>	No Discharge Violations				No Enforcement Actions		
	<b>Semi-Annual Self-Monitoring</b>								
		Copper (Total)							
		Formaldehyde							
		Mercury (Total)							
		Silver (Total)							
		TTO (Extractable Organic Fraction)							
		TTO (Volatile Organic Fraction)							
		Zinc (Total)							
		pH							
Sanofi Corporation 640 Memorial Drive Cambridge, MA 02139 #: 09403933 Category: 02	0101	<i>Spigots on discharge line</i>	No Discharge Violations				No Enforcement Actions		
	<b>Semi-Annual Self-Monitoring</b>								
		Chromium (Total)							
		Formaldehyde							
		Mercury (Total)							
		TTO (Extractable Organic Fraction)							
		TTO (Volatile Organic Fraction)							
		Zinc (Total)							
		pH							
Sanofi Pasteur Biologics 38 Sidney Street Floor 4 Cambridge, MA 02139 #: 09101547 Category: 02	0101	<i>Spigot(s) on the pH neutralization system discharge line</i>	No Discharge Violations				No Enforcement Actions		
	<b>Semi-Annual Self-Monitoring</b>								
		Copper (Total)							
		Formaldehyde							
		Mercury (Total)							
		Nickel (Total)							
		TTO (Extractable Organic Fraction)							
		TTO (Volatile Organic Fraction)							
		Zinc (Total)							
		pH							
Schlumberger Technology Corporation One Hampshire Street MD-A108 Cambridge, MA 02139 #: 09103590 Category: 02	0101	<i>Spigot on the pH neutralization system discharge line</i>	0101	<i>Spigot on the pH neutralization system discharge line</i>					No Enforcement Actions
	<b>Annual</b>	<b>Self-Monitoring</b>	22-Nov-2021	Zinc (Total)	2.9	mg/l	DYMx	< 1	
		Cadmium (Total)	29-Nov-2021	Zinc (Total)	4.2	mg/l	DYMx	< 1	
		Chromium (Total)	6-Dec-2021	Zinc (Total)	1.8	mg/l	DYMx	< 1	
		Copper (Total)	20-Dec-2021	Zinc (Total)	1.3	mg/l	DYMx	< 1	
		Lead (Total)	27-Dec-2021	Zinc (Total)	5.6	mg/l	DYMx	< 1	
		Mercury (Total)	7-Mar-2022	Zinc (Total)	2.7	mg/l	DYMx	< 1	
		Nickel (Total)							
		Selenium (Total)							
		Silver (Total)							
		Zinc (Total)							



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Scholar Rock Inc. 301 Binney Street Cambridge, MA 02142 #: 09408764 Category: 10		pH No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Seres Therapeutics 271 Cambridge Street Cambridge, MA 02141 #: 09409075 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sheraton Commander Hotel 16 Garden Street Cambridge, MA 02138 #: 09103492 Category: 02	0101	<i>WASHING MACHINE DISCHARGE LINE IN THE LAUNDRY ROOM</i>			No Discharge Violations		13-Sep-2021	Notice of Violation
	<b>Semi-Annual Self-Monitoring</b>	Oil and Grease pH						
Shire Human Genetic Therapies 205 Alewife Brook Parkway Cambridge, MA 02138 #: 09102452 Category: 02	0101	<i>STANDPIPE ON THE pH NEUTRALIZATION SYSTEM DISCHARGE LINE</i>			No Discharge Violations			No Enforcement Actions
	<b>Quarterly</b>	<b>Self-Monitoring</b> Chromium (Total) Copper (Total) Lead (Total) Mercury (Total) Nickel (Total) Oil and Grease TTO (Volatile Organic Fraction) Zinc (Total) pH						
Smile Line Dental Medicine 11 Binney Street Cambridge, MA 02142 #: 09407336 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Smithsonian Astrophysical Observatory 100 Acorn Park Drive Cambridge, MA 02140 #: 09103606 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Spaulding Hospital - Cambridge 1575 Cambridge Street Cambridge, MA 02138 #: 09007674 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Superior Nut Co., Inc. 225 Msgr. O'Brien Highway Cambridge, MA 02141 #: 09001997 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Takeda Pharmaceuticals U.S.A., Inc. 35 Landsdowne Street Cambridge, MA 02139 #: 09103014 Category: 02	0101	<i>SAMPLE PORT ON THE PH NEUTRALIZATION DISCHARGE LINE</i>			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Mercury (Total)						
		Nickel (Total)						
		Silver (Total)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Takeda Pharmaceuticals U.S.A., Inc. 40 Landsdowne Street Cambridge, MA 02139 #: 09103180 Category: 02	0101	<i>SPIGOT ON pH NEUT. SYS DISCHARGE LINE BEFORE WEIRBOX</i>			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Takeda Vaccines, Inc. 75 Sidney Street Cambridge, MA 02139 #: 09102278 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Telis Biosciences, Inc. 19 Blackstone Street Cambridge, MA 02139 #: 09409057 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
The Charles Hotel 1 Bennett Street Cambridge, MA 02138 #: 09007167 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
The Forsyth Institute 245 First Street Cambridge, MA 02142 #: 09403492 Category: 02	0101	<i>dental research wastewater discharged through the neutralization system</i>			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Mercury (Total)						
		TTO (Volatile Organic Fraction)						
		pH						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Torus Biosystems Inc. 125 Cambridgepark Drive Floor 5 Cambridge, MA 02140 #: 09408626 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ultimate Dental of Cambridge PC 2286 Massachusetts Avenue Cambridge, MA 02140 #: 09405809 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Vericel Corporation 64 Sidney Street Cambridge, MA 02139 #: 09007633 Category: 02	0101  Annual  0102  Annual  0103  Annual	Glassware Facilities Room 334  Self-Monitoring Copper (Total) Formaldehyde TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH  Sanitization Facilities Room 331  Self-Monitoring Copper (Total) Formaldehyde TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH  Limestone chiptank beneath sanitization room sink  Self-Monitoring Copper (Total) Formaldehyde TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH			No Discharge Violations			No Enforcement Actions
Vizgen, Inc. 61 Moulton Street Cambridge, MA 02138 #: 09408147 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Voyager Therapeutics 75 Sidney Street Floor 4 & 5 Cambridge, MA 02139 #: 09404290 Category: 02		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Walker Dental 60 Brattle Street Cambridge, MA 02138 #: 09405818 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Waters Corporation 301 Binney Street Suite 102A Cambridge, MA 02142 #: 09408589 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Wave Life Sciences 733 Concord Avenue Cambridge, MA 02138 #: 09403396 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Whitehead Institute for Biomedical Research 455 Main Street Cambridge, MA 02142 #: 09006332 Category: 02	0101  <b>Quarterly</b>	<i>pH neutralization system effluent line sample port</i>  <b>Self-Monitoring</b> Copper (Total) Cyanide (Total) Formaldehyde Mercury (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH			No Discharge Violations			No Enforcement Actions
AmericanBio, Inc. 20 Dan Road Canton, MA 02021 #: 10102671 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Anna Dalavurak DDS 779 Washington Street Canton, MA 02021 #: 10405836 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Armstrong Pharmaceuticals, Inc. 25 John Road Canton, MA 02021 #: 10103660 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Baohua Zhang DMD PC 8 Forge Pond Canton, MA 02021 #: 10405837 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Boyajian, Inc. 144 Will Drive Canton, MA 02021 #: 10405456 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Canton Dental Collaborative 726 Washington Street Canton, MA 02021 #: 10405835 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Canton Dental Group 608 Washington Street Canton, MA 02021 #: 10405832 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Canton Distributors CML Inc. 250 Dan Road Canton, MA 02021 #: 10404736 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Canton Family Dental 713 Washington Street Canton, MA 02021 #: 10405834 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Chemic Laboratories, Inc. 480 Neponset Street Building 7 Canton, MA 02021 #: 10405066 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Cobb Corner Endodontics PC 95 Washington Street Suite 482 Canton, MA 02021 #: 10405838 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
David F. Gaughan DDS 656 Chapman Street Canton, MA 02021 #: 10405833 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Del Monte Fresh Produce N.A., Inc. 105 Shawmut Road Canton, MA 02021 #: 10405429 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental Aid 1 95 Washington Street Suite 480 Canton, MA 02021 #: 10405839 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Draper Properties, Inc. 28 Draper Lane Canton, MA 02021 #: 10002472 Category: 02	0102	WASTEWATER FROM DYEING OF FIBERS			No Discharge Violations		03-May-2022 Notice of Violation	
	Quarterly	Self-Monitoring Oil and Grease pH						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Dream Smile Dental 2184 Washington Street Canton, MA 02021 #: 10405828 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dunkin Brands (Corporate Headquarters) 130 Royall Street Canton, MA 02021 #: 10405211 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Emergent BioSolutions, Inc. 50 Shawmut Road Canton, MA 02021 #: 10103255 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Emessa Dental Associates, P.C. 95 Washington Street Suite 472 Canton, MA 02021 #: 10409147 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Fresenius Kabi Compounding, LLC 20 Dan Road Canton, MA 02021 #: 10407655 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Homewood Suites by Hilton 50 Royall Street Canton, MA 02021 #: 10405320 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Ideal Instrument Co., Inc. 863 Washington Street Canton, MA 02021 #: 10002364 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Kindness Dental Center 1032 Turnpike Street Suite 203 Canton, MA 02021 #: 10407867 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lapuck Laboratories, Inc. 70 Shawmut Road Canton, MA 02021 #: 10005495 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Neponset River Valley Dental Center 510 Washington Street Canton, MA 02021 #: 10405831 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	<b>-----CURRENT SAMPLING REQUIREMENTS-----</b>		<b>-----DISCHARGE VIOLATIONS-----</b>				<b>-----ENFORCEMENT ACTIONS-----</b>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Organogenesis, Inc. 150 Dan Road Canton, MA 02021 #: 10007292 Category: 02	0101	Wastewater from cell culture operations			No Discharge Violations			No Enforcement Actions
	Quarterly	<b>Self-Monitoring</b> Formaldehyde Formaldehyde Mercury (Total) Mercury (Total) pH pH						
Organogenesis, Inc. 85 Dan Road Canton, MA 02021 #: 10403747 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Orthogon Therapeutics 960 Turnpike Street Unit 11 Canton, MA 02021 #: 10405477 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pecunit Street Water Treatment Facility 40 Carey Circle Canton, MA 02021 #: 10103692 Category: 02	0101	Backwash residuals sample port			No Discharge Violations			No Enforcement Actions
	Monthly	<b>Self-Monitoring</b> Total Suspended Solids Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Nickel (Total) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Podgurski Corporation 8 Springdale Avenue Canton, MA 02021 #: 10100401 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Robert Reiser & Co., Inc. 725 Dedham Street Canton, MA 02021 #: 10006496 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Saratoga Salad Dressing 5 Whitman Road Canton, MA 02021 #: 10403770 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Trillium Brewing Company 110 Shawmut Road Canton, MA 02021 #: 10405189 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	<b>-----CURRENT SAMPLING REQUIREMENTS-----</b>		<b>-----DISCHARGE VIOLATIONS-----</b>				<b>-----ENFORCEMENT ACTIONS-----</b>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Tufts Dental Facility at Pappas Rehabilitation Hosp. 3 Randolph Street Canton, MA 02021 #: 10405829 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
UL VS Canton, Inc. 85 John Road Canton, MA 02021 #: 10102647 Category: 02	0101	<i>Effluent from Microbiology and Chemistry Laboratories</i>	No Discharge Violations				No Enforcement Actions	
	<b>Semi-Annual Self-Monitoring</b>	TTO (Volatile Organic Fraction) pH						
	0102	<i>Effluent from the Physical Testing Laboratory</i>						
	<b>Annual</b>	<b>Self-Monitoring</b> Mercury (Total) Zinc (Total) pH						
A John's John 9 -R Sherman Street Charlestown, MA 02129 #: 47404182 Category: 06	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Accion Systems, Inc. 529 Main Street Suite 114 Charlestown, MA 02129 #: 47404707 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Eton Bioscience, Inc. 56 Roland Street Suite 306 Charlestown, MA 02129 #: 47403829 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Hood Park LLC and Lee Kennedy Co. Inc. 10 Stack Street Charlestown, MA 02129 #: 47407764 Category: 12	0101	<i>Sampling spigots on the final discharge pipe of the fractionation tank to M.H. #23</i>	No Discharge Violations				No Enforcement Actions	
	<b>Monthly</b>	<b>Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB/Pesticides Selenium (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
	0102	<i>Sampling spigots on the final discharge pipe of the fractionation tank to M.H. #28</i>						
	<b>Monthly</b>	<b>Self-Monitoring</b> Arsenic (Total)						



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Indigo, Inc. 500 Rutherford Avenue Charlestown, MA 02129 #: 47404765 Category: 02		Lead (Total) Mercury (Total) Oil and Grease PCB/Pesticides Selenium (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
	0101	Spigot after the pH neutralization tank			No Discharge Violations		14-Apr-2022	Notice of Violation
		<b>Semi-Annual Self-Monitoring</b>						
		Copper (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0201	Spigot after the pH neutralization tank						
		<b>Semi-Annual Self-Monitoring</b>						
		Copper (Total)						
	Formaldehyde							
	Lead (Total)							
	Mercury (Total)							
	Silver (Total)							
	TTO (Extractable Organic Fraction)							
	TTO (Volatile Organic Fraction)							
	Zinc (Total)							
	pH							
Jeffrey A Goldman DDS 1 Thompson Square Charlestown, MA 02129 #: 47405840 Category: D1	No Reporting Requirements			No Discharge Violations			No Enforcement Actions	
Louis W. Mian Incorporated 547 Rutherford Avenue Charlestown, MA 02129 #: 47002583 Category: 10	No Reporting Requirements			No Discharge Violations			No Enforcement Actions	
MGH Mass Biomedical Research Center 114 16th Street Charlestown, MA 02129 #: 47102651 Category: 02	0101	SAMPLING PORT AFTER NEUTRALIZATION			No Discharge Violations		No Enforcement Actions	
	<b>Quarterly</b>	<b>Self-Monitoring</b>						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
		Cyanide (Total) Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total) Zinc (Total) pH Formaldehyde TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction)						
Mama Rosie's Ravioli Co., Inc. 10 Dorrance Street Charlestown, MA 02129 #: 47102694 Category: G2	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Massachusetts General Hospital - CNY Building 75 75 Third Avenue Charlestown, MA 02129 #: 47103610 Category: 02	0101 <i>Sampling port after pH neutralization system</i>  <b>Semi-Annual Self-Monitoring</b>	Antimony (Total) Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH	0101 <i>Sampling port after pH neutralization system</i> 14-Jul-2021 Copper (Total) 1.3 mg/l 14-Jul-2021 Lead (Total) 0.84 mg/l 14-Jul-2021 Mercury (Total) 0.0011 mg/l 14-Jul-2021 Zinc (Total) 2.8 mg/l 12-Jan-2022 Copper (Total) 2.5 mg/l 12-Jan-2022 Lead (Total) 0.24 mg/l 3-May-2022 Copper (Total) 6.2 mg/l 3-May-2022 Zinc (Total) 1.9 mg/l 3-May-2022 Lead (Total) 0.65 mg/l		DYMX < 1 DYMX < 0.2 DYMX < 0.001 DYMX < 1 DYMX < 1 DYMX < 0.2 DYMX < 1 DYMX < 1 DYMX < 1 DYMX < 1		31-Aug-2021 Notice of Violation 01-Mar-2022 Notice of Noncompliance	
N.E.W. Health Charlestown 15 Tufts Street Charlestown, MA 02129 #: 47405841 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Robert J Esdale DDS 175 Main Street Charlestown, MA 02129 #: 47405843 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Spaulding Rehabilitation Hospital 300 First Avenue Charlestown, MA 02129 #: 47006021 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Spaulding Rehabilitation Hospital Corporation 96 Thirteenth Street Charlestown, MA 02129 #: 47404173 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Teamsterscare Dental Local 25 16 Sever Street Charlestown, MA 02129 #: 47405842 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Whittemore-Wright Co. 62 Alford Street Charlestown, MA 02129 #: 47002590 Category: 02	0101	SOAP MANUFACTURING WASTEWATER AFTER NEUTRALIZATION			No Discharge Violations		16-Nov-2021	Notice of Violation
	<b>Semi-Annual Self-Monitoring</b>	Oil and Grease pH						
Affordable Family Dental 59 Washington Avenue Chelsea, MA 02150 #: 11405851 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Alpha Dental Chelsea 778 Broadway Chelsea, MA 02150 #: 11407385 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Bellingham Square Family Dental PC 2 Washington Avenue Chelsea, MA 02150 #: 11407381 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Beth Israel Deaconess Healthcare-Chelsea 1000 Broadway Chelsea, MA 02150 #: 11101469 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Boston Hides & Fur, Ltd. 150 Marginal Street Chelsea, MA 02150 #: 11007678 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Broadway Family Dental 373 Broadway Chelsea, MA 02150 #: 11405850 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Chelsea Dental Associates 109 Washington Avenue Chelsea, MA 02150 #: 11405846 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Chelsea Pediatric Dentistry 950 Broadway Unit 1C Chelsea, MA 02150 #: 11407387 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Cortland Dental & Braces _Chelsea Facility 1096 Revere Beach Parkway Chelsea, MA 02150 #: 11405847 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Cutone Specialty Foods Inc. 145 Market Street Chelsea, MA 02150 #: 11101795 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dr. Jeyasri Gunarajasingam 61 Everett Avenue Chelsea, MA 02150 #: 11405852 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dr. Jeyasri Gunarajasingam 100 Everett Avenue Unit 5 Chelsea, MA 02150 #: 11407377 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Family Dental Care 357 Broadway Chelsea, MA 02150 #: 11405849 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Garden Fresh Salad Co. Inc. 17 New England Produce Center Bay 11-20 Chelsea, MA 02150 #: 11000838 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Golden Cannoli Shells Company 99 Crescent Avenue Chelsea, MA 02150 #: 11007114 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Holden Fruit & Produce, Inc. 1 Griffin Way Chelsea, MA 02150 #: 11407872 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Holiday Inn - Boston Logan Airport 1012 Broadway Chelsea, MA 02150 #: 11408322 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Inspectorate America Corporation 2 Williams Street Chelsea, MA 02150 #: 11101112 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
JSB Industries Inc. dba Muffin Town 130 Crescent Avenue Chelsea, MA 02150 #: 11103153 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lang's Dental Center 110 Park Street Chelsea, MA 02150 #: 11407379 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
MGH Chelsea Health Center 151 Everett Avenue Chelsea, MA 02150 #: 11101531 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Mystic Dental Studio 158 Everett Avenue Unit 5 Chelsea, MA 02150 #: 11407462 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Peter Condakes Co., Inc. 74 -77 New England Produce Center Chelsea, MA 02150 #: 11000828 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Peter Pan Bus Lines 333 Third Street Chelsea, MA 02150 #: 11103361 Category: 02	0102	<i>Spigot(s) on the discharge line of the 2500 gallon storage tank</i>			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Oil and Grease						
		Zinc (Total)						
		pH						
RM Biltrite 31 Highland Street Chelsea, MA 02150 #: 11006728 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Residence Inn by Marriott_Boston Logan Airport 200 Maple Street Chelsea, MA 02150 #: 11403900 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Signature Breads, Inc. 100 Justin Drive Chelsea, MA 02150 #: 11102627 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Summit Press, Inc. 240 Arlington Street Chelsea, MA 02150 #: 11000523 Category: G1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Trans Dental Care Inc. 242 Everett Avenue Chelsea, MA 02150 #: 11405848 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Aim Dental, P.C. 19 High Street Clinton, MA 01020 #: 57407410 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Clinton Hospital 201 Highland Street Clinton, MA 01510 #: 57101963 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dunn & Company 75 Green Street Clinton, MA 01510-0968 #: 57101034 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Immediate Dental 127 High Street Clinton, MA 01510 #: 57407409 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Liberty Compassion Center, Inc. 179 Brook Street Clinton, MA 01510 #: 57408176 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
New England Harvest 89 Parker Street Clinton, MA 01510 #: 57409351 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Simply Pediatric Dentistry and Orthodontics 200 High Street Clinton, MA 01510 #: 57407411 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Society Cannabis Co. 470 Main Street Clinton, MA 01510 #: 57409022 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sterling Street Brewery 175 Sterling Street Clinton, MA 01510 #: 57409352 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
TRAC TEST INDUSTRY 2 Griffin Way Chelsea, MA 02150 #: 99999999 Category: 06	0101	Primary Sample Location			No Discharge Violations			No Enforcement Actions
	Annual	Self-Monitoring Mercury (Total) Oil and Grease pH						
Town of Clinton DPW, Clinton Water Treatment Fac. 55 West Boylston Street Clinton, MA 01510 #: 57103331 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Tyca Corporation 470 Main Street Clinton, MA 01510 #: 57101499 Category: 02	0101	Apparel washing and dyeing operations			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Chromium (Total) Copper (Total) Zinc (Total) pH						
Advanced Oakdale Dental 244 River Street Dedham, MA 02026 #: 12407417 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
American Red Cross Blood Services - New England 180 Rustcraft Road Dedham, MA 02026 #: 12100250 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Aspen Dental 162 Providence Highway Dedham, MA 02026 #: 12405863 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Atrius Health dba Dedham Medical Associates 1 Lyons Street Dedham, MA 02026 #: 12102794 Category: 10	No Reporting Requirements				No Discharge Violations		No Enforcement Actions	
BioLegend, Inc. 210 Rustcraft Road 140 Dedham, MA 02026 #: 12101320 Category: 10	No Reporting Requirements				No Discharge Violations		No Enforcement Actions	
Costco Wholesale Corp. dba Costco Wholesale #319 200 Legacy Boulevard Dedham, MA 02026 #: 12102031 Category: G1	No Reporting Requirements				No Discharge Violations		No Enforcement Actions	
Dedham Dental Associates 888 Washington Street Suite 306 Dedham, MA 02026 #: 12405872 Category: D1	No Reporting Requirements				No Discharge Violations		No Enforcement Actions	
Dedham Dental Group 15 Bryant Street Dedham, MA 02026 #: 12405862 Category: D1	No Reporting Requirements				No Discharge Violations		No Enforcement Actions	
Dedham Dentist 110 Bridge Street Dedham, MA 02026 #: 12405861 Category: D1	No Reporting Requirements				No Discharge Violations		No Enforcement Actions	
Dedham Family Dental Care 395 Washington Street Dedham, MA 02026 #: 12405870 Category: D1	No Reporting Requirements				No Discharge Violations		No Enforcement Actions	
Dedham/Westwood Water District (Bridge Street WTP) 536 Bridge Street Dedham, MA 02026 #: 12007016 Category: 02	0101  <b>Monthly</b>	<i>SPIGOT ON PVC BACKWASH DISCHARGE LINE</i>  <b>Self-Monitoring</b> Total Suspended Solids pH Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Lead (Total) Nickel (Total) Zinc (Total)			No Discharge Violations		No Enforcement Actions	



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Dental Park 211 High Street Dedham, MA 02026 #: 12405865 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Specialties 245 Washington Street Dedham, MA 02026 #: 12405866 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr. Anna Vishart Digital Dental 418 Washington Street Dedham, MA 02026 #: 12407422 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Endodontic Care PC 5 School Street Dedham, MA 02026 #: 12405871 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Fairfield Inn by Marriott Boston Dedham 235 Elm Street Dedham, MA 02026 #: 12007169 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gauri Patil DMD PC 380 High Street Dedham, MA 02026 #: 12405869 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Island Hospitality Management III LLC dba Residence Inn Dedh 259 Elm Street Dedham, MA 02026 #: 12103690 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
John J Fiore DMD 19 Needham Street Dedham, MA 02026 #: 12405864 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Moderna Inc. 210 Rustcraft Road Dedham, MA 02026 #: 12408653 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
New England Baptist Outpatient Care Center 40 Allied Drive Dedham, MA 02026 #: 12403947 Category: 02	0101 Quarterly	Discharge from the operating room Central Supply Operation Self-Monitoring Copper (Total) Formaldehyde pH			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
P-LR-5A, LP (dba) Hilton Dedham 25 Allied Drive Dedham, MA 02026 #: 12100007 Category: 10	No Reporting Requirements	TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction)			No Discharge Violations			No Enforcement Actions
Smile Design Dental Team of Dedham 347 Washington Street Suite 302 Dedham, MA 02026 #: 12407869 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Spire Hospitality LLC dba Holiday Inn Dedham 55 Ariadne Road Dedham, MA 02026 #: 12006066 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Vargas Family Dentistry 263 Washington Street Dedham, MA 02026 #: 12405867 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
ATS Equipment Inc. 33 Locust Street Dorchester, MA 02125 #: 48103356 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Adams Dental Care 253 Adams Street Dorchester, MA 02122 #: 48405885 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Apollo Dental Associates 940 Dorchester Avenue Dorchester, MA 02122 #: 48407449 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
BCP BEAT Property LLC 135 Morrissey Boulevard Dorchester, MA 02125 #: 48409372 Category: 02	0101  Semi-Annual Self-Monitoring	<i>Spigot on the discharge line after the pH neutralization system</i>  Copper (Total) Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Beacon Dental Group 1026 Blue Hill Avenue Dorchester, MA 02124 #: 48405874 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Codman Square Health Center, Inc. 637 Washington Street Dorchester, MA 02124 #: 48102354 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
CommonWealth Kitchen 196 Quincy Street Dorchester, MA 02121 #: 48404925 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Commonwealth Zoological Corporation dba Zoo New England 1 Franklin Park Road Dorchester, MA 02121 #: 48103571 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Cummins Family Dental 1100 Washington Street Suite 208 Dorchester, MA 02124 #: 48407424 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dentonic dba Franklin Park Family Dental 614 B Blue Hill Avenue Suite B Dorchester, MA 02121 #: 48407441 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Diamond Windows & Doors Mfg. 99 E Cottage Street Dorchester, MA 02125 #: 48103253 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dorchester Beer Holdings LLC 1250 Massachusetts Avenue Dorchester, MA 02125 #: 48404650 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dorchester Dental 1370 Dorchester Avenue Unit 32 - 34 Dorchester, MA 02122 #: 48407427 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
DotHouse Health, Inc. 1353 Dorchester Avenue Dorchester, MA 02122 #: 48102474 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Dr. Malkemus Inc. 166 Columbia Road Dorchester, MA 02122 #: 48407430 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Emmerson Animal Hospital, Inc. 255 Freeport Street Dorchester, MA 02122 #: 48103157 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Family Dental Care of Dorchester 1444 Dorchester Avenue Dorchester, MA 02122 #: 48405878 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Family Dentistry 1470 Dorchester Avenue Dorchester, MA 02122 #: 48407605 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Folan Family Dental 540 Gallivan Boulevard Suite 203 Dorchester, MA 02124 #: 48409209 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Geiger Gibson Community Health Center 250 Mt Vernon Street Dorchester, MA 02125 #: 48405884 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Han M. Le DMD PC 1510 Dorchester Avenue Dorchester, MA 02111 #: 48405880 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Harvard St Neighborhood Health Center 632 Blue Hill Avenue Dorchester, MA 02121 #: 48405888 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Holiday Inn Express Boston 69 -R Boston Street Dorchester, MA 02125 #: 48103562 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lee Family Dentistry 383 Neponset Avenue Dorchester, MA 02122 #: 48405887 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
M. F. Foley Co. 24 W Howell Street Dorchester, MA 02125 #: 48003371 Category: G2		No Reporting Requirements						No Enforcement Actions
Mark N Dailey DMD 2260 Dorchester Avenue Dorchester, MA 02124 #: 48405883 Category: D1		No Reporting Requirements						No Enforcement Actions
Metropolitan Dental Center 1417 Dorchester Avenue Dorchester, MA 02122 #: 48405877 Category: D1		No Reporting Requirements						No Enforcement Actions
Michael J Masse DDS 212 Ashmont Street Dorchester, MA 02124 #: 48405882 Category: D1		No Reporting Requirements						No Enforcement Actions
NSTAR Electric Company, dba Eversource Energy 120 East Cottage Street Dorchester, MA 02125 #: 48102159 Category: 02	0101	<i>VEHICLE WASHING EFFLUENT AT MANHOLE AFTER SEPARATOR</i>	0101	<i>VEHICLE WASHING EFFLUENT AT MANHOLE AFTER SEPARATOR</i>			08-Jun-2022	Notice of Violation
		<b>Semi-Annual Self-Monitoring</b> Lead (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH	24-May-2022	Zinc (Total)	1.12	mg/l DYMx < 1		
Nhung Thi Tran DMD PC 850 Dorchester Avenue Dorchester, MA 02125 #: 48405892 Category: D1		No Reporting Requirements						No Enforcement Actions
Ramada Inn Boston 800 Morrissey Boulevard Dorchester, MA 02122 #: 48103706 Category: 10		No Reporting Requirements						No Enforcement Actions
Robert R. Perry, Jr. DMD PC 256 Ashmont Street Dorchester, MA 02124 #: 48405886 Category: D1		No Reporting Requirements						No Enforcement Actions
Sparkle Dental 97 Neponset Avenue Dorchester, MA 02122 #: 48405893 Category: D1		No Reporting Requirements						No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Steward Carney Hospital, Inc. 2100 Dorchester Avenue Dorchester, MA 02124-5666 #: 48103066 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
The Braces Place and T-Station Dental 1792 Dorchester Avenue Dorchester, MA 02124 #: 48407939 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Uphams Corner Health Center 636 Columbia Road Dorchester, MA 02125 #: 48405889 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
AP Dental & Laser Center 231 Border Street East Boston, MA 02128 #: 49407459 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
American Airlines, Inc. Logan International Airport Terminal B East Boston, MA 02128 #: 49003535 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Central Square Smiles, P.C. 38 Central Square Unit 1 East Boston, MA 02128 #: 49407463 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Channel Fish Company 370 East Eagle Street East Boston, MA 02128 #: 49003550 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Courtyard Marriott 225 McClellan Highway East Boston, MA 02128 #: 49103563 Category: 02	0101 Laundry effluent from common line				No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b> Mercury (Total) Oil and Grease pH							
Delta Air Lines, Inc. 100 Terminal A East Boston, MA 02128 #: 49003562 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Downeast Cider House, LLC 256 Marginal Street East Boston, MA 02128 #: 49404180 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
East Boston Dental and Orthodontics PC 999 Saratoga Street East Boston, MA 02128 #: 49405902 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
East Boston Neighborhood Health Center EPNHC 20 Maverick Square East Boston, MA 02128 #: 49407461 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Embassy Suites Boston at Logan Airport 207 Porter Street East Boston, MA 02128 #: 49406355 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gate Gourmet 21 Lovell Street East Boston, MA 02128 #: 49003616 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hilton Boston Logan Airport One Hotel Drive East Boston, MA 02128 #: 49405020 Category: 02	0101 Laundry wastewater discharge.				No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b> Mercury (Total) Oil and Grease Zinc (Total) pH							
Hyatt Corporation - as agent for Lasalle Hotel Lessee 101 Harborside Drive East Boston, MA 02128 #: 49103104 Category: 10	No Reporting Requirements				No Discharge Violations			20-Aug-2021 Notice of Violation 10-Feb-2022 Notice of Violation
Julia Faigel, DDS 55 Meridian Street East Boston, MA 02128 #: 49407470 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
LSG/Skychefs 25 Lovell Street East Boston, MA 02128 #: 49102144 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Liliana DiFabio DMD 56 Bennington Street East Boston, MA 02128 #: 49405900 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Massachusetts Port Authority 1 Harborside Drive Suite 200S East Boston, MA 02128 #: 49102434 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Maverick Family Dental PC 45 Maverick Square East Boston, MA 02128 #: 49405898 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
My Dental - East Boston 151 Meridian Street East Boston, MA 02128 #: 49407457 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Orient Heights Chiropractic 1214 Bennington Street East Boston, MA 02128 #: 49102309 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Wanda L. Irzykowski DMD 19 Porter Street East Boston, MA 02128 #: 49405895 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
All Care Dental of Everett 80 Chelsea Street Everett, MA 02149 #: 13405913 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Amazon.com Services LLC 201 Beacham Street Everett, MA 02149 #: 13404876 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Aquanor Marketing, Inc. 210 Beacham Street Everett, MA 02149 #: 13102994 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Bearmoose Brewing Company, Inc. 1934 Revere Beach Parkway Everett, MA 02149 #: 13406920 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Bone Up Brewing Company, LLC 38 Norman Street Everett, MA 02149 #: 13404713 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Bostonean Marble & Granite 151 Bow Street Everett, MA 02149 #: 13405043 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Broadway Dentists LLC 609 Broadway Everett, MA 02149 #: 13405912 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Buenas LLC 189 Elm Street Everett, MA 02149 #: 13407551 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Chicken & Rice Guys 77 Ferry Street Everett, MA 02149 #: 13406598 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Colonial Marble Company, Inc. 25 Garvey Street Everett, MA 02149 #: 13000049 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
DPV Transportation, Inc. 383 Second Street Everett, MA 02149 #: 13408000 Category: 02	0101	<i>Y-connection clean-out before gas/oil separator</i>			No Discharge Violations		26-Jul-2021 Notice of Violation	
	<b>Semi-Annual Self-Monitoring</b>							
		Chromium (Total)						
		Copper (Total)						
		Lead (Total)						
		Nickel (Total)						
		Oil and Grease						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Everett Dental Associates 345 Main Street Everett, MA 02149 #: 13405907 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Everett Dental Center 95 Main Street Everett, MA 02149 #: 13405916 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Everett Dental Wellness 826 Broadway Everett, MA 02149 #: 13405914 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Everett Family Dental 459 Broadway Unit 1 Everett, MA 02149 #: 13407873 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Everett Smiles Pediatric Dentistry & Orthodontics 11 Victoria Street Everett, MA 02149 #: 13409420 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
GK Dental PC 505 Broadway Everett, MA 02149 #: 13405908 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Garden Fresh Salad Company, Inc. 304 Second Street Everett, MA 02149 #: 13407413 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Global Dental 439 Broadway Everett, MA 02149 #: 13407480 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Great Smiles Dental 285 Main Street Everett, MA 02149 #: 13407479 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
H.P. Cookie Company 56 Garden Street Everett, MA 02149 #: 13101801 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Night Shift Brewing, Inc. 87 Santilli Highway Everett, MA 02149 #: 13404507 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Peter A Capodilupo DDS 563 Broadway Suite 21 Everett, MA 02149 #: 13405910 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Phuong Dao DDS 910 Broadway Everett, MA 02149 #: 13405915 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Richie's King of Slush Mfg. Co. 3 Garvey Street Everett, MA 02149 #: 13404651 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Samuel Holmes Inc. 56 Garden Street Everett, MA 02149 #: 13102996 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Short Path Distillery, Inc. 71 Kelvin Street Unit 2 Everett, MA 02149 #: 13404611 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Signs 2 Go 4 Inc. 670 Broadway Everett, MA 02149 #: 13407720 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Universal Screening Studio, Inc. 175 Ferry Street Everett, MA 02149 #: 13101165 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Above & Beyond Teeth 186 Union Avenue Unit G Framingham, MA 01702 #: 14407489 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Atlantis Dental Center 118 Concord Street Framingham, MA 01702 #: 14405919 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Bose Corporation One New York Avenue Framingham, MA 01701 #: 14101633 Category: 02	0101	<i>Spigot on the 300-gallon discharge tank in the cone manufacturing room</i>			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>	Copper (Total) pH						
	0201	<i>Spigot on the discharge pipe from 3D printer water jet washing</i>						
	<b>Annual</b>	<b>Self-Monitoring</b> pH						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
C & Z Dental of Framingham 463 Worcester Road Suite 102 Framingham, MA 01701 #: 14405946 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
City of Framingham Landfill 200 Crossing Boulevard Framingham, MA 01702 #: 14102700 Category: 02	0101	<i>Sump in the leachate pumping station</i>			No Discharge Violations			No Enforcement Actions
	<b>Quarterly</b>	<b>Self-Monitoring</b> Antimony (Total) Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total) Thallium (Total) Zinc (Total) pH						
Comfort Dental of Framingham 223 Walnut Street Suite 3 Framingham, MA 01702 #: 14405928 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Concord Dental of Framingham 32 Concord Street Framingham, MA 01702 #: 14407493 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Specialty Partners 405 Cochituate Road Suite 304 Framingham, MA 01701 #: 14405941 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dentplant 100 Concord Street Suite 1E Framingham, MA 01702 #: 14405917 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr Meera Ohri & Associates 463 Worcester Road Suite 404 Framingham, MA 01701 #: 14405945 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr. Neide Coutinho & Associates, P.C. 435 Union Avenue Framingham, MA 01702 #: 14407878 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Elevation Brands 190 Fountain Street Framingham, MA 01702 #: 14403361 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Endodontic Associates in Framingham PC 235 Walnut Street Framingham, MA 01702 #: 14405931 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Exhibit 'A' Brewing Company, Inc. 81 Morton Street Framingham, MA 01702 #: 14404865 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
FMC - Framingham 110 Mount Wayte Avenue Framingham, MA 01702 #: 14404617 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Framingham Animal Hospital 1415 Edgell Road Framingham, MA 01701 #: 14102253 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Framingham Dental Arts Condominium Trust 55 Main Street Framingham, MA 01701 #: 14407875 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Framingham Dental Care 661 Franklin Street Framingham, MA 01702 #: 14405955 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Framingham Dental Center 1283 Old Worcester Road Framingham, MA 01701 #: 14405920 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Framingham Dental Group 1671 Worcester Road Suite 103 Framingham, MA 01701 #: 14405926 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Framingham Family Dental 130 Maynard Road Framingham, MA 01701 #: 14405921 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Framingham Family Dental Care 434 Old Connecticut Path Framingham, MA 01701 #: 14405942 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Framingham State University 100 State Street Framingham, MA 01701 #: 14102219 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Grace Dental 55 Main Street Framingham, MA 01702 #: 14405948 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
ICL Imaging 51 Mellen Street Framingham, MA 01702 #: 14002107 Category: G1	0101 PHOTO	Self-Monitoring Silver (Total)			No Discharge Violations			No Enforcement Actions
JNL Family Dental Office 270 Concord Street Suite 1 Framingham, MA 01702 #: 14407157 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Jack's Abby Brewing 100 Clinton Street Framingham, MA 01702 #: 14404631 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Joan Petracca DMD 60 Lexington Street Framingham, MA 01702 #: 14405951 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lulu Dental, P.C. dba Chang Dental Group Framingham 1671 Worcester Road Suite 401 Framingham, MA 01701 #: 14407874 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
MCI Framingham 99 Loring Drive Framingham, MA 01701 #: 14405959 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
MCR Labs, LLC 85 Speen Street LL Framingham, MA 01701 #: 14406800 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Marilyn Rivero DMD 235 Walnut Street Unit 2 Framingham, MA 01702 #: 14405932 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Mark Fried DMD PC 61 Edgell Road Framingham, MA 01701 #: 14405952 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Metrowest Prosthodontics 661 Franklin Street Floor 2 Framingham, MA 01701 #: 14407504 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Michael A Ayik DDS 1310 Old Worcester Road Framingham, MA 01701 #: 14405922 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Nelson J Huang Family Dental 61 Lincoln Street Suite 202 Framingham, MA 01702 #: 14405953 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Nobscot Dental Care 231 Worcester Road Framingham, MA 01701 #: 14407491 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
OCP LLC 500 Old Connecticut Path Framingham, MA 01701 #: 14101100 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Orris Dental 233 Cochrane Road Framingham, MA 01701 #: 14407492 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Paul J Hubley, DMD 223 Walnut Street Suite 6 Framingham, MA 01702 #: 14407507 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Peter C Morris DDS 400 Union Avenue Framingham, MA 01702 #: 14405939 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Replimune, Inc. 33 New York Avenue Framingham, MA 01701 #: 14407981 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Robert A Kelly DDS 434 Old Connecticut Path Suite 2A Framingham, MA 01701 #: 14405943 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sanofi 1 & 5 Mountain Road Framingham, MA 01701 #: 14006783 Category: 02	0101	<i>Spigot on the discharge line of the pH neutralization system at 1 Mountain Road</i>			No Discharge Violations		08-Jul-2021	Notice of Violation
	<b>Annual</b>	<b>Self-Monitoring</b> Formaldehyde TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Copper (Total) Mercury (Total) Silver (Total) Zinc (Total) pH						
	0201	<i>Spigot on the discharge line of the pH neutralization system at 5 Mountain Road</i>						
	<b>Annual</b>	<b>Self-Monitoring</b> Formaldehyde TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Copper (Total) Mercury (Total) Silver (Total) pH						
Sanofi 78 New York Avenue Framingham, MA 01701 #: 14103222 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sanofi - Genzyme 51 New York Avenue Framingham, MA 01701 #: 14006351 Category: 02	0102	<i>Spigot on discharge line of neutralization system</i>			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual</b>	<b>Self-Monitoring</b> Biochemical Oxygen Demand (5 Day) Sulfate pH						
	0104	<i>Passivation wastewater</i>						
	<b>Annual</b>	<b>Self-Monitoring</b> Chromium (Total) Nickel (Total) Oil and Grease Zinc (Total)						



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Sanofi - Genzyme 31 New York Avenue Framingham, MA 01701 #: 14101558 Category: 02	0101	<i>Spigot on neutralization system discharge line</i>	0101	<i>Spigot on neutralization system discharge line</i>			24-Feb-2022	Notice of Violation
	<b>Semi-Annual Self-Monitoring</b>	pH Copper (Total) Mercury (Total) Silver (Total) Zinc (Total) pH	10-Feb-2022	Zinc (Total)	2.51	mg/l DYMX < 1		
Sanofi - Genzyme 49 & 55 New York Avenue Framingham, MA 01701 #: 14103408 Category: 02	0101	<i>Spigot on discharge line of neutralization system</i>						No Discharge Violations  No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>	Biochemical Oxygen Demand (5 Day) Copper (Total) Formaldehyde Mercury (Total) Silver (Total) TTO (Extractable Organic Fraction) Zinc (Total) pH						
Sanofi-Genzyme 45 New York Avenue Framingham, MA 01701 #: 14101556 Category: 02	0201	<i>Spigot on the discharge line after the neutralization system</i>						No Discharge Violations  No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>	Biochemical Oxygen Demand (5 Day) Chromium (Total) Copper (Total) Mercury (Total) Nickel (Total) Silver (Total) Sulfate Zinc (Total) pH						
Sanofi-Genzyme 8 New York Avenue Framingham, MA 01701 #: 14404408 Category: 02	0101	<i>Wastewater from the Integrated Continuous Bio-manufacturing Facility</i>						No Discharge Violations  No Enforcement Actions
	<b>Quarterly Self-Monitoring</b>	Biochemical Oxygen Demand (5 Day) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids Zinc (Total) pH Biochemical Oxygen Demand (5 Day) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids Zinc (Total) pH						
	0102	<i>Passivation wastewater</i>						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Sarah Lecerf DMD 61 Lincoln Street Suite 114 Framingham, MA 01702 #: 14405954 Category: D1	Annual	Self-Monitoring Chromium (Total) Nickel (Total) pH	No Reporting Requirements	No Discharge Violations				No Enforcement Actions
Sawan & Sawan Family Dental 2 Irving Street Framingham, MA 01701 #: 14407490 Category: D1			No Reporting Requirements	No Discharge Violations				No Enforcement Actions
Smilage Dental Center 463 Worcester Road Suite 201 Framingham, MA 01701 #: 14407876 Category: D1			No Reporting Requirements	No Discharge Violations				No Enforcement Actions
South Middlesex Correctional Center 135 Western Avenue Framingham, MA 01701 #: 14405924 Category: D1			No Reporting Requirements	No Discharge Violations				No Enforcement Actions
Speen Family Dental 689 Cochituate Road Framingham, MA 01701 #: 14407506 Category: D1			No Reporting Requirements	No Discharge Violations				No Enforcement Actions
Star Smile 377 Union Avenue Framingham, MA 01702 #: 14405937 Category: D1			No Reporting Requirements	No Discharge Violations				No Enforcement Actions
The Braces Place of Framingham 509 Concord Street Framingham, MA 01701 #: 14407494 Category: D1			No Reporting Requirements	No Discharge Violations				No Enforcement Actions
The Dentist at Framingham 116 Cochituate Road Framingham, MA 01701 #: 14405918 Category: D1			No Reporting Requirements	No Discharge Violations				No Enforcement Actions
The Pediatric Dental Group 297 Union Avenue Framingham, MA 01702 #: 14405935 Category: D1			No Reporting Requirements	No Discharge Violations				No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Union Ave Dental 383 Union Avenue Framingham, MA 01702 #: 14405938 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Unique Dental of Framingham 130 Maynard Road Framingham, MA 01701 #: 14407488 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Walnut Dental Group 235 Walnut Street Suite 1 Framingham, MA 01702 #: 14405933 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Anderson Dentistry 190 Lincoln Street Hingham, MA 02043 #: 15405964 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dr. Jeffrey Darling DMD 22 Central Street Hingham, MA 02043 #: 15405967 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Evergrin Dental 400 Lincoln Street Suite 21 Hingham, MA 02043 #: 15405970 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hingham Dental Associates 20 Downer Avenue Suite 2 Hingham, MA 02043 #: 15405965 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hingham Dentistry 169 Lincoln Street Suite 101 Hingham, MA 02043 #: 15405962 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hingham Shipyard Family Dental PLLC 350 Lincoln Street Suite 1106 Hingham, MA 02043 #: 15407525 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Linden Ponds at Hingham Dental Office 300 Linden Ponds Way Hingham, MA 02043 #: 15405968 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Myra J Brennan DMD PC 24 Shipyard Drive Suite 203 Hingham, MA 02043 #: 15409315 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
South Shore Prosthodontics 210 Whiting Street Unit 1 Hingham, MA 02043 #: 15405966 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Surfside Dental Studio PLLC 344 Rockland Street Hingham, MA 02043 #: 15405969 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
TGE Associates 312 High Street Hingham, MA 02043 #: 15407524 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Brookville Dental Associates 838 South Franklin Street Holbrook, MA 02343 #: 16405973 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Mica-Tron Products Corporation 275 Centre Street Unit 13 Holbrook, MA 02343 #: 16000678 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Pearl Dental Associates 175 N Franklin Street Holbrook, MA 02343 #: 16407530 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
South Shore Dental Care 169 N. Franklin Street Holbrook, MA 02343 #: 16407529 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Ace Dental Boston 1138 River Street Hyde Park, MA 02136 #: 50405974 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Aerogel Technologies, LLC 1 Westinghouse Plaza D157 Hyde Park, MA 02136 #: 50404349 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Armin Dental Associates 1234 Hyde Park Avenue Suite 201 Hyde Park, MA 02136 #: 50405977 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Bankhead & Groipen 1259 Hyde Park Avenue Suite 102 Hyde Park, MA 02136 #: 50405978 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Boston Baking, Inc. 101 Sprague Street Hyde Park, MA 02136 #: 50407722 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Chadda Family Dental 1234 Hyde Park Avenue Suite 103 Hyde Park, MA 02136 #: 50405976 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
My Grandma's of New England 1636 Hyde Park Avenue Hyde Park, MA 02136 #: 50102652 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Orleans Packing Company 1715 Hyde Park Avenue Hyde Park, MA 02136 #: 50102607 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Perfect Dental Hyde Park 912 River Street Hyde Park, MA 02136 #: 50405979 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Roundhead Brewing, LLC 1 Westinghouse Plaza Suite I-107 Hyde Park, MA 02136 #: 50409398 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
U Smile PC 1250 Hyde Park Avenue Hyde Park, MA 02136 #: 50407538 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
21st Century Foods, Inc. 30 -A Germania Street Jamaica Plain, MA 02130 #: 51103685 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Brookside CHC Dental Dept. 3297 Washington Street Jamaica Plain, MA 02130 #: 51405982 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Caring Family Dental 594 Center Street Jamaica Plain, MA 02130 #: 51405987 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Fresh City 31 Germania Street Building J Jamaica Plain, MA 02130 #: 51103683 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gentle Dental Jamaica Plain 612 Centre Street Jamaica Plain, MA 02130 #: 51405988 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
JP Family Dental 315 Centre Street Jamaica Plain, MA 02130 #: 51405981 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lemuel Shattuck Hospital 170 Morton Street Jamaica Plain, MA 02130 #: 51005748 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lemuel Shattuck Hospital 170 Morton Street Jamaica Plain, MA 02130 #: 51407701 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lenox-Martell, Inc. 89 Heath Street Jamaica Plain, MA 02130 #: 51101142 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Linens by Alice 18 Brookley Road Jamaica Plain, MA 02130 #: 51404602 Category: 02	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
MSPCA Angell 350 South Huntington Avenue Jamaica Plain, MA 02130 #: 51103140 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	<b>-----CURRENT SAMPLING REQUIREMENTS-----</b>		<b>-----DISCHARGE VIOLATIONS-----</b>				<b>-----ENFORCEMENT ACTIONS-----</b>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Perfect Dental Jamaica Plain 225 Centre Street Jamaica Plain, MA 02119 #: 51407543 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pondside Dental Associates 793 Centre Street Jamaica Plain, MA 02130 #: 51405991 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Pure Dental 3531 Washington Street Suite 102 Jamaica Plain, MA 02130 #: 51405989 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Red Sun Press, Inc. 94 Green Street Jamaica Plain, MA 02136 #: 51007059 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
The Boston Beer Company 30 Germania Street Jamaica Plain, MA 02130 #: 51007379 Category: 02	0101	<i>Spigot on discharge line after pH neutralization</i>			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>	pH						
Turtle Swamp Brewing LLC 3377 3379 Washington Street Jamaica Plain, MA 02130 #: 51404747 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
VA Boston Health Care System Dental 150 South Huntington Avenue Jamaica Plain, MA 02130 #: 51405980 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Washington Pine LLC and Cranshaw Construction 3368 Washington Street Jamaica Plain, MA 02130 #: 51409219 Category: 12	0101	<i>BWSC catch basin #218 located at the northern corner of 3368 Washington St.</i>			No Discharge Violations			No Enforcement Actions
	<b>Monthly</b>	<b>Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
	0102	<i>BWSC catch basin #15 located at the southern corner of 3368 Washington St.</i>						

## Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
	Monthly	<b>Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
Atlantic Union College 338 Main Street Lancaster, MA 01523 #: 58007005 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Bob's Turkey Farm, Inc. 181 Old Common Road Lancaster, MA 01523 #: 58101498 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
DaVinci Biomedical Research Products, Inc. 40 Maple Street Lancaster, MA 01561 #: 58103102 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lancaster Dental PC 136 High Street Extension Lancaster, MA 01523 #: 58405992 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Mossmann Family Dental, PC 240 Main Street South Lancaster, MA 01561 #: 58406290 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Nashaway Dental Group PC 131 Main Street South Lancaster, MA 01561 #: 58406289 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Theodore R. Nelson, DDS 387 Sterling Street Lancaster, MA 01523 #: 58407557 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Agenus, Inc. 3 Forbes Road Lexington, MA 02421 #: 17103198 Category: 02	0101	Spigot(s) on the discharge line after pH neutralization			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b> Chromium (Total)						



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Beth Israel/Children's Hospital Medical Care Ctr. 482 Bedford Street Lexington, MA 02420 #: 17101147 Category: 10	No Reporting Requirements	Mercury (Total) Nickel (Total) TTO (Volatile Organic Fraction) pH						No Enforcement Actions
Boston Bioskills Lab LLC 1 Hartwell Place Suite 103 Lexington, MA 02421 #: 17404936 Category: 10	No Reporting Requirements							No Enforcement Actions
Boston Family Dental 16 Clarke Street Suite 14 Lexington, MA 02421 #: 17407561 Category: D1	No Reporting Requirements							No Enforcement Actions
Brammer Bio, LLC 45 Hartwell Avenue Lexington, MA 02421 #: 17407849 Category: 02	0101	<i>spigot(s) located on discharge line of pH neutralization system</i>						No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b> Copper (Total) Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
CBSET, Inc. 500 Shire Way Lexington, MA 02421 #: 17103485 Category: 10	No Reporting Requirements							No Enforcement Actions
Clarke Street Family Dental 16 Clarke Street Suite 15 Lexington, MA 02421 #: 17405999 Category: D1	No Reporting Requirements							No Enforcement Actions
CoNCERT Pharmaceuticals, Inc. 65 Hayden Avenue Suite 400 Lexington, MA 02421 #: 17103513 Category: 10	No Reporting Requirements							No Enforcement Actions
Daniel R Olsen DDS 1 Wallis Court Level 2 Lexington, MA 02421 #: 17405993 Category: D1	No Reporting Requirements							No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Dare MB, Inc. 128 Spring Street Suite 310 Lexington, MA 02421 #: 17404168 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Designer Smiles of Lexington 76 Bedford Street Suite 9 Lexington, MA 02421 #: 17407582 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dicerna Pharmaceuticals, Inc. 33 Hayden Avenue Lexington, MA 02421 #: 17407912 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Eagle Endodontics 19 Muzzey Street Suite 210 Lexington, MA 02421 #: 17406005 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Family Dentistry 175 Bedford Street Suite 14 Lexington, MA 02420 #: 17406002 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Galina Gitlin DMD 62 Massachusetts Avenue Lexington, MA 02420 #: 17406016 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Garrett K Piskor DMD PC 57 Bedford Street Suite 208 Lexington, MA 02420 #: 17406014 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hadar Dental LLC 3 Bow Street Suite 2 Lexington, MA 02420 #: 17406010 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hyalex Orthopaedics 99 Hayden Avenue Building D-340 Lexington, MA 02421 #: 17406523 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Icon Dental 57 Bedford Street Suite 220 Lexington, MA 02420 #: 17406015 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Jacobio (US) Pharmaceuticals Inc. 99 Hayden Avenue Suite C-230 Lexington, MA 02421 #: 17407574 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Keith Asarkof DMD 10 Muzzey Street Lexington, MA 02421 #: 17406026 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lex Smiles PC 27 Muzzey Street Lexington, MA 02421 #: 17406008 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lexington Dental Associates PC 271 Lincoln Street Suite 2 Lexington, MA 02421 #: 17406009 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lexington Dental Care 922 Waltham Street Suite 205 Lexington, MA 02421 #: 17406022 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lexington Dental Group 35 Bedford Street Suite 16 Lexington, MA 02420 #: 17406012 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lexington Dental Group 57 Bedford Street Suite 110 Lexington, MA 02420 #: 17407577 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lexington Smile Studio 922 Waltham Street Suite 202 Lexington, MA 02421 #: 17407944 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Limited to Endodontics 1666 Massachusetts Avenue Lexington, MA 02420 #: 17406000 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
LogicBio Therapeutics 65 Hayden Avenue Lexington, MA 02421 #: 17407076 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Maria Evangelisti, DDS 1 Wallis Court Suite 1 Lexington, MA 02421 #: 17407560 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Medchem Partners LLC 99 Hayden Avenue Suite 210 Lexington, MA 02421 #: 17103567 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Paul F Dimattia DDS & Associates 76 Bedford Street Suite 8 Lexington, MA 02420 #: 17406017 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Pulmatrix, Inc. 99 Hayden Avenue Suite 390 Lexington, MA 02421 #: 17103608 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Robert J De Regis DMD 183 Bedford Street Lexington, MA 02420 #: 17406003 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Russell K Hagopian DDS 922 Waltham Street Suite 210 Lexington, MA 02421 #: 17406020 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Sarah Haven Davis DMD LLC 120 School Street Lexington, MA 02421 #: 17405996 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
T2 Biosystems, Inc. 101 Hartwell Avenue Lexington, MA 02421 #: 17103574 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
TARIS Biomedical, Inc. 113 Hartwell Avenue Lexington, MA 02421 #: 17403239 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Tepha, Inc. 99 Hayden Avenue Suite 360 Lexington, MA 02421 #: 17103626 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Thomas Braun DDS 20 Muzzey Street Lexington, MA 02421 #: 17406007 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Valo Early Discovery 75 Hayden Avenue Floor 2-2 Lexington, MA 02421 #: 17408889 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wallis Dental LLC 1 Wallis Court Suite 4 Lexington, MA 02421 #: 17405994 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Xenon Property, LLC (44 Hartwell Ave) 44 Hartwell Avenue Lexington, MA 02421 #: 17404648 Category: 02	0101	<i>Cleanout on the discharge line after pH neutralization</i>			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b>						
		Antimony (Total)						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Oil and Grease						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Xenon Property, LLC (60 Westview Street) 60 Westview Street Lexington, MA 02421 #: 17103662 Category: 02	0101	<i>Riser pipe on the discharge line after the pH neutralization system</i>			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b>						
		Antimony (Total)						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Oil and Grease						
		Silver (Total)						

## Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
		TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Zen Dental Group, LLC 14 Muzzey Street Lexington, MA 02421 #: 17405997 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
uniQure 113 Hartwell Avenue Lexington, MA 02421 #: 17404248 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Access Dental, LLC 6 Pleasant Street Suite 325 Malden, MA 02148 #: 18409328 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
American Dental Consultants 578 Main Street Suite 101 Malden, MA 02148 #: 18407356 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Arie Guthartz DMD 290 Ferry Street Malden, MA 02148 #: 18406031 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Atlantic Dental Partners 214 Main Street Malden, MA 02148 #: 18407583 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
BCD Metal Products, Inc. 205 Maplewood Street Malden, MA 02148 #: 18102432 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Boston Family Dental 572 Pleasant Street Suite 1F Malden, MA 02148 #: 18406040 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
D2 Dental 389 Main Street Suite 403 Malden, MA 02148 #: 18406034 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
David M Brodie DDS 7 Walnut Street Malden, MA 02148 #: 18406042 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dom's Sausage Company Inc. 10 Riverside Parkway Malden, MA 02148 #: 18000332 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dr. Pei Hua Wu, M.D. 389 Main Street Suite 201 Malden, MA 02148 #: 18407590 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Endodontics of Malden 10 Holden Street Suite 5 Malden, MA 02148 #: 18406027 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
F A Carmichael Dentristry 11 Dartmouth Street Suite 101 Malden, MA 02148 #: 18406028 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gentle Dental Malden 225 Centre Street Malden, MA 02148 #: 18406030 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gerard A Centrella DMD 738 Salem Street Malden, MA 02148 #: 18406044 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hoff's Bakery 35 Green Street Malden, MA 02148 #: 18407879 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Interstate Food Equipment Service Inc. 43 Sharon Street Malden, MA 02148 #: 18404755 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Malden Dental Associates 389 Main Street Suite 204 Malden, MA 02148 #: 18409193 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Malden Dental Care 10 Holden Street Suite 2 Malden, MA 02148 #: 18406023 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Malden Dentistry and Braces 427 Main Street Malden, MA 02148 #: 18409327 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Malden Family Dentist 45 -A Pleasant Street Malden, MA 02148 #: 18407588 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Maplewood Dental Associates 635 Salem Street Malden, MA 02148 #: 18407597 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Piantedosi Baking Company, Inc. 240 Commercial Street Malden, MA 02148 #: 18000057 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Pleasant Street Dental Associates 388 Pleasant Street Suite 2 Malden, MA 02148 #: 18406033 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Quartzite Processing, Inc. 6 Holyoke Street Malden, MA 02148 #: 18000085 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Sky Dental 70 Eastern Avenue Malden, MA 02148 #: 18406043 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Smart Dental 452 Pleasant Street Malden, MA 02148 #: 18406038 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Stoney Brook Family & Cosmetic Dentistry 445 Highland Avenue Malden, MA 02148 #: 18406037 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Supersport Screen Printing LLC 910 Eastern Avenue Malden, MA 02148 #: 18101606 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Tabrizi Dental Associates 389 Main Street Suite 404 Malden, MA 02148 #: 18407593 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Children & Family Dentistry & Braces 90 River Street Mattapan, MA 02126 #: 52406045 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dorchester Pediatric Dentistry and Orthodontic 1192 Blue Hill Avenue Mattapan, MA 02126 #: 52408925 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Globus Dental Mattapan 1634 Blue Hill Avenue Mattapan, MA 02126 #: 52407606 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Mattapan Community Health Center 1575 Blue Hill Avenue Mattapan, MA 02126 #: 52407603 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
River Street Family Dental 542 River Street Mattapan, MA 02126 #: 52407609 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Absorption Systems Boston, LLC. 47 Hall Street Medford, MA 02155 #: 19405122 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Albert E Cangiano Jr DMD 132 Forest Street Medford, MA 02155 #: 19406051 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Ali Mashayekhi Family Dentists 0 Governors Avenue Suite 23 Medford, MA 02155 #: 19407613 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Anthony Giamberardino DMD, PC 84 High Street Suite 304 Medford, MA 02155 #: 19406063 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Aspen Dental 690 Fellsway Plaza Medford, MA 02155 #: 19406061 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Atrius Health dba Harvard Vanguard Medical Associates 26 City Hall Mall Medford, MA 02155 #: 19007152 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
BioIVT (formerly Ascendance Biotechnology) 200 Boston Avenue Suite 1550 Medford, MA 02155 #: 19403155 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Body Toppers Inc. 407 R Mystic Avenue Unit 13 Medford, MA 02155 #: 19009513 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental Care 0 Governors Avenue Suite 1 Medford, MA 02155 #: 19406046 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental Delights PC 84 High Street Suite 203 Medford, MA 02155 #: 19406064 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Edelweiss Enterprises, Inc. 19 Blake Street Medford, MA 02155 #: 19102911 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Evolved By Nature, Inc. 196 Boston Avenue Suite 1100 Medford, MA 02155 #: 19404213 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
First Dental 366 Salem Street Medford, MA 02155 #: 19407623 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Gentle Dental Medford 23 Riverside Avenue Medford, MA 02155 #: 19408707 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gio Dental at Station Landing 8 Earhart Landing Medford, MA 02155 #: 19407630 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
GreenLight Biosciences, Inc. 200 Boston Avenue Suite 3100 Medford, MA 02155 #: 19403316 Category: 02	0102	<i>Spigot on the discharge line of the 5-gallon chip tank in Suite G850</i>			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b>						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Odor (T.O.N.)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0103	<i>Spigot on the discharge line of the 15-gallon chip tank in Suite 1250</i>						
		<b>Semi-Annual Self-Monitoring</b>						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Odor (T.O.N.)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0104	<i>Spigots on the discharge line of the 250-gallon neutralization tank in Room 201</i>						
		<b>Semi-Annual Self-Monitoring</b>						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Odor (T.O.N.)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Hyatt Place 116 Riverside Avenue Medford, MA 02155 #: 19103519 Category: 02	0101	<i>Sample port on the combined discharge pipe above the floor drain trough</i>			No Discharge Violations		01-Apr-2022	Notice of Violation
		<b>Annual Self-Monitoring</b>						
		Oil and Grease						
		pH						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Isabelle B Jailet DDS 12 Bower Street Medford, MA 02155 #: 19406057 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lawrence Memorial Hospital 170 Governors Avenue Medford, MA 02155 #: 19005758 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Limited to Endodontics 1 City Hall Mall Medford, MA 02155 #: 19406048 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lorenzo Lepore DDS PC 101 Main Street Suite 206 Medford, MA 02155 #: 19406049 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Main Street Dentistry & Orthodontics 251 Main Street Medford, MA 02155 #: 19406053 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Medford Endodontics 0 Governors Avenue Suite 30 Medford, MA 02155 #: 19406047 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Medford Square Dentistry and Implants 30 Main Street Medford, MA 02155 #: 19406055 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Omnidentix & Associates 289 Middlesex Avenue Medford, MA 02155 #: 19406054 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Paul K. Shick, DMD 3 Ashland Street Medford, MA 02155 #: 19407620 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Renato Carpinito DMD 38 High Street Medford, MA 02155 #: 19406056 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Sofregen Medical 200 Boston Avenue Suite 1100 Medford, MA 02155 #: 19404758 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
The Classic Smile 92 High Street Suite 11-12 Medford, MA 02155 #: 19406065 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Therese H Venedikian DMD PC 84 High Street Suite 7 Medford, MA 02155 #: 19409200 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Trustees of Tufts College 200 Boston Avenue Medford, MA 02155 #: 19103498 Category: 02	0101	<i>Spigot on the discharge line of the pH adjustment system</i>			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Copper (Total)						
		Formaldehyde						
		Lead (Total)						
		Nickel (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		pH						
Wellington Circle Dental 1 City Hall Mall Unit 2 Medford, MA 02155 #: 19406060 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Woburn Street Dental PC 18 Woburn Street Medford, MA 02155 #: 19406052 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Yavner Dental Associates 101 Main Street Suite 220 Medford, MA 02155 #: 19406050 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Daniel N Giatrelis DMD 515 Franklin Street Melrose, MA 02176 #: 20406073 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dr. Mark Gianatassio 820 Lynn Fells Parkway Melrose, MA 02176 #: 20406076 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Hillside Press, LLC 192 Green Street Melrose, MA 02176 #: 20103657 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hunt's Photo & Video 100 Main Street Melrose, MA 02176 #: 20101586 Category: G1	0101	PHOTO			No Discharge Violations			No Enforcement Actions
	<b>Annual</b>	<b>Self-Monitoring</b> Silver (Total)						
John Symond DDS 554 Franklin Street Melrose, MA 02176 #: 20406074 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Joseph J Scola DDS 486 A Main Street Melrose, MA 02176 #: 20406072 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Melrose Center for Oral Health 944 Main Street Melrose, MA 02176 #: 20406078 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Melrose Dental Care 80 West Foster Street Melrose, MA 02176 #: 20406075 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Melrose Family Dental PC 12 Porter Street Melrose, MA 02176 #: 20406067 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Melrose Family Dentistry LLC 10 East Emerson Street Melrose, MA 02176 #: 20406066 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Melrose Oriental Rug Co., Inc. 937 Main Street Melrose, MA 02176 #: 20404418 Category: 02	0101	<i>Rug cleaning wastewater from collection sump in basement</i>			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b> Oil and Grease pH						
Nowak Family Dental LLC 84 Myrtle Street Melrose, MA 02176 #: 20406077 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Pan Dental Care 985 Main Street Melrose, MA 02176 #: 20406079 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Shieh Dental Health Care PC 44 Grove Street Melrose, MA 02176 #: 20406071 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Solomon & Wright Associates PC 12 West Emerson Street Melrose, MA 02176 #: 20406068 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Vasilios Mourmoutis DMD PC 27 East Emerson Street Melrose, MA 02176 #: 20409326 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Curry College 1071 Blue Hill Avenue Milton, MA 02186 #: 21406556 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental 1 PC 480 Adams Street Suite 104 Milton, MA 02186 #: 21406084 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dentistry of Milton, LLC 4 Franklin Street Milton, MA 02186 #: 21406081 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
East Milton Dental 539 Adams Street Milton, MA 02186 #: 21406086 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gayle M Pezzulo DMD PC 480 Adams Street Milton, MA 02186 #: 21406085 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Harte Dental LLC 480 Adams Street Suite 206 Milton, MA 02186 #: 21406083 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Milton Hill Dental 99 Adams Street Milton, MA 02186 #: 21406087 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Murphy Dental Group 464 Granite Avenue Milton, MA 02186 #: 21406082 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
ABI Lab 27 Strathmore Road Natick, MA 01760 #: 22404969 Category: 02	0101	75-gallon limestone chip tank			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Mercury (Total)						
		TTO (Volatile Organic Fraction)						
		pH						
ABI-LAB2 22 Strathmore Road Natick, MA 01760 #: 22408050 Category: 02	0101	Laboratory wastewater.			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Aspen Dental 843 Worcester Road Natick, MA 01760 #: 22406100 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Chang Dental Group 220 North Main Street Suite 203 Natick, MA 01760 #: 22406096 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Courtyard by Marriott 342 Speen Street Natick, MA 01760 #: 22102976 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Craig I MacDonald DMD PC 182 West Central Street Natick, MA 01760 #: 22406092 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Elite Dental of Natick 232 Pond Street Suite 5 Natick, MA 01760 #: 22406098 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions



## Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Gentle Dental Center of Natick 1322 Worcester Road Natick, MA 01760 #: 22406090 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Jacques Boudreau DMD PC 205 Union Street Natick, MA 01760 #: 22406093 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
James R Sunners DDS PC 209 West Central Street Natick, MA 01760 #: 22406094 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Natick Dental Associates 1 Common Street Suite B Natick, MA 01760 #: 22406088 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Natick Dental Health 164 N Main Street Natick, MA 01760 #: 22406091 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Natick Dental Partners 230 Pond Street Natick, MA 01760 #: 22406097 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Natick Family Dental 14 West Central Street Natick, MA 01760 #: 22409140 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Natick Fire - Speen Street Station 268 Speen Street Natick, MA 01760 #: 22300991 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Natick Travelodge 1350 Worcester Street Natick, MA 01760 #: 22103109 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Phoenix Diagnostics, Inc. 8 Tech Circle Natick, MA 01760 #: 22007616 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Pillar Biosciences, Inc. (Michigan Dr.) 12 Michigan Drive Natick, MA 01760 #: 22405483 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Pillar Biosciences, Inc. (Strathmore Rd.) 9 Strathmore Road Natick, MA 01760 #: 22408278 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Reality Dentistry 10 Union Street Suite 3D Natick, MA 01760 #: 22406089 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
SBH Sciences, Inc. 4 -A Strathmore Road Natick, MA 01760 #: 22101930 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Samer Aleid DDS 318 North Main Street Natick, MA 01760 #: 22406099 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Scott R Helle, DMD, LLC 4 Whittier Road Natick, MA 01760 #: 22409162 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Springvale Water Treatment Plant 1080 Worcester Street Natick, MA 01760 #: 22102009 Category: 03	0101	<i>SPIGOT ON THE SLUDGE DISCHARGE LINE</i>			No Discharge Violations			No Enforcement Actions
		Semi-Annual Self-Monitoring Total Suspended Solids pH						
Vita Needle Co. 22 Pleasant Street Natick, MA 01760 #: 22405227 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Atkins & Meola Dental Group 32 Wexford Street Needham, MA 02459 #: 23409021 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Atrius Health - Harvard Vanguard Medical Associates 152 Second Avenue Needham, MA 02494 #: 23404428 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Baker's Best Catering 150 Gould Street Needham, MA 02494 #: 23404100 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Beth Israel Deaconess Hospital - Needham Campus 148 Chestnut Street Needham, MA 02492 #: 23005716 Category: 02	0104	SPIGOT ON THE DISCHARGE PIPE OF THE LIMESTONE CHIPTANK			No Discharge Violations		27-Aug-2021	Notice of Violation
	Quarterly	<b>Self-Monitoring</b> Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	0201	OR INSTRUMENT WASHER DRAIN LINE						
	Semi-Annual	<b>Self-Monitoring</b> Chromium (Total) Nickel (Total) pH						
Brookline Rug Cleaning Co. Inc. 317 Hunnewell Street Needham, MA 02494 #: 23005375 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Carrie B Reddish DMD PC 1233 Highland Avenue Needham, MA 02492 #: 23406105 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Celldex Therapeutics, Inc. 119 Fourth Avenue Needham, MA 02494 #: 23100233 Category: 02		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Charles River Wellfield Water Treatment Plant 914 Charles River Street Needham, MA 02492 #: 23101898 Category: 02	0102	Sampling port after limestone chip tank in Lab			No Discharge Violations			No Enforcement Actions
	Annual	<b>Self-Monitoring</b> pH						
	0103	Recycled backwash water						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Chestnut Dental Associates 87 Chestnut Street Needham, MA 02492 #: 23406112 Category: D1	Quarterly	Self-Monitoring Arsenic (Total) Copper (Total) Nickel (Total) Total Suspended Solids Zinc (Total) pH						
		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Chillybears Inc. 6 Brook Road Needham, MA 02494 #: 23101730 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
D.L. Atkinson Inc. 48 Mellen Street Needham, MA 02494 #: 23100384 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Franklin W. Olin College of Engineering 100 Olin Way Needham, MA 02492 #: 23103042 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gillis Dental 1211 Highland Avenue Needham, MA 02492 #: 23408708 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Homewood Suites by Hilton - Needham/Boston 200 First Avenue Needham, MA 02494 #: 23406555 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hoye Dental 20 Chestnut Street Needham, MA 02492 #: 23406108 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Inform Diagnostics 15 19 Crawford Street Needham, MA 02494 #: 23102336 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Invicro, LLC 119 Fourth Avenue Needham, MA 02494 #: 23404006 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Jonathan M Davis DMD 1410 Highland Avenue Suite 203 Needham, MA 02492 #: 23406107 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Marva Khalid DMD 105 Chestnut Street Suite 25 Needham, MA 02492 #: 23406102 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Needham Dental 302 Chestnut Street Needham, MA 02492 #: 23406111 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Needham Laser Dentistry 1253 Highland Avenue Needham, MA 02494 #: 23408869 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Paul H Aswad DMD PC 1253 Highland Avenue Needham, MA 02492 #: 23406106 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
ST Equipment & Technology, LLC 101 Hampton Avenue Needham, MA 02494 #: 23403277 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
SXC Needham Inn LLC dba Residence Inn by Marriott 80 B Street Needham, MA 02494 #: 23404390 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Shark Ninja 89 A Street Suite 100 Needham, MA 02494 #: 23405380 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Sheraton Needham Hotel 100 Cabot Street Needham, MA 02494 #: 23007315 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Stephen J McCrann DDS 20 Chestnut Street Needham, MA 02492 #: 23406109 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
The Cancer Center at Beth Israel Deaconess Med. Cntr Needham 148 Chestnut Street Needham, MA 02492 #: 23404409 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Thomas A Analetto DMD 214 Chestnut Street Needham, MA 02492 #: 23406110 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Vita Needle Company 919 Great Plain Avenue Needham, MA 02492 #: 23002927 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
William D Irving DDS 1116 Great Plain Avenue Needham, MA 02492 #: 23406103 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Aesthetics-In-Dentistry/Periodontal Associates, Inc. 1400 Centre Street Suite 102 Newton Centre, MA 02459 #: 24409159 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Auburndale Dental 2098 Commonwealth Avenue Newton, MA 02466 #: 24407643 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Baek Dental PC 1400 Centre Street Suite 106 Newton Centre, MA 02459 #: 24406142 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Beth Israel Deaconess Healthcare - Chestnut Hill 200 Boylston Street Chestnut Hill, MA 02467 #: 24404326 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Boston College - Chestnut Hill Campus 140 Commonwealth Avenue Chestnut Hill, MA 02467 #: 24005439 Category: 02	0102	Spigot on discharge pipe of trim tank	0102	Spigot on discharge pipe of trim tank			18-Oct-2021 Notice of Violation	03-Nov-2021 Notice of Violation
	<b>Semi-Annual Self-Monitoring</b>		7-Oct-2021	Toluene	2.19	mg/l	DYMX < 1	
		TTO (Extractable Organic Fraction)	0115	Spigot on discharge pipe of neutralization system				
		TTO (Volatile Organic Fraction)	4-Oct-2021	Cadmium (Total)	0.13	mg/l	DYMX < 0.1	
		pH						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
	0103	<i>Spigot on discharge pipe of neutralization tank</i>						
		<b>Semi-Annual Self-Monitoring</b>						
		Formaldehyde						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		pH						
	0115	<i>Spigot on discharge pipe of neutralization system</i>						
		<b>Semi-Annual Self-Monitoring</b>						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		pH						
	0116	<i>Discharge from Science and Engineering Building, 245 Beacon Street</i>						
		<b>Semi-Annual Self-Monitoring</b>						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0117	<i>Spigot on the discharge pipe from the washing machines</i>						
		<b>Semi-Annual Self-Monitoring</b>						
		Copper (Total)						
		Mercury (Total)						
		Oil and Grease						
		Zinc (Total)						
		pH						
	0118	<i>Discharge from laundry machines in the Conte Forum</i>						
		<b>Semi-Annual Self-Monitoring</b>						
		Copper (Total)						
		Mercury (Total)						
		Oil and Grease						
		Zinc (Total)						
		pH						
	0119	<i>Discharge from laundry machines in the Yawkey Center</i>						
		<b>Semi-Annual Self-Monitoring</b>						
		Copper (Total)						
		Mercury (Total)						
		Oil and Grease						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
		Zinc (Total) pH						
	0301	<i>Discharge from laundry machines in the Frates Center</i>						
		<b>Semi-Annual Self-Monitoring</b>						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		Zinc (Total)						
		pH						
Boylston Street Dental, LLC dba Boylston Street Dental Group 300 Boylston Street Suite 202 Chestnut Hill, MA 02467 #: 24407403 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Chestnut Hill Dental 631 -A VFW Parkway Chestnut Hill, MA 02467 #: 24405858 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Complete Dental of Newton 558 Commonwealth Avenue Newton, MA 02459 #: 24406133 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Concord Dental Associates 69 Union Street Newton, MA 02459 #: 24406135 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cosmetic Dentistry Center 64 Columbus Street Newton, MA 02461 #: 24406134 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Cynthia R Shapiro DMD 1957 Beacon Street Waban, MA 02468 #: 24406344 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dana Farber Cancer Institute 300 Boylston Street Chestnut Hill, MA 02467 #: 24408374 Category: 02	0101	<i>Process wastewater from laboratory operations.</i>						No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b>						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Dental Specialists of Newton 271 Auburn Street Newton, MA 02466 #: 24406123 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dentist of Chestnut Hill/Convivial Dental 1244 Boylston Street Suite 205 Chestnut Hill, MA 02467 #: 24405856 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Finagle A Bagel 77 Rowe Street Newton, MA 02466 #: 24103437 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gentle Dental Newton 188 Needham Street Newton, MA 02462 #: 24408704 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hammond Pond Dental Group 822 Boylston Street Suite 200 Chestnut Hill, MA 02467 #: 24405859 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Harvey J Cohen DMD 1087 Beacon Street Suite 102 Newton, MA 02459 #: 24406114 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Herbert S. Birnbaum DMD 670 Beacon Street Newton Centre, MA 02459 #: 24406144 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Karyopharm Therapeutics, Inc. 75 -95 Wells Avenue Floor 2 & 3 Newton, MA 02459 #: 24404334 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
LabShares Newton LLC 55 Chapel Street Suite 100 Newton, MA 02458 #: 24409247 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
LabShares Newton, LLC 90 Bridge Street Suite 100 & 200 Newton, MA 02458 #: 24404582 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Lane S Sofman DDS 86 Bowers Street Newton, MA 02460 #: 24406138 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lasell University 1844 Commonwealth Avenue Newton, MA 02466 #: 24405351 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Mark Dental Group 37 Austin Street Newton, MA 02460 #: 24406129 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Massachusetts General Hospital - Newton, MA 2 Wells Avenue Newton, MA 02459 #: 24403988 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Newton Centre Dental 1400 Centre Street Suite 201 Newton, MA 02459 #: 24406120 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Newton Corner Dental Care 313 Washington Street Suite 102 Newton, MA 02458 #: 24406127 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Newton Dental Associates 93 Union Street Suite 402 Newton, MA 02459 #: 24406139 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Newton Dental PLLC 345 Boylston Street Suite 101 Newton, MA 02459 #: 24406128 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Newton Dental Wellness 93 Union Street Suite 408 Newton, MA 02459 #: 24406141 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Newton Dentistry 73 Lexington Street Suite 204 Newton, MA 02466 #: 24405554 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Newton Family Dental Center 1172 Beacon Street Suite 104 Newton, MA 02461 #: 24406116 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Newton Smile Centre 796 Beacon Street Newton, MA 02459 #: 24409286 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Newtonville Dental Associates 701 Washington Street Newton, MA 02458 #: 24406136 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Rousson Family Dentistry 1001 Watertown Street Newton, MA 02465 #: 24406113 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Salvatore Angelo II DMD PC 1280 Centre Street Suite 200 Newton, MA 02459 #: 24406118 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Starlident Newton Dental Office 517 Washington Street Newton, MA 02458 #: 24409059 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
T. D. Filandrianos and Associates 1400 Centre Street Suite 101 Newton, MA 02459 #: 24406121 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
The Center for Advanced Dental Care PLLC 93 Union Street Suite 308 Newton, MA 02459 #: 24406140 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
The Newton Dental Group 290 Centre Street Suite 201 Newton, MA 02458 #: 24406125 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
TissueVision, Inc. 150 California Street Newton, MA 02458 #: 24408395 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Trustees of Boston College-Newton Campus 885 Centre Street Newton, MA 02459 #: 24007255 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
UMass Amherst - Mount Ida Campus 777 Dedham Street Newton, MA 02459 #: 24005508 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Vast Dental 433 Watertown Street Newton, MA 02458 #: 24407644 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Waban Dental Group 1180 Beacon Street Newton, MA 02461 #: 24406117 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Yamamoto and Associate PC 1400 Centre Street Suite 103 Newton Centre, MA 02459 #: 24409160 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
1Globe Health Institute, LLC 333 Providence Highway Norwood, MA 02062 #: 25103550 Category: C1	0101 Annual	X-RAY FILM PROCESSOR AFTER EPAN SILVER RECOVERY SYS Self-Monitoring Silver (Total)			No Discharge Violations			No Enforcement Actions
Advanced Dental Center 125 Central Street Norwood, MA 02062 #: 25406151 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Advanced Instruments 2 Technology Way Norwood, MA 02062 #: 25407959 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Anna Zaborovsky Dental Practice 648 Washington Street Suite 204 Norwood, MA 02062 #: 25406156 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Atrius Health dba Dedham Medical Associates 1177 Providence Highway Norwood, MA 02062 #: 25405505 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Butera Dental Specialists 89 Access Road Suite 26 Norwood, MA 02062 #: 25406165 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Castle Island Brewing Co., LLC 31 Astor Avenue Norwood, MA 02062 #: 25404620 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Central Dental Associates 470 Washington Street Suite 1 Norwood, MA 02062 #: 25406154 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Courtyard By Marriott - Norwood 300 River Ridge Drive Norwood, MA 02062 #: 25101857 Category: 02	0101	<i>DISCHARGE PIPE AT THE FLOOR TRENCH</i>			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b> Oil and Grease pH						
Dana L. Mandel DMD 63 Broadway Norwood, MA 02062 #: 25406155 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dedham Medical Associates 325 River Ridge Drive Norwood, MA 02062 #: 25406152 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
E.I.C. Laboratories, Inc. 111 Downey Street Norwood, MA 02062 #: 25003019 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Epic Family Dentistry, PLLC dba Epic Dental 315 Norwood Park South Suite 100 Norwood, MA 02062 #: 25409299 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Four Points Hotel and Conference Center 1125 Boston-Providence Turnpike Norwood, MA 02062 #: 25006130 Category: 02	0201	<i>Laundry wastewater</i>			No Discharge Violations			No Enforcement Actions
		<b>Annual Self-Monitoring</b> Oil and Grease Oil and Grease pH pH						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
GQ Machine Company 61 Endicott Street Building 34 Norwood, MA 02062 #: 25101565 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gentle Dental Norwood 980 Providence Highway Norwood, MA 02062 #: 25406166 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Ingleside Corporation dba The Corporate Press 89 Access Road Unit 17 Norwood, MA 02062 #: 25100236 Category: G1	0101	LINE FROM MSII TO DRAIN  Annual Self-Monitoring Silver (Total)			No Discharge Violations			No Enforcement Actions
Kaceli Dental Studio, LLC 661 Washington Street Unit 211 Norwood, MA 02062 #: 25406159 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Landmark Dental 77 Access Road Suite 1 Norwood, MA 02062 #: 25406163 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Laura E. Sullivan DMD, PC 56 Walpole Street Norwood, MA 02062 #: 25409296 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Maranda A. Bliss DMD, PC 111 Lenox Street Suite 113 Norwood, MA 02062 #: 25406158 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Modern Testing Services LLC 349 Lenox Street Norwood, MA 02062 #: 25405072 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Moderna Therapeutics, Inc. 1 Upland Road Building 100 Norwood, MA 02062 #: 25405498 Category: 02	0101	Wastewater from vaccine manufacturing in MTC-South  Semi-Annual Self-Monitoring Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total)			No Discharge Violations		08-Feb-2022	Notice of Violation

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		pH						
	0102	<i>Wastewater from vaccine manufacturing in MTC-South Building</i>						
		<b>Semi-Annual Self-Monitoring</b>						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0202	<i>Wastewater from MTC-North Building</i>						
		<b>Semi-Annual Self-Monitoring</b>						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0203	<i>Laboratory wastewater from MTC-North Building</i>						
		<b>Annual Self-Monitoring</b>						
		Copper (Total)						
		Cyanide (Total)						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
	0301	<i>Wastewater from Quality Control in MTC-East</i>						
		<b>Annual Self-Monitoring</b>						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Mystic Scenic Studios, Inc. 293 Lenox Street Norwood, MA 02062 #: 25405323 Category: 02	0101	Waterjet effluent after cascading weir	0101	Waterjet effluent after cascading weir			30-Dec-2021	Notice of Violation
	<b>Semi-Annual Self-Monitoring</b>	Chromium (Total) Copper (Total) Nickel (Total) Zinc (Total) pH	9-Dec-2021	Zinc (Total)	3.69	mg/l DYMx < 1		
Neponset River LLC fka FM Global Research Corporation 1151 Boston Providence Turnpike Norwood, MA 02062 #: 25103383 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
New England Dental Specialists of Norwood 24 Guild Street Norwood, MA 02062 #: 25409297 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Norwood Dental Care 47 Central Street Norwood, MA 02062 #: 25406153 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Norwood Dental Center PC 1242 Washington Street Norwood, MA 02062 #: 25406150 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Norwood Family Dental 117 Broadway Norwood, MA 02062 #: 25409298 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Norwood Hospital, A Steward Family Hospital 800 Washington Street Norwood, MA 02062 #: 25005737 Category: 02	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Norwood Hospitality, LLC 434 Providence Highway Norwood, MA 02062 #: 25101808 Category: 02	0101	Floor trench behind the washing machines					15-Sep-2021 Notice of Violation 11-Apr-2022 Notice of Violation	
	<b>Semi-Annual Self-Monitoring</b>	Copper (Total) Lead (Total) Mercury (Total) Oil and Grease Zinc (Total) pH						



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Olympic Adhesives, Inc. 670 Canton Street Norwood, MA 02062 #: 25005440 Category: 02	0101	discharge pipe in floor trench			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b> TTO (Extractable Organic Fraction) pH							
Pediatric & Family Dentistry of Norwood & Endodontic Care 761 Washington Street Floor 1 Norwood, MA 02062 #: 25406162 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Prize Possessions 340 -R Vanderbilt Avenue Norwood, MA 02062 #: 25405449 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Quest Diagnostic TB, LLC 315 Norwood Park South Norwood, MA 02062 #: 25007440 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Siemens Healthcare Diagnostics, Inc. 2 Edgewater Drive Norwood, MA 02062 #: 25103309 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Taylor Freezer of New England, Inc. 1030 University Avenue Norwood, MA 02062 #: 25405213 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
The Regal Press, Inc. 79 Astor Avenue Norwood, MA 02062 #: 25003884 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
A-Best Enterprises & Portable Toilets, Inc. 267 N Quincy Street Abington, MA 02351 #: 00103251 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
B.N.V. Enterprises, Inc. dba Rooter-Man 48 Sullivan Road Billerica, MA 01862 #: 00100409 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Claude Dubord & Son Inc. 45 Mae Avenue Bridgewater, MA 02324 #: 00100376 Category: 06		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
John Zanni Pumping Co., Inc. 5 Hallberg Park North Reading, MA 01864 #: 00100394 Category: 06	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Miles of Excavating 115 Park Street Norfolk, MA 02056 #: 00404013 Category: 06	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
T Horn Pumping Services Inc. dba Stoughton Pumping Service 46 Plain Street E Berkley, MA 02779 #: 00101305 Category: 06	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Tewksbury Sewer Service, Inc. 95 Helvetia Street Tewksbury, MA 01876 #: 00100414 Category: 06	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Adams Family Dental 953 Hancock Street Quincy, MA 02170 #: 26406186 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Advanced Dental Arts of Quincy 1250 Hancock Street Suite 123 S Quincy, MA 02169 #: 26406173 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Alfredo Aiello Italian Foods, Inc. 122 Water Street Quincy, MA 02169 #: 26001284 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Alliance Dental Center, LLC 111 Washington Street Suite 301 Quincy, MA 02169 #: 26409395 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
American Dental Quincy 688 Hancock Street Quincy, MA 02170 #: 26406201 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Aspen Dental 45 Newport Avenue Quincy, MA 02171 #: 26406191 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Atrius Health - Harvard Vanguard Medical Associates 1250 Hancock Street Quincy, MA 02169 #: 26102436 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Boston Scientific 500 Commander Shea Boulevard Quincy, MA 02169 #: 26103145 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Coddington Dental 59 Coddington Street Suite 102 Quincy, MA 02169 #: 26407846 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Comprehensive Dental Care 1261 Furnace Brook Parkway Suite 16 Quincy, MA 02169 #: 26405891 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Core Dental LLC 611 Adams Street Quincy, MA 02169 #: 26406198 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Courtney Sanders Knapik, DMD, P.C. 350 Hancock Street Quincy, MA 02171 #: 26407844 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Crown Dental Group 500 Congress Street Suite 3E Quincy, MA 02169 #: 26406193 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Daniel J Madden DMD 1073 Hancock Street Suite 205 Quincy, MA 02169 #: 26406167 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental Associates Inc 300 Crown Colony Drive Suite 301 Quincy, MA 02169 #: 26406199 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dr. Dental of Quincy, PC 101 Falls Boulevard Quincy, MA 02169 #: 26409232 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Ermont Inc. 216 Ricciuti Drive Quincy, MA 02169 #: 26405232 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Excel Family Dental PC 1261 Furnace Brook Parkway Suite 24 Quincy, MA 02169 #: 26406175 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Family Dental Health Center, PC 121 Billings Road Quincy, MA 02171 #: 26406170 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
G & L Labs, Inc. 246 Arlington Street Quincy, MA 02170 #: 26405427 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
General Dynamics Mission Systems, Inc. - Bluefin Robotics 553 South Street Quincy, MA 02169 #: 26404987 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gentle Dental Quincy 130 Parking Way Quincy, MA 02169 #: 26406177 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gentle Dental Quincy 1530 Hancock Street Quincy, MA 02169 #: 26408706 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Giri Quincy Restaurant Services dba Best Western Adams Inn 29 Hancock Street Quincy, MA 02171 #: 26101809 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Howard Lau, DMD PC 14 Federal Avenue Quincy, MA 02169 #: 26406179 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Huail Fish House Boston Inc 206 Ricciuti Drive Quincy, MA 02169 #: 26409158 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
JF Dental 44 Greenleaf Street Suite 1 Quincy, MA 02169 #: 26406189 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
John Ictech-Cassis-Sandra Morin 1372 Hancock Street Suite 204 Quincy, MA 02169 #: 26406178 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lumiere Dental Spa 495 Sea Street Quincy, MA 02169 #: 26406192 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Marina Bay Dental Associates PC 308 Victory Road North Quincy, MA 02171 #: 26406146 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
MaryAnne Del Cupolo DDS 21 Franklin Street Quincy, MA 02169 #: 26406183 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Nankin Dental Associates Inc 500 Congress Street Suite 2D Quincy, MA 02169 #: 26406194 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Patricia L Carolan DMD 111 Willard Street Suite 1A Quincy, MA 02169 #: 26406168 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Paul H. Murphy & Company, Inc. 634 Willard Street Quincy, MA 02169 #: 26102740 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Pelly Chang DMD PC 166 Willard Street Quincy, MA 02169 #: 26406182 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Purity Cheese Company 206 Ricciuti Drive Quincy, MA 02169 #: 26101969 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Quincy Center For Endodontics 234 Copeland Street Suite 310 Quincy, MA 02169 #: 26409350 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Quincy Dental 875 Southern Artery Quincy, MA 02169 #: 26406204 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Quincy Dental Associates 234 Copeland Street Unit 330 Quincy, MA 02169 #: 26406185 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Quincy Dental Specialists Group 580 Hancock Street Quincy, MA 02170 #: 26406196 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Quincy Dentists 79 Elm Street Quincy, MA 02169 #: 26406203 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Quincy Endodontics 67 Coddington Street Suite 102 Quincy, MA 02169 #: 26407850 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Robert William Ryan DDS Inc 1229 Hancock Street Quincy, MA 02169 #: 26406172 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Shabazian Family Dental 157 Washington Street Quincy, MA 02169 #: 26406180 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Sobo Dental 111 Willard Street Suite 1-B Quincy, MA 02169 #: 26406169 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
South Cove Community Health Center 88 Holmes Street Quincy, MA 02171 #: 26406205 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
South Street Dental 276 South Street Quincy, MA 02169 #: 26406187 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
South Suburban Dialysis Center (#1610) 241 Parkway Quincy, MA 02169 #: 26007484 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Spring Dental 440 Hancock Street Suite 205 North Quincy, MA 02171 #: 26407847 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Staybridge / Holiday Inn 1 Arlington Street Quincy, MA 02171 #: 26407788 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Stella Bondar, DMD 1261 Furnace Brook Parkway Suite 27 Quincy, MA 02169 #: 26407845 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Stephen MacDonald DMD 770 Hancock Street Quincy, MA 02170 #: 26406202 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Stephen Matarazzo DMD 300 Crown Colony Drive Quincy, MA 02169 #: 26406188 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Sunbelt Rentals 153 Brook Road Quincy, MA 02169 #: 26405388 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Taiyo Seafood Boston, Inc. 256 Arlington Street Quincy, MA 02170 #: 26405425 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Temple Family Dentistry 1261 Furnace Brook Parkway Suite 12 Quincy, MA 02169 #: 26406174 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

## Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
US Renal Care Quincy Dialysis 500 Victory Road Quincy, MA 02171 #: 26405118 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
USAPhil Dental Health Care II 52 Greenleaf Street Quincy, MA 02169 #: 26406195 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wollaston Dental Group 628 Hancock Street Quincy, MA 02170 #: 26406327 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Aqua Dental LLC 1395 North Main Street Randolph, MA 02368 #: 27406213 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Comfort Inn 1374 North Main Street Randolph, MA 02368 #: 27103560 Category: 02	0101	<i>Discharge line receiving laundry wastewater</i>			No Discharge Violations		17-Sep-2021 Notice of Violation 20-Apr-2022 Notice of Violation	
		<b>Semi-Annual Self-Monitoring</b> Copper (Total) Lead (Total) Mercury (Total) Oil and Grease Zinc (Total) pH						
Dental Specialties Inc 950 North Main Street Randolph, MA 02368 #: 27406217 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Elite Envelope & Graphics, Inc. 280 Pond Street Randolph, MA 02368 #: 27102306 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Evoqua Water Technologies, LLC 49 York Avenue Randolph, MA 02368 #: 27403177 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Fowler Printing & Graphics ,Inc. 132 York Avenue Randolph, MA 02368 #: 27007381 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Frito Lay Inc. dba Stacy's Pita Chip Company 663 North Street Randolph, MA 02368 #: 27103381 Category: G2		No Reporting Requirements						No Enforcement Actions
Holiday Inn Express & Suites Boston South-Randolph Hotel 60 Mazzeo Drive Randolph, MA 02368 #: 27407670 Category: 02	0101	<i>Process wastewater from laundry operation.</i>					10-Aug-2021	Notice of Violation
	<b>Semi-Annual Self-Monitoring</b>							
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		Zinc (Total)						
		pH						
Jimmy Lai DMD PC 10 Mazzeo Drive Suite 209 Randolph, MA 02368 #: 27406207 Category: D1		No Reporting Requirements						No Enforcement Actions
LION TotalCare, Inc. 40 -B Teed Drive Randolph, MA 02368 #: 27405382 Category: 02	0101	<i>Laundry effluent</i>	0101	<i>Laundry effluent</i>			14-Mar-2022	Notice of Violation
	<b>Semi-Annual Self-Monitoring</b>		10-Feb-2022	Zinc (Total)	2.05	mg/l		
		Oil and Grease						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Melmar Inc 296 North Street Randolph, MA 02368 #: 27101094 Category: 02	0101	<i>Washing machine effluent.</i>						No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Copper (Total)						
		Copper (Total)						
		Lead (Total)						
		Lead (Total)						
		Mercury (Total)						
		Mercury (Total)						
		Oil and Grease						
		Oil and Grease						
		Zinc (Total)						
		Zinc (Total)						
		pH						
		pH						
Melville Candy Company 28 York Avenue Randolph, MA 02368 #: 27405295 Category: G2		No Reporting Requirements						No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Progressive Marble Fabrication, Inc. 43 York Avenue Randolph, MA 02368 #: 27007222 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Randolph Dental Group 96 North Main Street Randolph, MA 02368 #: 27406214 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Randolph Dental Smile, PLLC 89 South Main Street Randolph, MA 02368 #: 27406216 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Randolph Engineering Inc. 26 Thomas Patten Drive Randolph, MA 02368 #: 27101001 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Randolph Family Dentistry PC 56 South Main Street Randolph, MA 02368 #: 27406215 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Sharri Trilling DMD 1093 North Main Street Randolph, MA 02368 #: 27406209 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Simply Orthodontics & Pediatric Dentistry 15 Warren Street Randolph, MA 02368 #: 27409308 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Trans Dental Care, Inc. 1062 North Main Street Randolph, MA 02368 #: 27406208 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Ultrafiltronics, Ltd. 91 York Avenue Randolph, MA 02368 #: 27102497 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Family Dental Associates 636 Main Street Reading, MA 01867 #: 28406226 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
First Dental Associates 274 Main Street Reading, MA 01867 #: 28406225 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Kallen K Hull DMD PC 274 Main Street Suite 205 Reading, MA 01867 #: 28406224 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lisa Vouras DMD, PC 85 Woburn Street Reading, MA 01867 #: 28406252 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
MA Dental Care 2 Haven Street Suite 303 Reading, MA 01867 #: 28406220 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Radiance Dental 161 Ash Street Suite C Reading, MA 01867 #: 28406218 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Ravens Family Dental 198 Ash Street Reading, MA 01867 #: 28406219 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Reading Dental 270 Main Street Reading, MA 01867 #: 28406223 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Reading Dental Associates 161 Ash Street Suite B Reading, MA 01867 #: 28408691 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Susan E. Fitzgerald DMD 246 Woburn Street Reading, MA 01867 #: 28406222 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Walker's Brook Crossing, LLC, c/o Wilder Companies Walkers Brook Drive Reading, MA 01867 #: 28103125 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Winchester & Reading Pediatric Dentistry LLC 54 Haven Street Reading, MA 01867 #: 28406221 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Annese DMD LLC 106 Broadway Revere, MA 02151 #: 29406229 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Artshirt Company 386 Squire Road Revere, MA 02151 #: 29404867 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Bao Min Yee, DMD PC 49 Shirley Avenue Revere, MA 02151 #: 29406239 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Becker Becker & Silvius LLC 34 Shirley Avenue Revere, MA 02151 #: 29406237 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Benecchi Dental Group 140 School Street Revere, MA 02151 #: 29406232 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Boschetti Dental One Orr Square Revere, MA 02151 #: 29406228 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
DVI 407 Squire Road LLC dba Boston Logan Four Points 407 Squire Road Revere, MA 02151 #: 29101880 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Depietro Family Dental Care 123 Revere Street Revere, MA 02151 #: 29406231 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dr. Dental of Revere, PC 339 Squire Road Revere, MA 02151 #: 29409233 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Ernest F Powers Jr DMD 276 Squire Road Revere, MA 02151 #: 29406235 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Louis Devito Jr DMD 50 Squire Road Revere, MA 02151 #: 29406244 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
My Dental Revere 334 Broadway Revere, MA 02151 #: 29406236 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Olufemi A. Oguntolu DMD PC 252 Squire Road Revere, MA 02151 #: 29406233 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Page Family Dental LLC 26 Central Avenue Revere, MA 02151 #: 29406234 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Park Avenue Dental Associates 500 Park Avenue Revere, MA 02151 #: 29406240 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Perfect Dental Revere 651 Squire Road Revere, MA 02151 #: 29406243 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Revere Dentistry and Braces 370 Broadway Revere, MA 02151 #: 29409317 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Revere Pediatric Dentistry 11 Vinal Street Revere, MA 02151 #: 29406230 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental Collaborative 4452 Washington Street Roslindale, MA 02131 #: 53406246 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Gourmet Caterers Inc. 3867 Washington Street Roslindale, MA 02131 #: 53001789 Category: 02	0101	Spigot on discharge piping from lift station			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>	Oil and Grease Zinc (Total) pH						
Harvard University - Weld Hill Research Facility 1300 Centre Street Roslindale, MA 02131 #: 53403347 Category: 02	0101	Laboratory and greenhouse wastewater after neutralization			No Discharge Violations			No Enforcement Actions
	<b>Annual Self-Monitoring</b>	Formaldehyde Pesticides TTO (Volatile Organic Fraction) Zinc (Total) pH						
Perfect Dental Roslindale 644 American Legion Highway Roslindale, MA 02131 #: 53406247 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Puritan Ice Cream Company 3895 Washington Street Roslindale, MA 02131 #: 53001683 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Richard F.X. Spagnuolo DDS PC 1048 South Street Roslindale, MA 02131 #: 53406245 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Smiley Dental Roslindale 954 American Legion Highway Roslindale, MA 02131 #: 53407541 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Unity Dental 4172 Washington Street Roslindale, MA 02131 #: 53409498 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
2147 Master Developer LLC and Kaplan Construction 2147 Washington Street Roxbury, MA 02119 #: 54409186 Category: 12	0101	Catch basin at 2117 Washington St (north side), between Dade St and Williams St			No Discharge Violations			No Enforcement Actions
	<b>Monthly Self-Monitoring</b>	Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction)						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
AB Seafood LLC 20 Newmarket Square Roxbury, MA 02118 #: 54404109 Category: G2	No Reporting Requirements	TTO (Volatile Organic Fraction) Total Suspended Solids pH			No Discharge Violations			No Enforcement Actions
Best Western Roundhouse Suites 891 Massachusetts Avenue Roxbury, MA 02118 #: 54103676 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Biomedical Applications of Roxbury 416 Warren Street Roxbury, MA 02119 #: 54101168 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Bon Me Foods 148 Hampden Street Roxbury, MA 02119 #: 54404174 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Boston Brisket Co., Inc. 42 Newmarket Square Roxbury, MA 02118 #: 54007095 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Boston Police Headquarters (City Of Boston) 1 Schroeder Plaza Roxbury, MA 02120 #: 54101319 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Bully Boy Distillers, LLC 35 Cedric Street Roxbury, MA 02119 #: 54403457 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
City Fresh Foods, Inc. 77 Shirley Street Roxbury, MA 02119 #: 54403667 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Cortland Dental & Braces_Roxbury Facility 2181 Washington Street Suite 101 Roxbury, MA 02119 #: 54406250 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

## Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Dental Dreams LLC 3033 Washington Street Roxbury, MA 02119 #: 54406254 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Diablo Glass School 123 Terrace Street Roxbury, MA 02120 #: 54403885 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dimock Community Health Center 55 Dimock Street Roxbury, MA 02119 #: 54406255 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Mass Wholesale Food Terminal Condo Trust 140 Newmarket Square Roxbury, MA 02118 #: 54004419 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Morgan Services, Inc. 941 Massachusetts Avenue Roxbury, MA 02118 #: 54004499 Category: 02	0101 Quarterly	8 INCH PALMER BOWLUS FLUME Self-Monitoring Oil and Grease Zinc (Total) pH TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction)			No Discharge Violations			No Enforcement Actions
Shanghai Ravioli Corporation 25 Howard Street Roxbury, MA 02119 #: 54103466 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Southampton Wholesale Food Terminal 80 -88 Newmarket Square Roxbury, MA 02118 #: 54004548 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Steve Connolly Seafood Company, Inc. 34 Newmarket Square Roxbury, MA 02118 #: 54007642 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Suresh K Naidu DDS 156 Dudley Street Roxbury, MA 02119 #: 54406249 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
101 South Street Owner LLC and Shawmut Construction 101 South Street Somerville, MA 02143 #: 30406826 Category: 12		0101 Catch basin on Earle St. (east of site)	No Discharge Violations				No Enforcement Actions	
	Monthly	<b>Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TSS_ONLY Group TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
		0201 Catch basin on Earle St, close to South St (east of site, south of 0101)	No Discharge Violations				No Enforcement Actions	
	Monthly	<b>Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TSS_ONLY Group TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
		0301 Catch basin on South St. (south of 101 South St. site)	No Discharge Violations				No Enforcement Actions	
	Monthly	<b>Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TSS_ONLY Group TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
599 Somerville Ventures LLC & Shawmut Design & Construction 599 Somerville Avenue Somerville, MA 02143 #: 30409384 Category: 12		0101 Stormwater catch basin located on Somerville Ave.	No Discharge Violations				No Enforcement Actions	
	Monthly	<b>Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction)						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
		TTO (Volatile Organic Fraction) Total Suspended Solids pH						
	0102	<i>Stormwater catch basin located on Spring St.</i>						
	<b>Monthly</b>	<b>Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						
Aeronaut Brewing Company 14 Tyler Street Somerville, MA 02143 #: 30404392 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Alpha Dental 701 Broadway Somerville, MA 02144 #: 30406278 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Anthony P Parrella DMD 102 College Avenue Somerville, MA 02144 #: 30406256 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Atrius Health - Harvard Vanguard Medical Associates 40 Holland Street Somerville, MA 02144 #: 30102777 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Brickbottom QOZB LP and Consigli Construction Company, Inc. 28 Chestnut Street Somerville, MA 02143 #: 30409082 Category: 12	0101	<i>Catch basin 001 located on corner of Fitchburg St. and Chestnut St.</i>				No Discharge Violations		No Enforcement Actions
	<b>Monthly</b>	<b>Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS----- Frequency    Parameter	-----DISCHARGE VIOLATIONS----- Date          Parameter          Result          Limit	-----ENFORCEMENT ACTIONS----- Date          Actions
<p>0102    <i>Catch basin 002 located at 28 Chestnut St. east side of site</i></p> <p><b>Monthly</b>      <b>Self-Monitoring</b>                      Arsenic (Total)                      Lead (Total)                      Mercury (Total)                      Oil and Grease                      PCB's                      Pesticides                      TTO (Extractable Organic Fraction)                      TTO (Volatile Organic Fraction)                      Total Suspended Solids                      pH</p>	<p>No Reporting Requirements</p>	<p>No Discharge Violations</p>	<p>No Enforcement Actions</p>
<p>Bright Dental                      435 Washington Street Suite 97B                      Somerville, MA 02143                      #: 30406271 Category: D1</p>	<p>No Reporting Requirements</p>	<p>No Discharge Violations</p>	<p>No Enforcement Actions</p>
<p>Cambridge Health Alliance - Somerville Campus                      230 Highland Avenue Somerville, MA 02143                      #: 30006648 Category: 10</p>	<p>No Reporting Requirements</p>	<p>No Discharge Violations</p>	<p>No Enforcement Actions</p>
<p>City of Somerville (SHSS Project) and P. Gioioso &amp; Sons Inc.                      Somerville Avenue Somerville, MA 02143                      #: 30409380 Category: 12</p>	<p>0101    <i>Somerville manhole located at intersection of Bow St. &amp; Walnut St.</i></p> <p><b>Monthly</b>      <b>Self-Monitoring</b>                      Arsenic (Total)                      Lead (Total)                      Mercury (Total)                      Oil and Grease                      PCB's                      Pesticides                      TTO (Extractable Organic Fraction)                      TTO (Volatile Organic Fraction)                      Total Suspended Solids                      pH</p>	<p>No Discharge Violations</p>	<p>No Enforcement Actions</p>
<p>City of Somerville / Barletta Heavy Division, Inc                      93 Highland Street Somerville, MA 02143                      #: 30406710 Category: 12</p>	<p>0106    <i>Manhole located on Somerville Ave Extension; near 216 McGrath Highway</i></p> <p><b>Monthly</b>      <b>Self-Monitoring</b>                      Arsenic (Total)                      Lead (Total)                      Mercury (Total)                      Oil and Grease                      PCB's                      Pesticides                      TSS_ONLY Group                      TTO (Extractable Organic Fraction)                      TTO (Volatile Organic Fraction)                      Total Suspended Solids</p>	<p>No Discharge Violations</p>	<p>No Enforcement Actions</p>

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Corp.#10408875 U.S. Inc. dba nPlexBio 15 Ward Street Somerville, MA 02143 #: 30409292 Category: 10	No Reporting Requirements	pH			No Discharge Violations			No Enforcement Actions
DCI-Somerville 643 Broadway Somerville, MA 02145 #: 30101768 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Davis Square Dental 67 Holland Street Somerville, MA 02144 #: 30406273 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Deano's Pastacia Inc. 15 Garfield Avenue Somerville, MA 02145 #: 30404538 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental Arts Davis Square 396 Highland Avenue Somerville, MA 02144 #: 30406269 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dentplant 281 Broadway Somerville, MA 02145 #: 30406265 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Finch Therapeutics, Inc. 200 Innerbelt Road Somerville, MA 02143 #: 30404858 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Fleming & Son Corp. dba Fleming Printing 40 White Street Somerville, MA 02144-3213 #: 30008870 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Formlabs Inc. 35 Medford Street Suite 301 Somerville, MA 02143 #: 30406785 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gentle Dental Somerville 14 McGrath Highway Somerville, MA 02143 #: 30406260 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Great Hill Dental Somerville 20 Holland Street Suite 400 Somerville, MA 02144 #: 30406264 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Harvard University - Harvard Art Museums - Somerville 200 Inner Belt Road Somerville, MA 02143 #: 30403337 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hemlock Ink 19 Properzi Way Somerville, MA 02143 #: 30404399 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Highland Dental Associates 366 Broadway Suite 202 Somerville, MA 02145 #: 30406268 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Julian Basha DMD PLLC 36 Bow Street Somerville, MA 02143 #: 30406267 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Kappa Dental Group 402 Washington Street Somerville, MA 02143 #: 30406270 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Langs Dental Center 593 McGrath Highway Somerville, MA 02145 #: 30406276 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lina Al-Aswad DDS 1133 Broadway Somerville, MA 02144 #: 30406257 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lorna Lally DMD 109 College Avenue Somerville, MA 02144 #: 30406275 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
M. Catherine Taimo, DMD, PC 180 Highland Avenue Somerville, MA 02143 #: 30406263 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
North Star Rental Systems / Universal Laundry, Inc. 43 Fremont Street Somerville, MA 02145 #: 30002736 Category: 02	0101	Laundry effluent from 8 inch Palmer Bowlus flume			No Discharge Violations			No Enforcement Actions
	Quarterly	Self-Monitoring Oil and Grease TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
Perfect Dental Somerville 128 Broadway Somerville, MA 02145 #: 30406259 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Rogers Foam Corporation 20 Vernon Street Somerville, MA 02145 #: 30002306 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sandra Tranfaglia DMD PC 17 Washington Street Somerville, MA 02143 #: 30406261 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Smiles Over Somerville 474 Broadway Suite 110 Somerville, MA 02145 #: 30406272 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Smiles by Rosie Family Dentistry 6 Kensington Avenue Somerville, MA 02145 #: 30406277 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Somerville Family Dental 365 Somerville Avenue Somerville, MA 02143 #: 30406274 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Somerville First Dental 622 Somerville Avenue Somerville, MA 02143 #: 30409390 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Spring Hill Dental 174 Highland Avenue Unit 1 Somerville, MA 02143 #: 30406262 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Taza Chocolate 561 Windsor Street Somerville, MA 02143 #: 30404337 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
The Braces Place & T-Station Dental 30 College Avenue Somerville, MA 02144 #: 30407940 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
West Somerville Dental 124 College Avenue Somerville, MA 02144 #: 30406258 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
105 W First Street Owner, LLC 105 W First Street South Boston, MA 02127 #: 55409278 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Adams-Chapman Co. - FB Packing Co 9-15 Foodmart Road South Boston, MA 02118 #: 55102995 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Autodesk, Inc. 23 Drydock Avenue Suite 110C South Boston, MA 02210 #: 55405524 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Boston Sword & Tuna, Inc. 10 Codfish Way South Boston, MA 02210 #: 55103160 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Cambridge Packing Company 39-43 Foodmart Road South Boston, MA 02118 #: 55102989 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Campco 41 Foodmart Road South Boston, MA 02118 #: 55102997 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Cape Cod Shellfish Seafood/Boston Seafood Express 8 Seafood Way South Boston, MA 02210 #: 55408092 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Catamaran Bio, Inc. 451 D Street Suite Fir5-500 South Boston, MA 02210 #: 55409387 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Channel Fish Processing Co. 18 Foodmart Road South Boston, MA 02118 #: 55103005 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Citidental South Boston 141 Dorchester Avenue South Boston, MA 02127 #: 55409204 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Commercial Lobster Co. 300 Northern Avenue South Boston, MA 02210 #: 55403751 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Constitution Seafoods, Inc. 8 Seafood Way South Boston, MA 02210 #: 55103161 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dana-Farber Cancer Institute 27 Drydock Avenue South Boston, MA 02210 #: 55403136 Category: 02	0101	<i>Sampling spigot located after pH neutralization system</i>			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Total Suspended Solids						
		Zinc (Total)						
		pH						
Emulate, Inc. 27 Drydock Avenue Floor 5 South Boston, MA 02210 #: 55404479 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
F. B. Packing 1 -3 Foodmart Road South Boston, MA 02118 #: 55102998 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	<b>-----CURRENT SAMPLING REQUIREMENTS-----</b>	<b>-----DISCHARGE VIOLATIONS-----</b>	<b>-----ENFORCEMENT ACTIONS-----</b>
<u>Frequency</u> <u>Parameter</u>	<u>Date</u> <u>Parameter</u> <u>Result</u> <u>Limit</u>	<u>Date</u> <u>Actions</u>	
FastCAP Systems Corporation dba Nanoramic Laboratories 21 Drydock Avenue Suite 820E South Boston, MA 02110 #: 55404984 Category: 10	No Reporting Requirements	No Discharge Violations	No Enforcement Actions
Flour Bakery 1 Design Center Place Suite 17-130E South Boston, MA 02210 #: 55404693 Category: G2	No Reporting Requirements	No Discharge Violations	No Enforcement Actions
Frank Bertolino Beef 45 -51 Foodmart Road South Boston, MA 02118 #: 55103006 Category: G2	No Reporting Requirements	No Discharge Violations	No Enforcement Actions
Gentle Dental South Boston 368 A West Broadway South Boston, MA 02127 #: 55406282 Category: D1	No Reporting Requirements	No Discharge Violations	No Enforcement Actions
Ginkgo BioWorks 27 Drydock Avenue Floor 8 South Boston, MA 02210 #: 55403380 Category: 02	<p>0101    <i>Lab sink effluent</i></p> <p><b>Semi-Annual Self-Monitoring</b></p> <p style="padding-left: 20px;">Copper (Total) Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH</p> <p>0102    <i>Washer effluent</i></p> <p><b>Semi-Annual Self-Monitoring</b></p> <p style="padding-left: 20px;">Copper (Total) Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH</p> <p>0103    <i>Autoclave effluent</i></p> <p><b>Semi-Annual Self-Monitoring</b></p> <p style="padding-left: 20px;">Copper (Total) Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH</p>	No Discharge Violations	No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Gordon Industries Inc. dba Amramp 202 W First Street South Boston, MA 02127 #: 55002596 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Grab & Go LLC 28 Damrell Street South Boston, MA 02127 #: 55405327 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
GrandTen Distilling 383 Dorchester Avenue South Boston, MA 02127 #: 55404342 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Haemonetics Corporation 125 Summer Street Floor 16 South Boston, MA 02110 #: 55005543 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
IDB 21-25 Drydock Limited Partnership 21 Drydock Avenue Suite 330E South Boston, MA 02210 #: 55409376 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Inozyme Pharma 451 D Street Floor 9 South Boston, MA 02210 #: 55408663 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Jnana Therapeutics 6 Tide Street Suite 301 South Boston, MA 02210 #: 55408336 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
John Nagle Company 306 Northern Avenue South Boston, MA 02210 #: 55403500 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
John P. Pow Company, Inc. 49 D Street South Boston, MA 02127 #: 55004446 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Karas & Karas Glass Company, Inc. 455 Dorchester Avenue South Boston, MA 02127 #: 55002245 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
KeraFast, Inc. 21 Drydock Avenue Floor 7 South Boston, MA 02210 #: 55403859 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
LSF Quality Control Center LLC 1 Seafood Way South Boston, MA 02210 #: 55409084 Category: G2		No Reporting Requirements			No Discharge Violations		15-Jul-2021	Notice of Noncompliance
Living Proof, Inc. 17 Drydock Avenue Floor 6 South Boston, MA 02210 #: 55103397 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Lucky River Transportation Corp. 38 - 48 Damrell Street South Boston, MA 02127 #: 55403873 Category: 02	0101  Annual	<i>Standpipe on the discharge line after the oil/water separator</i>  <b>Self-Monitoring</b> Nickel (Total) Oil and Grease Zinc (Total) pH			No Discharge Violations			No Enforcement Actions
Marriott Residence Inn Seaport 368 Congress Street South Boston, MA 02210 #: 55403594 Category: 02	0101	<i>Effluent from laundry</i>  <b>Semi-Annual Self-Monitoring</b> Oil and Grease Zinc (Total) pH			No Discharge Violations			No Enforcement Actions
Mass Innovation Labs dba SmartLabs 6 Tide Street South Boston, MA 02210 #: 55407805 Category: 02	0101  Annual	<i>Lab wastewater from first floor neutralization system #1</i>  <b>Self-Monitoring</b> Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH			No Discharge Violations			No Enforcement Actions
	0102	<i>Lab wastewater from second floor neutralization system #2</i>  <b>Semi-Annual Self-Monitoring</b> Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
Metropolitan Meat Company 1 Widett Circle South Boston, MA 02118 #: 55103088 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Michael F Arcieri DMD Inc 590 East Broadway South Boston, MA 02127 #: 55406286 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Mytide Therapeutics, Inc. 451 D Street Suite 707 South Boston, MA 02210 #: 55407702 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Nan Fung Life Sciences Real Estate (S.Bos) 51 Sleeper Street South Boston, MA 02210 #: 55409076 Category: 02	0101	<i>Spigot on discharge line of pH neutralization tank</i>			No Discharge Violations		25-May-2022	Notice of Violation
	<b>Semi-Annual Self-Monitoring</b>							
		Chromium (Total)						
		Copper (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
New Boston Seafood Center, Inc. 310 -312 Northern Avenue South Boston, MA 02210 #: 55101981 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
North Coast Seafoods 270 West First Street South Boston, MA 02127 #: 55103360 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
OPG MP Parcel Owner (DE), LLC 645 Summer Street Boston, MA 02210 #: 55406792 Category: 02	0101	<i>Central pH neutralization system Lab effluent.</i>			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Chromium (Total)						
		Copper (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
ORIG3N 27 Drydock Avenue Floor 3 South Boston, MA 02210 #: 55404469 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Pacific American Fish Company, Inc. 8 Seafood Way South Boston, MA 02210 #: 55103159 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Pier 7, Inc. 23 Foodmart Road South Boston, MA 02118 #: 55103007 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Prime Foodservice Inc. dba S. M. Sneider Co., Inc. 53 Foodmart Road South Boston, MA 02118 #: 55102991 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
PureTech Health 6 Tide Street South Boston, MA 02210 #: 55407145 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Puritan Foods Company, Inc. 17 Foodmart Road South Boston, MA 02118 #: 55103003 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Robbins Beef Company, Inc. 35 Foodmart Road South Boston, MA 02118 #: 55102990 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
SG Technology Excellence Center US, Inc. 451 D Street Suite 704 South Boston, MA 02210 #: 55408179 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Sea-Cap, Inc. 8 Seafood Way South Boston, MA 02210 #: 55103162 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Seaport Catering Co. 88 Black Falcon Avenue Suite 165 South Boston, MA 02210 #: 55403872 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Seaport Dental Associates 451 D Street Suite 200 South Boston, MA 02210 #: 55407223 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Shaughnessy RE LLC 295 W First Street South Boston, MA 02127 #: 55103643 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Silicon Therapeutics 451 D Street Suite 205 South Boston, MA 02210 #: 55406597 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
South Boston Community Health Center 386 West Broadway South Boston, MA 02127 #: 55406284 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
South Boston Dental Associates Inc 29 Farragut Road South Boston, MA 02127 #: 55406281 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
South Boston Family Dental 591 East Broadway South Boston, MA 02127 #: 55406287 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
The Freeport South Boston and Rise Construction Management 270 Dorchester Avenue South Boston, MA 02127 #: 55408197 Category: 12	0101  Monthly	<i>Catch basin located on B Street, near the intersection with W. 6th Street</i>  <b>Self-Monitoring</b> Arsenic (Total) Arsenic (Total) Lead (Total) Lead (Total) Mercury (Total) Mercury (Total) Oil and Grease Oil and Grease PCB's PCB's Pesticides Pesticides TTO (Extractable Organic Fraction) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids Total Suspended Solids pH pH			No Discharge Violations			No Enforcement Actions
	0102	<i>Catch basin located on B Street, near the intersection with W. 7th Street</i>						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----	-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
<u>INDUSTRY</u>	<u>Frequency</u> <u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
	<b>Monthly</b> <b>Self-Monitoring</b> Arsenic (Total) Arsenic (Total) Lead (Total) Lead (Total) Mercury (Total) Mercury (Total) Oil and Grease Oil and Grease PCB's PCB's Pesticides Pesticides TTO (Extractable Organic Fraction) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids Total Suspended Solids pH pH						
	0201 <i>Catch basin located W. 6th Street, near the intersection with B Street</i>						
	<b>Monthly</b> <b>Self-Monitoring</b> Arsenic (Total) Arsenic (Total) Lead (Total) Lead (Total) Mercury (Total) Mercury (Total) Oil and Grease Oil and Grease PCB's PCB's Pesticides Pesticides TTO (Extractable Organic Fraction) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids Total Suspended Solids pH pH						
U.S. Postal Service 25 Dorchester Avenue South Boston, MA 02205 #: 55101900 Category: 10	No Reporting Requirements	No Discharge Violations				No Enforcement Actions	

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Vertex Pharmaceuticals Inc. 50 Northern Avenue South Boston, MA 02210 #: 55404203 Category: 02	0101	Sample Spigot on Discharge Piping from pH Neutralization  <b>Semi-Annual Self-Monitoring</b> Chromium (Total) Copper (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH			No Discharge Violations			No Enforcement Actions
Vertex Pharmaceuticals Inc. 316 -318 Northern Avenue South Boston, MA 02210 #: 55409223 Category: 02	0101	Wastewater from R&D Laboratories  <b>Semi-Annual Self-Monitoring</b> Copper (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH			No Discharge Violations			No Enforcement Actions
Washington Village Property Owner LLC & Dimeo Constr. Co. 235 Dorchester Street South Boston, MA 02215 #: 55409138 Category: 12	0101	Stormwater catch basin north of site on Damrell St  <b>Monthly Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total)			No Discharge Violations			No Enforcement Actions



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>	<u>-----DISCHARGE VIOLATIONS-----</u>	<u>-----ENFORCEMENT ACTIONS-----</u>
	<u>Frequency</u> <u>Parameter</u>	<u>Date</u> <u>Parameter</u> <u>Result</u> <u>Limit</u>	<u>Date</u> <u>Actions</u>
	Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH		
	0201 <i>Stormwater catch basin north of site on Old Colony Ave</i>		
	<b>Monthly</b> <b>Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH		
	0202 <i>Stormwater catch basin east of site on Dorchester St</i>		
	<b>Monthly</b> <b>Self-Monitoring</b> Arsenic (Total) Lead (Total) Mercury (Total) Oil and Grease PCB's Pesticides TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Total Suspended Solids pH		
Watermark Donut Company 370 Dorchester Avenue South Boston, MA 02127 #: 55404705 Category: G2	No Reporting Requirements	No Discharge Violations	No Enforcement Actions
West Broadway Family Dental 385 West Broadway South Boston, MA 02127 #: 55406283 Category: D1	No Reporting Requirements	No Discharge Violations	No Enforcement Actions
William Eaves DMD 216 Dorchester Street South Boston, MA 02127 #: 55406280 Category: D1	No Reporting Requirements	No Discharge Violations	No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Yotel Boston 65 Seaport Boulevard South Boston, MA 02210 #: 55407736 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Charles W Malta DDS (Stoneham) 158 Main Street Stoneham, MA 02180 #: 31406303 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dr. Bruce Doyle DMD 74 Main Street Stoneham, MA 02180 #: 31406330 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dr. Ray Rezanian 271 Main Street Suite G02 Stoneham, MA 02180 #: 31407458 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Drs Pizzarello & Silvestro Family Dentistry 546 Main Street Stoneham, MA 02180 #: 31406306 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
LPI Printing & Graphics, Inc. 18 Spencer Street Stoneham, MA 02180 #: 31405008 Category: G1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lund Dental Associates LLC 2 Main Street Suite 225 Stoneham, MA 02180 #: 31406304 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Nandhavan Dental PLLC 106 Main Street Suite 5 Stoneham, MA 02180 #: 31409325 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Northshore Family Dentistry 3 Woodland Road Suite 417 Stoneham, MA 02180 #: 31406305 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
R J Wu & Associates 61 Main Street Stoneham, MA 02180 #: 31406307 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Redstone Dental Center 70 Main Street Stoneham, MA 02180 #: 31406329 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Robert L Roy DDS 61 Main Street Stoneham, MA 02180 #: 31406308 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Steven A Migliorini DMD 114 Central Street Stoneham, MA 02180 #: 31406302 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Stoneham Dental Care 112 Main Street Stoneham, MA 02180 #: 31406300 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
All Seasons Septic Service Inc. 200 Cushing Street Suite 7 Stoughton, MA 02072 #: 32101571 Category: 06	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Alpha Chemical Services, Inc. 46 Morton Street Stoughton, MA 02072 #: 32005051 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Alright Dental 684 Washington Street Stoughton, MA 02072 #: 32409303 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Avon Food Company LLC 220 Canton Street Stoughton, MA 02072 #: 32103304 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
B&B Trading Corporation 1033 Turnpike Street Stoughton, MA 02072 #: 32407737 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Childrens Dental Health Center 966 -C Park Street Stoughton, MA 02072 #: 32406342 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Crescent Ridge Dairy, Inc. 355 Bay Road Sharon, MA 02067 #: 32408781 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dayspring Dental Solutions 1819 Central Street Stoughton, MA 02072 #: 32409302 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dentistry on Park LLC 19 Park Street Stoughton, MA 02072 #: 32406334 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dr. Matthew Finkelstein, DMD dba Cobb Corner Dental 36 Bay Road Stoughton, MA 02072 #: 32409301 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Endodontic Center PC 1256 Park Street Suite 203 Stoughton, MA 02072 #: 32409305 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Endontic Health, PC 839 Washington Street Stoughton, MA 02072 #: 32406341 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
First Impression Printing, Inc. 178 Tosca Drive Stoughton, MA 02072 #: 32102361 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gentle Dental Stoughton 341 Washington Street Stoughton, MA 02072 #: 32406335 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gerald M. Winkler DMD PC 4 Cabot Place Suite 8 Stoughton, MA 02072 #: 32406337 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Kid Care Dental 1613 Central Street Stoughton, MA 02072 #: 32406333 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Marver Med, Inc. 1063 Turnpike Street Stoughton, MA 02072 #: 32103702 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Massachusetts Bay Technologies (MBT) 378 Page Street Building 7 Stoughton, MA 02072 #: 32403434 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Park Dental Group, PC 480 Park Street Stoughton, MA 02072 #: 32406339 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Primo Medical Group 75 Mill Street Stoughton, MA 02072 #: 32100111 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Rentals Unlimited (PEAK) 117 Tosca Drive Stoughton, MA 02072 #: 32405345 Category: 02	0101	<i>laundry washwater</i>			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b> Oil and Grease Zinc (Total) pH						
Seth M Roth DMD 450 Pearl Street Stoughton, MA 02072 #: 32406338 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Sonesta Select Boston Stoughton 200 Technology Center Drive Stoughton, MA 02072 #: 32405319 Category: 02	0101	<i>Trough behind washing machines</i>			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b> Copper (Total) Oil and Grease pH						
Stoughton Dentistry 35 Park Street Stoughton, MA 02072 #: 32406336 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Stoughton Family Dental 1255 Central Street Stoughton, MA 02072 #: 32406332 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Teamstercare Dental Local 25 1214 Park Street Stoughton, MA 02072 #: 32406331 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Albion Dental Care 6 Albion Street Wakefield, MA 01880 #: 33406358 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Biocytogen Boston Corp 50 -C Audubon Road Wakefield, MA 01880 #: 33405710 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Bruce Parad DMD 24 Mansfield Drive Wakefield, MA 01880 #: 33406350 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Crescent Dental Associates, LLC 10 Crescent Street Wakefield, MA 01880 #: 33406346 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Crystal Lake Dental 725 Main Street Wakefield, MA 01880 #: 33406359 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Darr Dental LLC 9 -A Richardson Avenue Wakefield, MA 01880 #: 33406362 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Fiore Dental Associates 39 Yale Avenue Wakefield, MA 01880 #: 33406352 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Future of Dentistry 968 Main Street Floor 1 Wakefield, MA 01880 #: 33406361 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gentle Dental Wakefield 409 Main Street Wakefield, MA 01880 #: 33406353 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Great Pond Dental PC 202 Lowell Street Wakefield, MA 01880 #: 33406348 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Jeffrey B Kravitz DDS 417 Water Street Wakefield, MA 01880 #: 33406354 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Joseph P Russo DDS PC 15 West Water Street Wakefield, MA 01880 #: 33406347 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Joy Dental Care 384 Lowell Street Suite 106 Wakefield, MA 01880 #: 33406351 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lakeside Inn 595 North Avenue Wakefield, MA 01880 #: 33101871 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Nardone Septic, Inc. dba John's Pumping Service 82 New Salem Street Wakefield, MA 01880 #: 33103407 Category: 06	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Richard J. Luise DMD 5 Common Street Floor 2 Wakefield, MA 01880 #: 33406356 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Schumacher Dental 599 North Avenue Unit Door 9 Wakefield, MA 01880 #: 33409324 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Wakefield Custom Dental 1 West Water Street Suite 101 Wakefield, MA 01880 #: 33406345 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Wakefield Family Dental Center 211 Albion Street Wakefield, MA 01880 #: 33406349 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Wakefield Item Company, Inc. 26 Albion Street Wakefield, MA 01880 #: 33102249 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Aspen Dental 116 Providence Highway East Walpole, MA 02032 #: 34406363 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
B Saba DMD PC 965 Main Street Walpole, MA 02081 #: 34406369 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dental Associates of Walpole 1428 Main Street Suite 1 Walpole, MA 02081 #: 34406365 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Edward J. Delaney Water Treatment Facility 1303 Washington Street Walpole, MA 02081 #: 34101766 Category: 02	0101	<i>BACKWASH FROM THE WASTE BASINS</i>			No Discharge Violations			No Enforcement Actions
	<b>Monthly</b>	<b>Self-Monitoring</b> Total Suspended Solids Antimony (Total) Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total) TTO (Volatile Organic Fraction) Zinc (Total) pH						
H.E. Willis Water Treatment Plant 9 Leonard Road Walpole, MA 02081 #: 34102907 Category: 02	0101	<i>SAMPLE PORT ON THE RESIDUALS DISCHARGE PIPE</i>			No Discharge Violations			No Enforcement Actions
	<b>Monthly</b>	<b>Self-Monitoring</b> Total Suspended Solids Antimony (Total) Arsenic (Total) Cadmium (Total) Chromium (Total) Copper (Total) Lead (Total) Mercury (Total) Nickel (Total) Selenium (Total) Silver (Total)						



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Herb Chambers Lexus of Sharon 25 Providence Highway Sharon, MA 02067 #: 34103589 Category: 02	0101  Semi-Annual	RISER PIPE ON DISCH. LINE OF GAS/OIL SEPARATOR ON ABUTMENT  Self-Monitoring Zinc (Total) pH Lead (Total) Nickel (Total) Oil and Grease TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH	0101 14-Jun-2022	RISER PIPE ON DISCH. LINE OF GAS/OIL SEPARATOR ON ABUTMENT  pH	5.45  S.U.	Grab/ > 5.5 Ph	25-May-2022	Notice of Violation
Kevin P Mischley DDS 1329 Main Street Walpole, MA 02081 #: 34406364 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Marshall A. Storm DDS, LLC 841 Main Street Suite 6 Walpole, MA 02081 #: 34409300 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Peggy Lawton Kitchens, Inc. 255 Washington Street East Walpole, MA 02032 #: 34001783 Category: G2	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Richard A Collari DMD 420 Main Street Walpole, MA 02081 #: 34406367 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Siemens Healthineers 333 Coney Street Walpole, MA 02032 #: 34005974 Category: 02	0101  Semi-Annual	NEUTRALIZATION SYSTEM BUILDING 1  Self-Monitoring TTO (Volatile Organic Fraction) pH	No Discharge Violations				No Enforcement Actions	
	0301  Semi-Annual	NEUTRALIZATION SYSTEM PARAMAGNETIC PARTICLE MANUFACTURE  Self-Monitoring TTO (Volatile Organic Fraction) pH						
	0401  Semi-Annual	NEUTRALIZATION SYSTEM MANUFACTURING AREA BUILDING #3  Self-Monitoring TTO (Volatile Organic Fraction) pH						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
<i>0501 NEUTRALIZATION SYSTEM IN BUILDING #4</i>								
<b>Semi-Annual Self-Monitoring</b>								
TTO (Volatile Organic Fraction)								
pH								
Svetlana Livshin DMD 254 Main Street Walpole, MA 02081 #: 34406366 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Unident Dental Group 90 Boston Providence Highway Walpole, MA 02032 #: 34406370 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
376 Dental Studio 376 Moody Street Waltham, MA 02453 #: 35409285 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
A123 Systems LLC 200 West Street Waltham, MA 02451 #: 35103324 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
ARE-MA Region No. 9, LLC 100 Beaver Street Waltham, MA 02453 #: 35100174 Category: 02	<i>0106 SPIGOT ON THE NEUTRALIZATION SYSTEM DISCHARGE LINE</i>		No Discharge Violations				No Enforcement Actions	
<b>Semi-Annual Self-Monitoring</b>								
Copper (Total)								
Formaldehyde								
Nickel (Total)								
TTO (Volatile Organic Fraction)								
Zinc (Total)								
pH								
Actronics, Inc. 166 Bear Hill Road Waltham, MA 02451 #: 35004599 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Aspen Dental 1030 Main Street Waltham, MA 02451 #: 35406373 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
AstraZeneca R&D Boston 35 Gatehouse Drive Waltham, MA 02451 #: 35102425 Category: 02	<i>0101 Neutralization system located in Building B</i>		<i>0301 Cooling Tower Lift Station</i>				No Enforcement Actions	
<b>Semi-Annual Self-Monitoring</b>								
Chromium (Total)								
Cyanide (Total)								
		23-May-2022	Zinc (Total)	1.49	mg/l	DYMX < 1		

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>	<u>-----DISCHARGE VIOLATIONS-----</u>	<u>-----ENFORCEMENT ACTIONS-----</u>				
<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
	Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	0201 Neutralization system located in Building K  <b>Semi-Annual Self-Monitoring</b> Chromium (Total) Cyanide (Total) Formaldehyde Lead (Total) Mercury (Total) Nickel (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	0301 Cooling Tower Lift Station  <b>Annual Self-Monitoring</b> Chromium (Total) Copper (Total) Lead (Total) Mercury (Total) Molybdenum Nickel (Total) Orthophosphate Zinc (Total) pH						
Azure Dental Studio 25 Lionel Avenue Suite A Waltham, MA 02452 #: 35406382 Category: D1	No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Bentley University 175 Forest Street Waltham, MA 02452 #: 35006032 Category: 10	No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Best Western Plus 477 Totten Pond Road Waltham, MA 02451 #: 35101867 Category: 10	No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
CeraMem LLC 12 Clematis Avenue Waltham, MA 02453 #: 35101781 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Charles River Community Health Center 43 Foundry Avenue Waltham, MA 02543 #: 35406393 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Children's Dental of Waltham PC 695 Main Street Waltham, MA 02451 #: 35406396 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Children's Hospital Boston at Waltham 9 Hope Avenue Waltham, MA 02453 #: 35103502 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Comprint, Inc. 216 -R Newton Street Waltham, MA 02453 #: 35102645 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Crescent Suites Hotel 285 -287 Crescent Street Waltham, MA 02453 #: 35404993 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Cronins Dental 225 Moody Street Waltham, MA 02453 #: 35406377 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Damion D Meola & Associates 131 Main Street Waltham, MA 02453 #: 35406375 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental Associates-New England 40 2nd Avenue Suite 500 Waltham, MA 02451 #: 35406387 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dr. Farzaneh & Associates 616 Trapelo Road Waltham, MA 02452 #: 35406394 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Elevatebio, Inc. 200 Smith Street Waltham, MA 02451 #: 35407980 Category: 02	0101	Sampling spigot after pH neutralization system			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Embassy Suites Hotel/Waltham 550 Winter Street Waltham, MA 02451 #: 35007573 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Evident Scientific 48 Woerd Avenue Waltham, MA 02453 #: 35103245 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Extended Stay America 52 Fourth Avenue Waltham, MA 02451 #: 35102477 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Extended Stay America #9846 32 Fourth Avenue Waltham, MA 02451 #: 35102476 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Failla & DeFrancesco Family Dentistry 976 Main Street Waltham, MA 02451 #: 35406400 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Foster-Miller, Inc. dba QinetiQ North America, Inc. Technolo 358 Second Avenue Building 2 Waltham, MA 02451 #: 35103148 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Gentle Dental Waltham 879 Main Street Waltham, MA 02451 #: 35406398 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Hilton Garden Inn Boston/Waltham 420 Totten Pond Road Waltham, MA 02451 #: 35101868 Category: 02	0101	Spigot on the final discharge line from the washers.			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Oil and Grease						
		pH						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Hyatt House Boston/Waltham 54 Fourth Avenue Waltham, MA 02451 #: 35102475 Category: 02	0101	Hotel laundry discharge.			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b> Mercury (Total) Oil and Grease Zinc (Total) pH							
Immunitas Therapeutics, Inc. 830 Winter Street Floor 2 Waltham, MA 02451 #: 35408386 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Jeffrey S Cummings DMD 520 Main Street Waltham, MA 02452 #: 35406391 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
John F Giglio DMD Inc 66 South Street Waltham, MA 02453 #: 35406395 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Mighty Squirrel Brewing Company 411 Waverley Oaks Road Suite 100 Waltham, MA 02452 #: 35406822 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Minerva Biotechnologies Corporation 40 Bear Hill Road Waltham, MA 02451 #: 35103507 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Modalis Therapeutics 43 Foundry Avenue Waltham, MA 02453 #: 35407078 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Moody Street Dental Group 52 Elm Street Waltham, MA 02453 #: 35406389 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
My Dental Waltham 314 Moody Street Suite B Waltham, MA 02453 #: 35406385 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
NanoLab, Inc. 22 Bedford Street Waltham, MA 02453 #: 35403986 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
New England Donor Services, Inc. 60 First Avenue Waltham, MA 02451 #: 35403338 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Northway Biotech Inc. 828 Winter Street Waltham, MA 02451 #: 35408338 Category: 02	0101	Sampling spigot after the pH neutralization system	0101	Sampling spigot after the pH neutralization system			11-May-2022	Notice of Violation
			22-Apr-2022	Zinc (Total)	2.4	mg/l	DYMx	< 1
			26-May-2022	Zinc (Total)	3.2	mg/l	DYMx	< 1
		<b>Semi-Annual Self-Monitoring</b>						
			Copper (Total)					
			Lead (Total)					
			Mercury (Total)					
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
PPF OFF 828-830 Winter Street, LLC 830 Winter Street Waltham, MA 02451 #: 35408826 Category: 02	0101	Sampling spigot after the pH Neutralization system	No Discharge Violations				No Enforcement Actions	
		<b>Semi-Annual Self-Monitoring</b>						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Quantum Pathology, LLC 303 Bear Hill Road Waltham, MA 02451 #: 35404439 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Regis College 235 Wellesley Street Weston, MA 02493-0000 #: 35102895 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Repligen Corporation 41 Seyon Street Building 1-100 Waltham, MA 02453 #: 35102962 Category: 02	0101	SPIGOT ON NEUTRALIZATION SYSTEM DISCHARGE LINE	No Discharge Violations				No Enforcement Actions	
		<b>Semi-Annual Self-Monitoring</b>						
			Copper (Total)					
			Formaldehyde					
			Mercury (Total)					
			Nickel (Total)					
			TTO (Volatile Organic Fraction)					
			Zinc (Total)					
			pH					

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Robert Bosch LLC 101 First Avenue Waltham, MA 02451 #: 35100506 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Robert J Lindberg & Associates 32 South Street Suite 202 Waltham, MA 02451 #: 35406386 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
SSG Hospitality dba Courtyard by Marriott 387 Winter Street Waltham, MA 02451 #: 35102943 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Sanofi US (formerly Genzyme Corporation) 153 Second Avenue Waltham, MA 02451 #: 35101041 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Simpson Gumpertz & Heger Inc. 480 Totten Pond Road Waltham, MA 02451 #: 35102980 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Smile Land Dental Care, LLC dba PediatricDentalCareofWaltham 20 Hope Avenue Suite 306 Waltham, MA 02453 #: 35406376 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
T. Sona Tacvorian, DMD 29 Spruce Street Suite 1-1 Waltham, MA 02453 #: 35407881 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Tecogen, Inc. 45 First Avenue Waltham, MA 02451 #: 35005726 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Wal-Lex Dental Associates 1077 Lexington Street Suite 201 Waltham, MA 02452 #: 35406374 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Waltham Dental Center 85 River Street # 2 Waltham, MA 02453 #: 35406397 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Waltham Family Dental 30 Grant Street Waltham, MA 02453 #: 35407882 Category: D1	No Reporting Requirements							No Enforcement Actions
<hr/>								
Waverly Oaks Dental Inc. 465 Waverly Oaks Road Suite 208 Waltham, MA 02452 #: 35406388 Category: D1	No Reporting Requirements							No Enforcement Actions
<hr/>								
ARE - 480 Arsenal Street, LLC 480 Arsenal Street Watertown, MA 02472 #: 36103717 Category: 02	0101	<i>Sample spigots on the discharge line after the pH neutralization system</i>						No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b>						
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Selenium (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
<hr/>								
ARE-MA Region No. 75, LLC (200 Talcott Ave) 200 Talcott Avenue Watertown, MA 02472 #: 36409370 Category: 02	0101	<i>sampling port after pH neutralization system</i>						No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b>						
		Copper (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
<hr/>								
ARE-MA Region No. 75, LLC (300 N Beacon St) 300 N Beacon Street Watertown, MA 02472 #: 36409184 Category: 02	0101	<i>lab wastewater standpipe after pH neutralization system</i>	0101	<i>lab wastewater standpipe after pH neutralization system</i>				27-May-2022 Notice of Violation
		<b>Semi-Annual Self-Monitoring</b>	14-Jun-2022	Cyanide (Total)	0.66	mg/l	DYM	< 0.5
		Arsenic (Total)						
		Cadmium (Total)						
		Chromium (Total)						
		Color						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
		Lead (Total) Mercury (Total) Nickel (Total) Odor (T.O.N.) Selenium (Total) Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Temperature Zinc (Total) pH						
Aldatu Biosciences 313 Pleasant Street Floor 1 W Watertown, MA 02472 #: 36409009 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
All Dental Center 21 Main Street Watertown, MA 02472 #: 36406408 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
AmberGen, Inc. 313 Pleasant Street Floor 4 Watertown, MA 02472 #: 36103631 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
American Dental Watertown 171 Watertown Street Watertown, MA 02472 #: 36407647 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Arkuda Therapeutics 200 Arsenal Yards Boulevard Suite 220 Watertown, MA 02472 #: 36408235 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Arranta Bio MA, LLC 650 Pleasant Street Watertown, MA 02472 #: 36408642 Category: 02	0101	Process wastewater after pH neutralization system.  <b>Semi-Annual Self-Monitoring</b> Copper (Total) Mercury (Total) TTO (Volatile Organic Fraction) Zinc (Total) pH			No Discharge Violations			No Enforcement Actions
Arsenal Lab Space 200 -201 Dexter Avenue Watertown, MA 02472 #: 36407017 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Atrius Health - Harvard Vanguard Medical Associates 485 Arsenal Street Watertown, MA 02272 #: 36102779 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
BRE-BMR Grove LLC 65 Grove Street Watertown, MA 02472 #: 36408012 Category: 02	0101	<i>Laboratory wastewater from 1st &amp; 3rd floors</i>			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b> Copper (Total) Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	0102	<i>Laboratory wastewater from 1st, 2nd, &amp; 3rd floors</i>						
		<b>Semi-Annual Self-Monitoring</b> Copper (Total) Lead (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Barclay Water Management, Inc. 80 Coolidge Avenue Watertown, MA 02472 #: 36002494 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Biomodels LLC 313 Pleasant Street Watertown, MA 02472 #: 36403694 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Bon Ton Rug Cleaners, Inc. 81 -85 Coolidge Hill Road Watertown, MA 02472 #: 36002175 Category: 02	0201	<i>The floor drain beside the automated carpet cleaner</i>			No Discharge Violations			No Enforcement Actions
		<b>Quarterly Self-Monitoring</b> Oil and Grease TTO (Volatile Organic Fraction) pH						
C4 Therapeutics, Inc. 490 Arsenal Way Watertown, MA 02472 #: 36406070 Category: 02	0101	<i>R&amp;D lab wastewater</i>			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b> Cadmium (Total) Copper (Total) Cyanide (Total) Formaldehyde Mercury (Total)						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>	
	Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH							
0102	R&D lab wastewater							
	<b>Semi-Annual Self-Monitoring</b> Cadmium (Total) Copper (Total) Cyanide (Total) Formaldehyde Mercury (Total) Nickel (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH							
Cambrian Innovation Inc. 150 Coolidge Avenue Watertown, MA 02472 #: 36403605 Category: 10	No Reporting Requirements			No Discharge Violations			No Enforcement Actions	
Charles M Seitz DDS 1047 Belmont Street Watertown, MA 02472 #: 36406401 Category: D1	No Reporting Requirements			No Discharge Violations			No Enforcement Actions	
Cyprotex US LLC 313 Pleasant Street Watertown, MA 02472 #: 36103625 Category: 10	No Reporting Requirements			No Discharge Violations			No Enforcement Actions	
David M Drucker DDS 491 Main Street Watertown, MA 02472 #: 36406428 Category: D1	No Reporting Requirements			No Discharge Violations			No Enforcement Actions	
Directed Genomics, Inc. 313 Pleasant Street Watertown, MA 02472 #: 36408364 Category: 10	No Reporting Requirements			No Discharge Violations			No Enforcement Actions	
Doble Engineering Company 85 Walnut Street Watertown, MA 02472 #: 36002188 Category: 10	No Reporting Requirements			No Discharge Violations			No Enforcement Actions	

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Domic Damico DMD 359 Main Street Watertown, MA 02472 #: 36406413 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
East Watertown Dental 53 Bigelow Avenue Watertown, MA 02472 #: 36406420 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Enanta Pharmaceuticals, Inc. 500 Arsenal Street Watertown, MA 02472 #: 36102888 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Exonics Therapeutics 490 Arsenal Way Floor 1 Watertown, MA 02472 #: 36406652 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
EyePoint Pharmaceuticals 480 Pleasant Street Suite B300 Watertown, MA 02472 #: 36102959 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Fantasia, Failla & DeFrancesco Family Dentistry 293 Mount Auburn Street Watertown, MA 02472 #: 36406411 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Fluid Management Systems, Inc. 580 Pleasant Street Watertown, MA 02472 #: 36403346 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
James W Triant DDS 164 Galen Street Watertown, MA 02472 #: 36406406 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Joseph J Salusti DMD PC 118 Main Street Watertown, MA 02472 #: 36406402 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Kala Pharmaceuticals, Inc. 490 Arsenal Way Watertown, MA 02472 #: 36406677 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Karekine Matossian DMD 222 Waverly Avenue Watertown, MA 02472 #: 36406409 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Landmark Bio 300 N Beacon Street Watertown, MA 02472 #: 36409367 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Leon B Bastajian DDS 521 Mount Auburn Street Suite 207 Watertown, MA 02472 #: 36406419 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Luminous Dental LLC 63 Mount Auburn Street Watertown, MA 02472 #: 36406422 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lyra Therapeutics, Inc. 480 Arsenal Way Watertown, MA 02472 #: 36103648 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Mack Dental 15 Summer Street Watertown, MA 02472 #: 36406405 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Mark J Strokowski DMD 326 Belmont Street Watertown, MA 02472 #: 36406424 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Markforged, Inc. 85 School Street Watertown, MA 02472 #: 36406784 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Mayani Dental Watertown LLC 6 Mount Auburn Street Watertown, MA 02472 #: 36406433 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Newly Weds Foods, Inc. 70 -80 Grove Street Watertown, MA 02472 #: 36101065 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Pandion Therapeutics 134 Coolidge Avenue Floor 2 Watertown, MA 02472 #: 36408368 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Pediatric Dental Arts 521 Mount Auburn Street Suite 104 Watertown, MA 02472 #: 36406430 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Peter A Zucker DDS 95 Mount Auburn Street Watertown, MA 02472 #: 36406435 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Premier Dental Care 377 Main Street Watertown, MA 02472 #: 36406426 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Pulpdent Corporation 80 Oakland Street Watertown, MA 02472 #: 36007274 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Radiation Monitoring Devices, Inc. 44 Hunt Street Watertown, MA 02472 #: 36005477 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
SQZ Biotechnologies Company 200 Arsenal Yards Boulevard Suite 210 Watertown, MA 02472 #: 36408074 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Sweet Cream Corporation 128 Arlington Street Watertown, MA 02472 #: 36403490 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
TNT Dental Care PC 230 Main Street Watertown, MA 02472 #: 36406410 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Tectonic Therapeutic 490 Arsenal Way Suite 210 Watertown, MA 02472 #: 36408860 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Toyota of Watertown 149 Arsenal Street Watertown, MA 02472 #: 36301610 Category: 02	0101	<i>Pipe in the Fire Panel Room that flows into the oil/water separator</i>			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Cadmium (Total)						
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Oil and Grease						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Virogen Corporation 200 Dexter Avenue Watertown, MA 02472 #: 36101932 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Watertown Family Dental 190 Mount Auburn Street Suite A-2 Watertown, MA 02472 #: 36406407 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
William V Byrne DMD 148 Main Street Watertown, MA 02472 #: 36406404 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Windgap Medical 200 Dexter Avenue Suite 270 Watertown, MA 02472 #: 36407148 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Andrew J Toyias DDS 490 Washington Street Wellesley, MA 02482 #: 37406452 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Atrius Health - Harvard Vanguard Medical Associates 230 Worcester Street Wellesley, MA 02481 #: 37005430 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Au Blanc Aesthetics 1 Hollis Street Suite 140 Wellesley, MA 02481 #: 37406444 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Babson College 231 Forest Street Babson Park Wellesley, MA 02457 #: 37005429 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Babson Executive Conference Center One Woodland Hill Drive Wellesley, MA 02457 #: 37102424 Category: 02	0101 <i>Flume situated in vault in mechanical room adjacent to laundry room</i>  <b>Semi-Annual Self-Monitoring</b> Oil and Grease pH				No Discharge Violations			No Enforcement Actions
Faridoon Zamani, DMD, PC 310 Washington Street Suite 208 Wellesley, MA 02481 #: 37407296 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Fereydoun Haghkerdar DMD 1 Washington Street Suite 205 Wellesley, MA 02481 #: 37406439 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gary S. Wetreich DDS, PC 1 Washington Street Suite 204 Wellesley, MA 02481 #: 37406437 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hirshberg Dental Group 65 William Street Wellesley, MA 02481 #: 37406454 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Jeffrey A Harrison DMD PC 258 Washington Street Wellesley, MA 02481 #: 37406441 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
John Owen DMD 332 Washington Street Suite 300 Wellesley, MA 02481 #: 37409291 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Limited to Endodontics 1 Washington Street Suite 103 Wellesley Hills, MA 02481 #: 37406455 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Longfellow Pond Groundwater Treatment Facility 272 Worcester Street Wellesley, MA 02481 #: 37101759 Category: 02	0101 <i>4-inch filter backwash/sludge line</i>  <b>Monthly Self-Monitoring</b> Total Suspended Solids Copper (Total)				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
		Nickel (Total) pH						
	0102	<i>Discharge pipe from chlorine analyzer near lab bench</i>						
	<b>Annual</b>	<b>Self-Monitoring</b> pH						
Maewall Dental Care 358 Washington Street Wellesley, MA 02481 #: 37406448 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Maria E Cardenas DMD 332 Washington Street Suite 365 Wellesley, MA 02481 #: 37406447 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Morses Pond Groundwater Treatment Facility 100 Turner Road Extension Wellesley, MA 02481 #: 37101760 Category: 02	0101	<i>4-inch sludge line from waste basins</i>				No Discharge Violations		No Enforcement Actions
	<b>Monthly</b>	<b>Self-Monitoring</b> Total Suspended Solids Arsenic (Total) Copper (Total) Nickel (Total) pH						
	0102	<i>2-inch analyzer discharge line</i>						
	<b>Annual</b>	<b>Self-Monitoring</b> pH						
New Generation Dental Center 1 Washington Street Suite 306 Wellesley, MA 02481 #: 37406438 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Newton Wellesley Outpatient Surgery Center 25 Washington Street Wellesley, MA 02481 #: 37404682 Category: 02	0101	<i>Utensil Washers A&amp;B</i>				No Discharge Violations		No Enforcement Actions
	<b>Semi-Annual</b>	<b>Self-Monitoring</b> Copper (Total) Lead (Total) Nickel (Total) Zinc (Total) pH						
Peter W. Brodie DMD PC and Matthew R. Fantasia DMD PC 372 Washington Street Wellesley, MA 02481 #: 37406449 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Premier Dental Group of Wellesley, PC 70 Walnut Street Floor 1 Wellesley, MA 02481 #: 37407284 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Wellesley Avenue Groundwater Treatment Facility 409 Wellesley Avenue Wellesley, MA 02481 #: 37101761 Category: 02	0101	<i>Filter backwash sludge from waste basins</i>	No Discharge Violations				No Enforcement Actions	
	<b>Monthly</b>	<b>Self-Monitoring</b> Total Suspended Solids Arsenic (Total) Copper (Total) Lead (Total) Nickel (Total) Zinc (Total) pH						
	0102	<i>Laboratory discharge</i>						
	<b>Annual</b>	<b>Self-Monitoring</b> pH						
Wellesley College 106 Central Street Wellesley, MA 02481 #: 37005432 Category: 02	0103	<i>Discharge from Science Center pH adjustment system</i>	No Discharge Violations				No Enforcement Actions	
	<b>Semi-Annual Self-Monitoring</b>	Copper (Total) Mercury (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
	0106	<i>KSC basement laundry room</i>						
	<b>Semi-Annual Self-Monitoring</b>	Copper (Total) Mercury (Total) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Wellesley Dental Arts 31 Washington Street Suite A Wellesley, MA 02481 #: 37406443 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Wellesley Dental Arts - Linden St. 277 Linden Street Suite 209 Wellesley, MA 02482 #: 37406442 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Wellesley Dental Associates 148 Linden Street Suite B-3 Wellesley, MA 02482 #: 37406440 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Wellesley Dental Group 5 Seaward Road Wellesley, MA 02481 #: 37406453 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Wellesley Dental Studio 332 Washington Street Suite 240 Wellesley, MA 02481 #: 37409290 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Wellesley Dialysis LLC 195 Worcester Street Wellesley, MA 02481 #: 37404325 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Wellesley Endodontics PC 40 Grove Street Suite 420 Wellesley, MA 02482 #: 37406450 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Wellesley Family Dental 298 Washington Street Wellesley, MA 02481 #: 37406445 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Wellesley Hills Dental 332 Washington Street Suite 330 Wellesley, MA 02481 #: 37406446 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Wellesley Square Dental 1 Hollis Street Suite 340 Wellesley, MA 02482 #: 37406436 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
A Beautiful Smile Dentistry 1864 Centre Street West Roxbury, MA 02132 #: 56407649 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
American Banknote Corporation (ABC Corp) 225 Rivermoor Street West Roxbury, MA 02132 #: 56006941 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Ari Family Dental 1819 Centre Street West Roxbury, MA 02132 #: 56406468 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Atrius Health - Harvard Vanguard Medical Associates 291 Independence Drive West Roxbury, MA 02467 #: 56101738 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Bankhead & Groipen DDS PC 399 Belgrade Avenue West Roxbury, MA 02132 #: 56406473 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
City of Boston - Gardner Street Landfill 315 Gardner Street West Roxbury, MA 02132 #: 56102744 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Fadi Metri & Associates 28 Corey Street West Roxbury, MA 02132 #: 56406469 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Family Dentistry of West Roxbury 5230 Washington Street West Roxbury, MA 02132 #: 56406474 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gentle Dental West Roxbury 1852 Centre Street West Roxbury, MA 02132 #: 56406466 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
JL Dental Associates 1892 Center Street West Roxbury, MA 02132 #: 56406467 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Joseph P Nore DDS 362 Belgrade Avenue West Roxbury, MA 02132 #: 56406472 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
L David Gassiraro DDS 725 Veterans of Foreign Wars Parkway West Roxbury, MA 02132 #: 56406476 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
McLaughlin Family Dentist 59 Beach Street West Roxbury, MA 02132 #: 56406475 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Reliant Dental Group PC 1996 Centre Street Suite 201 West Roxbury, MA 02132 #: 56409096 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Richard J Shea DMD 335 Corey Street West Roxbury, MA 02132 #: 56406471 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Steven R Sepe DDS 1686 Center Street West Roxbury, MA 02132 #: 56406461 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Timothy N Smith DMD 12 Spring Street West Roxbury, MA 02131 #: 56406458 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
West Roxbury Dental Arts 1811 Centre Street West Roxbury, MA 02132 #: 56406464 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Westbrook Family Dental Care 1840 Center Street West Roxbury, MA 02132 #: 56406465 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Captain Marden's Seafoods 35 Perwal Street Westwood, MA 02090 #: 38102816 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dedham-Westwood Water District (White Lodge WTP) 154 University Avenue Westwood, MA 02090 #: 38101064 Category: O2	0101  Monthly	<i>Discharge line in the underground waste tank chamber</i>  Self-Monitoring Total Suspended Solids Cadmium (Total) Chromium (Total) Copper (Total) Lead (Total) Nickel (Total) Selenium (Total) Silver (Total)			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
		TTO (Volatile Organic Fraction) Zinc (Total) pH						
Dental Arts of Westwood 100 High Street Level Lower Westwood, MA 02090 #: 38406477 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Fresenius Kidney Care - Westwood 90 Glacier Drive Westwood, MA 02090 #: 38007115 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Westwood Dental Partners 541 High Street Suite 3 Westwood, MA 02090 #: 38406480 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Westwood Dentistry 327 Washington Street Westwood, MA 02090 #: 38406478 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
iLove Dental Care 541 High Street Level LL1 Westwood, MA 02090 #: 38406479 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Ace Dental Group 1025 Main Street South Weymouth, MA 02190 #: 39406291 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Advanced Dental Centers 544 Main Street Weymouth, MA 02190 #: 39406489 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Antech Diagnostics 595 Columbian Street Weymouth, MA 02190 #: 39102702 Category: 10	No Reporting Requirements				No Discharge Violations		30-Mar-2022	Notice of Violation
Arbor Inn LLC 750 Bridge Street Weymouth, MA 02191 #: 39405338 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Associated Dental Group of Weymouth 500 Pond Street South Weymouth, MA 02190 #: 39406296 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Barrel House Z, LLC 95 Woodrock Road Weymouth, MA 02189 #: 39405399 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Beyond Dental Health of Weymouth 851 Main Street Suite 8 Weymouth, MA 02188 #: 39409312 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Boston Motel 655 Washington Street Weymouth, MA 02188 #: 39405337 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Brady Enterprises, Inc. 167 Moore Road East Weymouth, MA 02189 #: 39002044 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Columbian Square Dental 59 Columbian Street Weymouth, MA 02190 #: 39408755 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Comfort Dental Weymouth 47 Washington Street Weymouth, MA 02188 #: 39406488 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
DaVita - Weymouth Dialysis Center 330 Libbey Industrial Parkway Suite 900 Weymouth, MA 02188 #: 39101150 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
David F. Grace, DMD 1125 Washington Street East Weymouth, MA 02189 #: 39407473 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Deluxe Family Dental Care 83 Broad Street Weymouth, MA 02188 #: 39406493 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Dental Aid 1 PC 884 Washington Street Suite 130 Weymouth, MA 02189 #: 39409173 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dentistry for Children PC 851 Main Street Suite 3 South Weymouth, MA 02190 #: 39406298 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Dr. Richard M. Nadler 94 Washington Street Suite 1 Weymouth, MA 02188 #: 39409310 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Elias Badran DDS 73 Pleasant Street Weymouth, MA 02190 #: 39406492 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
FCS Boston, Inc. dba Chemstation - Boston 96 Moore Road Weymouth, MA 02189 #: 39103307 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Great Pond Water Treatment Plant 239 Pond Street Weymouth, MA 02190 #: 39102335 Category: 02	0101	SLUDGE DISCHARGE FROM TREATMENT PLANT			No Discharge Violations			No Enforcement Actions
	Monthly	<b>Self-Monitoring</b> Arsenic (Total) Copper (Total) Lead (Total) TTO (Volatile Organic Fraction) Total Suspended Solids Zinc (Total) pH						
	0103	Sample Spigot in Maintenance Room						
	Quarterly	<b>Self-Monitoring</b> Cyanide (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
Horizon Dental 312 Bridge Street Weymouth, MA 02191 #: 39409316 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Iona Dental, PC (dba Meridian Dental Associates) 1650 Main Street Weymouth, MA 02190 #: 39406486 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Jonathan Alihosseini DMD 33 Union Street South Weymouth, MA 02190 #: 39406295 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Monahan's Marine Inc. 396 Washington Street Weymouth, MA 02188 #: 39405410 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Pauline J McDonough DDS 1355 Pleasant Street Weymouth, MA 02189 #: 39406485 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Peter J McDonald DDS 147 Pleasant Street South Weymouth, MA 02190 #: 39406294 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
QCDC Weymouth #1944 (aka Fresenius Kidney Care) 2 West Street 1 Weymouth, MA 02190 #: 39103169 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Richard E Wolfert DDS 1121 Main Street Suite 2 South Weymouth, MA 02190 #: 39406292 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
South Shore Dentistry 696 Main Street South Weymouth, MA 02190 #: 39406299 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Star Litho, Inc. 360 Libbey Industrial Parkway Weymouth, MA 02189 #: 39009317 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Stetson Dental Care 561 Main Street Weymouth, MA 02190 #: 39406491 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
T.EN Stone & Webster Process Technology, Inc. 56 Woodrock Road East Weymouth, MA 02189 #: 39001933 Category: 01	0101	Styrene unit decant water			No Discharge Violations			No Enforcement Actions
Thomas M Decoste DDS 293 Libbey Parkway Suite A-100 Weymouth, MA 02189 #: 39406487 Category: D1	Annual	Self-Monitoring TTO (Volatile Organic Fraction) pH			No Reporting Requirements	No Discharge Violations		No Enforcement Actions
US Renal Care Weymouth 587 Washington Street Weymouth, MA 02188 #: 39405398 Category: 10					No Reporting Requirements	No Discharge Violations		No Enforcement Actions
Unident Group Inc. 527 Main Street Weymouth, MA 02190 #: 39409238 Category: D1					No Reporting Requirements	No Discharge Violations		No Enforcement Actions
Vitamin Sea Brewing LLC 30 Moore Road Weymouth, MA 02189 #: 39406798 Category: 10					No Reporting Requirements	No Discharge Violations		No Enforcement Actions
Weymouth Dental Associates 130 Broad Street Weymouth, MA 02188 #: 39406484 Category: D1					No Reporting Requirements	No Discharge Violations		No Enforcement Actions
Weymouth Dentistry and Braces 35 Pleasant Street Weymouth, MA 02190 #: 39409313 Category: D1					No Reporting Requirements	No Discharge Violations		No Enforcement Actions
Weymouth Family Dental Care 1125 Washington Street Weymouth, MA 02189 #: 39406483 Category: D1					No Reporting Requirements	No Discharge Violations		No Enforcement Actions
Weymouth Smiles Dental 536 Broad Street Suite 1 Weymouth, MA 02189 #: 39406490 Category: D1					No Reporting Requirements	No Discharge Violations		No Enforcement Actions
AAE Embroidery & Screen Printing, Inc. 789 Woburn Street Unit 2 Wilmington, MA 01887 #: 40407963 Category: 10					No Reporting Requirements	No Discharge Violations		No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Advanced Imaging, Inc. 234 Ballardvale Street Wilmington, MA 01887 #: 40103659 Category: G1	0101	PHOTO	No Discharge Violations				No Enforcement Actions	
<hr/>								
Agfa Corporation 187 Ballardvale Street Wilmington, MA 01887 #: 40005698 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
<hr/>								
Analog Devices 831 Woburn Street Wilmington, MA 01887 #: 40007290 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
<hr/>								
Biondo & Foley Dental Group 188 Main Street Suite 200 Wilmington, MA 01887 #: 40406494 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
<hr/>								
Boston Gas Company dba National Grid 326 Ballardvale Street Wilmington, MA 01887 #: 40102909 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
<hr/>								
CHEP Services 1 Burlington Avenue Wilmington, MA 01887 #: 40408129 Category: 01	0101	<i>Aqua Klippa unit storage tank after filtration from the final discharge line</i>	0101	<i>Aqua Klippa unit storage tank after filtration from the final discharge line</i>		26-Oct-2021 Notice of Violation		
<hr/>								
			3-Nov-2021	Copper (Total)	1.4	mg/l	DYMX	< 1
			3-Nov-2021	Zinc (Total)	1.71	mg/l	DYMX	< 1
			4-Nov-2021	Copper (Total)	1.01	mg/l	DYMX	< 1
			4-Nov-2021	Zinc (Total)	1.67	mg/l	DYMX	< 1
			5-Nov-2021	Zinc (Total)	1.16	mg/l	DYMX	< 1
			24-Jan-2022	Zinc (Total)	2.39	mg/l	DYMX	< 1
<hr/>								
Charles River Laboratories 251 Ballardvale Street Wilmington, MA 01887 #: 40000924 Category: 02	0501	<i>standpipe on the discharge line after pH neutralization in Bldg 18</i>	1001	<i>outdoor standpipe behind Building 12</i>		28-Feb-2022 Notice of Violation		
<hr/>								
			27-Jan-2022	Copper (Total)	2.41	mg/l	DYMX	< 1
			1101	<i>spigot on the discharge line after pH neutralization in Building 22</i>				
			17-May-2022	Zinc (Total)	1.94	mg/l	DYMX	< 1

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>	<u>-----DISCHARGE VIOLATIONS-----</u>	<u>-----ENFORCEMENT ACTIONS-----</u>
	<u>Frequency</u> <u>Parameter</u>	<u>Date</u> <u>Parameter</u> <u>Result</u> <u>Limit</u>	<u>Date</u> <u>Actions</u>
	pH		
	1001 <i>outdoor standpipe behind Building 12</i>		
	<b>Semi-Annual Self-Monitoring</b>		
	Copper (Total)		
	Formaldehyde		
	Lead (Total)		
	Mercury (Total)		
	TTO (Extractable Organic Fraction)		
	TTO (Volatile Organic Fraction)		
	Zinc (Total)		
	pH		
	1101 <i>spigot on the discharge line after pH neutralization in Building 22</i>		
	<b>Semi-Annual Self-Monitoring</b>		
	Biochemical Oxygen Demand (5 Day)		
	Formaldehyde		
	TTO (Extractable Organic Fraction)		
	TTO (Volatile Organic Fraction)		
	Total Suspended Solids		
	pH		
ChemGenes Corporation 33 Industrial Way Wilmington, MA 01887 #: 40103037 Category: 10	No Reporting Requirements	No Discharge Violations	No Enforcement Actions
DJKDMD, PC 102 Lowell Street Wilmington, MA 01887 #: 40409322 Category: D1	No Reporting Requirements	No Discharge Violations	No Enforcement Actions
Deborah A Ederly DMD 299 Main Street Wilmington, MA 01887 #: 40406496 Category: D1	No Reporting Requirements	No Discharge Violations	No Enforcement Actions
Dee-Ray Inc. 919 Main Street Wilmington, MA 01887 #: 40100403 Category: 06	No Reporting Requirements	No Discharge Violations	No Enforcement Actions
Forever Family Dental PLLC 25 Lowell Street Wilmington, MA 01887 #: 40406495 Category: D1	No Reporting Requirements	No Discharge Violations	No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
HP Hood R&D 800 Research Drive Wilmington, MA 01887 #: 40102074 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Happy Sunny Dental LLC dba Smile Life Dental 211 Lowell Street Unit K Wilmington, MA 01887 #: 40409321 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Kirkwood Printing Company, Inc. 904 Main Street Wilmington, MA 01887 #: 40006245 Category: G1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
MKS Instruments, Inc. 90 Industrial Way Wilmington, MA 01887 #: 40102397 Category: O2	0101	<i>pH neutralization system discharge line</i>			No Discharge Violations			No Enforcement Actions
	Quarterly	<b>Self-Monitoring</b> Copper (Total) Zinc (Total) pH						
	0102	<i>Spigot on sump tank discharge line</i>						
		<b>Semi-Annual Self-Monitoring</b> Aluminum Chromium (Total) Copper (Total) Nickel (Total) Zinc (Total) pH						
Monogram Gourmet Foods, LLC (301 Ballardvale) 301 Ballardvale Street Wilmington, MA 01887 #: 40407227 Category: G2		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
New England Dental Group - Wilmington 206 Ballardvale Street Wilmington, MA 01887 #: 40409323 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Screenprint/Dow 200 Research Drive Wilmington, MA 01887 #: 40101635 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Silver Lake Dental 96 Main Street Wilmington, MA 01887 #: 40406498 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Smyth Companies LLC-The Dow Division 271 Ballardvale Street Wilmington, MA 01887 #: 40005632 Category: 02	0104	SCREENPRINT AREA			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Copper (Total)						
		Lead (Total)						
		Nickel (Total)						
		Silver (Total)						
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Warner Babcock Institute for Green Chemistry 100 Research Drive Wilmington, MA 01887 #: 40103623 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Wilmington Dental Studio 230 Lowell Street Suite 1E Wilmington, MA 01887 #: 40409320 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Xenon Corporation 37 Upton Drive Wilmington, MA 01887 #: 40103386 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Elene Avgherinos DDS 576 Main Street Winchester, MA 01890 #: 41406504 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Fiorillo Dentistry 955 Main Street Suite 205 Winchester, MA 01890 #: 41406509 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Janis Moriarty DMD 607 Main Street Winchester, MA 01890 #: 41406505 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Middlesex Endodontics 47 Shore Road Suite 2 Winchester, MA 01890 #: 41406502 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Nabil R Ibrahim DDS, PLLC 10 Converse Place Suite 102 Winchester, MA 01890 #: 41406499 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Pablo Bella Dental 259 Swanton Street Winchester, MA 01890 #: 41406501 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Russell Hill Dental PC 955 Main Street Suite 201 Winchester, MA 01890 #: 41406510 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Smile Boutique 49 Church Street Winchester, MA 01890 #: 41406503 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Thomas Russo DDS 63 Shore Road Suite 13 Winchester, MA 01890 #: 41406506 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
U.S. Food and Drug Administration 109 Holton Street Winchester, MA 01890 #: 41003788 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Weston P Wilson DDS 78 Church Street Winchester, MA 01890 #: 41406507 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Winchester Hospital 41 Highland Avenue Winchester, MA 01890 #: 41005764 Category: 02	0102	<i>Equalization tank for Central Material Services</i>			No Discharge Violations			No Enforcement Actions
		<b>Semi-Annual Self-Monitoring</b>						
		Copper (Total)						
		Zinc (Total)						
		pH						
	0106	<i>Sampling spigot on limestone chip tank discharge line</i>						
		<b>Semi-Annual Self-Monitoring</b>						
		Copper (Total)						
		Mercury (Total)						
		TTO (Volatile Organic Fraction)						
		Zinc (Total)						
		pH						
Winchester Water Treatment Plant 345 S Border Road Winchester, MA 01890 #: 41103460 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Winchester and Reading Pediatric Dentistry LLC 955 Main Street Suite 101/102 Winchester, MA 01890 #: 41406508 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
AP Dental Center 113 Revere Street Suite 1 Winthrop, MA 02152 #: 42406511 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Brooks Dental 54 Woodside Avenue Winthrop, MA 02152 #: 42406309 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Harborside Dental 313 Main Street Winthrop, MA 02152 #: 42406514 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Varinos Dental Associates of Winthrop PC 155 Veterans Road Winthrop, MA 02152 #: 42406512 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
Winthrop Dental 249 Washington Avenue Winthrop, MA 02152 #: 42406513 Category: D1	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
3-D Matrix, Inc. 25 -K Olympia Avenue Suite 600 Woburn, MA 01801 #: 43404097 Category: 10	No Reporting Requirements		No Discharge Violations				No Enforcement Actions	
AKE - MA Region #20, LLC 19 Presidential Way Woburn, MA 01801 #: 43404639 Category: 02	0101	pH ADJUSTMENT SYSTEM OUTLET	0101	pH ADJUSTMENT SYSTEM OUTLET			14-Mar-2022	Notice of Violation
	<b>Semi-Annual</b>	<b>Self-Monitoring</b>	16-Feb-2022	Formaldehyde	20.2	mg/l	DYMX	< 9
		Antimony (Total)	16-Feb-2022	Cyanide (Total)	3.7	mg/l	DYMX	< 0.5
		Arsenic (Total)	11-May-2022	Formaldehyde	19	mg/l	DYMX	< 9
		Cadmium (Total)						
		Chromium (+6)						
		Chromium (Total)						
		Copper (Total)						
		Cyanide (Total)						
		Formaldehyde						
		Lead (Total)						
		Mercury (Total)						
		Nickel (Total)						
		Oil and Grease						
		Selenium (Total)						

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
		Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH						
Advanced Dentistry LLC 65 Pleasant Street Woburn, MA 01801 #: 43406322 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Agape Dentist 576 Main Street Woburn, MA 01801 #: 43406318 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Agrivida Inc. 78 E Olympia Avenue Woburn, MA 01801 #: 43103617 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Air Liquide - Advanced Technologies LLC 35 A Cabot Road Woburn, MA 01801 #: 43103321 Category: 02	0101	Area sink located in the Extrusion Lab  <b>Semi-Annual Self-Monitoring</b> TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH			No Discharge Violations			No Enforcement Actions
	0102	Discharge line of area sink limestone chip tank in Fiber Rinsing Area  <b>Semi-Annual Self-Monitoring</b> TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
	0103	Area sink located in Coating Area  <b>Semi-Annual Self-Monitoring</b> TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) pH						
Alden-Hauk, Inc. 215 Salem Street Unit G Woburn, MA 01801 #: 43102113 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Alsym Energy 82 Cummings Park Woburn, MA 01801 #: 43408680 Category: 02	0101	Wastewater from the holding tank and lab sink  <b>Semi-Annual Self-Monitoring</b> Cadmium (Total) Chromium (Total) Copper (Total)			No Discharge Violations		09-Sep-2021	Notice of Violation

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Anagenex 10 -N Roessler Road Woburn, MA 01801 #: 43409179 Category: 10		Lead (Total) Mercury (Total) Nickel (Total) Oil and Grease Silver (Total) TTO (Extractable Organic Fraction) TTO (Volatile Organic Fraction) Zinc (Total) pH	No Reporting Requirements		No Discharge Violations			No Enforcement Actions
Apex Photo Lab 223 Main Street Woburn, MA 01801 #: 43101784 Category: G1	0101 Annual	PHOTO Self-Monitoring Silver (Total)			No Discharge Violations			No Enforcement Actions
Aphios Corporation 3 -E Gill Street Woburn, MA 01801 #: 43100248 Category: 10			No Reporting Requirements		No Discharge Violations			No Enforcement Actions
Aspen Dental 3 Elm Street Woburn, MA 01801 #: 43406316 Category: D1			No Reporting Requirements		No Discharge Violations			No Enforcement Actions
Aspentl Health 57 Commerce Way Woburn, MA 01801 #: 43405385 Category: 10			No Reporting Requirements		No Discharge Violations			No Enforcement Actions
Azurity Pharmaceuticals 8 Cabot Road Suite 3000 Woburn, MA 01801 #: 43405053 Category: 10			No Reporting Requirements		No Discharge Violations			No Enforcement Actions
BD Interventional Surgery Group 160 New Boston Street Woburn, MA 01801 #: 43100484 Category: 02	0103 Semi-Annual	Equipment cleaning from Avitene manufacturing process Self-Monitoring Oil and Grease pH			No Discharge Violations			No Enforcement Actions
Best Western Plus New Englander 1 Rainin Road Woburn, MA 01801 #: 43101878 Category: 02	0101 Semi-Annual	LAUNDRY ROOM Self-Monitoring Copper (Total) Lead (Total) Mercury (Total)			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Boston Electrometallurgical Corp. 6 -C Gill Street Woburn, MA 01801 #: 43406952 Category: 10	No Reporting Requirements	Oil and Grease Zinc (Total) pH						No Enforcement Actions
Brannen Brothers Flutemakers, Inc. 58 Dragon Court Woburn, MA 01801 #: 43100193 Category: 10	No Reporting Requirements							No Enforcement Actions
CONTINUOUS Pharmaceuticals, Inc. 256 W Cummings Park Woburn, MA 01801 #: 43409198 Category: 10	No Reporting Requirements							No Enforcement Actions
CSM CY Woburn, LLC dba Courtyard by Marriott - Woburn 700 Unicorn Park Drive Woburn, MA 01801 #: 43404614 Category: 02	0101 Laundry Room  <b>Semi-Annual Self-Monitoring</b> Copper (Total) Lead (Total) Mercury (Total) Oil and Grease Zinc (Total) pH						08-Mar-2022 Notice of Violation	
Cambridge Polymer Group, Inc. 100 Trade Center Drive Suite 200 & 150 Woburn, MA 01801 #: 43403813 Category: 10	No Reporting Requirements							No Enforcement Actions
Cardone Family Dental 800 West Cummings Park Suite 1050 Woburn, MA 01801 #: 43406324 Category: D1	No Reporting Requirements							No Enforcement Actions
Comfort Inn Boston/Woburn 14 Hill Street Woburn, MA 01801 #: 43404753 Category: 02	0101 LAUNDRY ROOM  <b>Semi-Annual Self-Monitoring</b> Copper (Total) Lead (Total) Mercury (Total) Oil and Grease Zinc (Total) pH							No Enforcement Actions
Connolly Printing, LLC 17 -B Gill Street Woburn, MA 01801 #: 43403800 Category: 10	No Reporting Requirements							No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Courtyard By Marriott 240 Mishawum Road Woburn, MA 01801 #: 43101815 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Covaris, Inc. 14 Gill Street Unit H Woburn, MA 01801 #: 43404152 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Crowne Plaza Boston-Woburn 15 Middlesex Canal Park Road Woburn, MA 01801 #: 43101822 Category: 02	0101	LAUNDRY ROOM  Semi-Annual Self-Monitoring Oil and Grease pH			No Discharge Violations			No Enforcement Actions
DaVita Dialysis - Woburn 23 Warren Avenue Suite 195 Woburn, MA 01801 #: 43103330 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dental Healthcare of Woburn PC 90 Pleasant Street Woburn, MA 01801 #: 43406325 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Dentology 444 Washington Street Suite 301 Woburn, MA 01801 #: 43407984 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Discovery Life Sciences, LLC 6 Henshaw Street Woburn, MA 01801 #: 43102759 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
E.V. Yeuell, Inc. 17 Gill Street Woburn, MA 01801 #: 43005201 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Edward Canniff DDS 186 Cambridge Road Suite 12 Woburn, MA 01801 #: 43406312 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
ElectroChem, Inc. 400 W Cummings Park Suite 5600 Woburn, MA 01801 #: 43101774 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Epic Technologies Inc. 500 W Cummings Park Suite 6950 Woburn, MA 01801 #: 43101471 Category: 01	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
F T Dental Corp 444 Washington Street Suite 312 Woburn, MA 01801 #: 43406317 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Fairfield Inn Woburn 285 Mishawum Road Woburn, MA 01801 #: 43101816 Category: 02	0101	<i>Flume on discharge line of washers</i>			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		Copper (Total)						
		Lead (Total)						
		Mercury (Total)						
		Oil and Grease						
		Zinc (Total)						
		pH						
Fanikos Salib Dental Associates 7 Alfred Street Suite 125 Woburn, MA 01801 #: 43406323 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Four Corners Dental Care 237 Lexington Street Suite 210 Woburn, MA 01801 #: 43406313 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gentle Dental Woburn 474 Main Street Woburn, MA 01801 #: 43409271 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Genturi, Inc. 8 Cabot Road Suite 3400&4400 Woburn, MA 01801 #: 43405106 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Glycosyn LLC 6 -H Gill Street Woburn, MA 01801 #: 43404785 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Gradient Corporation 11 Sixth Road Unit C Woburn, MA 01801 #: 43404254 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

INDUSTRY	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Hannaford - Dumas Corporation 26 Conn Street Woburn, MA 01801 #: 43103347 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Hela Novel Metals 150 New Boston Street Suite A Woburn, MA 01801 #: 43407668 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Insultab, Inc. 45 Industrial Parkway Woburn, MA 01801 #: 43000746 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Ionic Materials 10 -L Commerce Way Woburn, MA 01801 #: 43403915 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Joseph G. DiTullio DMD 8 Cedar Street Suite 41 Woburn, MA 01801 #: 43409230 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Joseph's Catering Inc. 30 Torrice Drive Woburn, MA 01801 #: 43409231 Category: G2	No Reporting Requirements				No Discharge Violations		14-Feb-2022 Notice of Noncompliance	
Kayem Foods 14 Industrial Park Woburn, MA 01801 #: 43101035 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
KemLab 254 W Cummings Park Woburn, MA 01801 #: 43404151 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
L.E.A.F. Pharmaceuticals 10 -R Gill Street Woburn, MA 01801 #: 43406519 Category: 02	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Lord Hobo Brewing Company LLC 5 Draper Street Woburn, MA 01801 #: 43404515 Category: G2	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Luminus Devices, Inc. 175 New Boston Street Suite X Woburn, MA 01801 #: 43103195 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
MRL Inc. 160 New Boston Street Woburn, MA 01801 #: 43404185 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
McCall Family Dental 14 Winn Street Woburn, MA 01801 #: 43406311 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Medtronic dba Covidien LP 12 Gill Street Suite 3500 Woburn, MA 01801 #: 43403369 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Modular Genetics, Inc. 12 -T Cabot Road Woburn, MA 01801 #: 43403450 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Myriant Corporation 66 Cummings Park Woburn, MA 01801 #: 43103695 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Nanoimaging Services 4 Gill Street Suite C Woburn, MA 01801 #: 43408337 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Novatein BioSciences 310 W Cummings Park Woburn, MA 01801 #: 43404081 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
OPKO Diagnostics LLC 4 Constitution Way Suite E, F & G Woburn, MA 01801 #: 43103581 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Optowares, Inc. 15 Presidential Way Woburn, MA 01801 #: 43409170 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions



# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Organix Chemistry Solutions LLC 240 Salem Street Woburn, MA 01801 #: 43101987 Category: 02	0102	Discharge Line After pH Adjustment Tank			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b>							
		TTO (Extractable Organic Fraction)						
		TTO (Volatile Organic Fraction)						
		pH						
PKC Pharmaceuticals, Inc. 165 -T New Boston Street Woburn, MA 01801 #: 43005939 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Paul J Lennon DDS 620 Main Street Woburn, MA 01801 #: 43406320 Category: D1		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Phoenix Tailings, Inc. 8 -B Henshaw Avenue Woburn, MA 01801 #: 43408243 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Practical Applications, Inc. 8 Adele Road Woburn, MA 01801 #: 43102504 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
ProScience Analytical Services, Inc. 22 Cummings Park Drive Woburn, MA 01801 #: 43404401 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Purinomia Biotech Inc. 2 -E Gill Street Woburn, MA 01801 #: 43407679 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Quad Technologies, Inc. 175 New Boston Street Suite H Woburn, MA 01801 #: 43407673 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
Quad/Graphics Commercial & Specialty, LLC 110 Commerce Way Building J Woburn, MA 01801 #: 43404380 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions
ReForm Biologics LLC 12 Gill Street Suite 4650 Woburn, MA 01801 #: 43404852 Category: 10		No Reporting Requirements			No Discharge Violations			No Enforcement Actions

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<b>INDUSTRY</b>	-----CURRENT SAMPLING REQUIREMENTS-----		-----DISCHARGE VIOLATIONS-----				-----ENFORCEMENT ACTIONS-----	
	Frequency	Parameter	Date	Parameter	Result	Limit	Date	Actions
Red Roof Inn #10238 19 Commerce Way Woburn, MA 01801 #: 43101814 Category: 02	0101	LAUNDRY ROOM			No Discharge Violations			No Enforcement Actions
	<b>Semi-Annual Self-Monitoring</b> Copper (Total) Lead (Total) Mercury (Total) Oil and Grease Zinc (Total) pH							
Residence Inn by Marriott 300 Presidential Way Woburn, MA 01801 #: 43404861 Category: 10		No Reporting Requirements			No Discharge Violations		04-Aug-2021 Notice of Violation	
Rohtstein Corporation 70 Olympia Avenue Woburn, MA 01801 #: 43000378 Category: G2		No Reporting Requirements			No Discharge Violations		No Enforcement Actions	
Ryan M Clancy DMD PC 358 Cambridge Road Woburn, MA 01801 #: 43406062 Category: D1		No Reporting Requirements			No Discharge Violations		No Enforcement Actions	
Signal Communications Corporation 4 Wheeling Avenue Woburn, MA 01801 #: 43101480 Category: 10		No Reporting Requirements			No Discharge Violations		No Enforcement Actions	
Solid Energy Systems, Inc. 35 -B Cabot Road Woburn, MA 01801 #: 43405119 Category: 10		No Reporting Requirements			No Discharge Violations		No Enforcement Actions	
Something Sweet Without Wheat 19 Sixth Road Woburn, MA 01801 #: 43404233 Category: G2		No Reporting Requirements			No Discharge Violations		No Enforcement Actions	
The Throne Depot 25 Republic Road North Billerica, MA 01862 #: 43403481 Category: 06		No Reporting Requirements			No Discharge Violations		No Enforcement Actions	
True World Foods Boston LLC 242 Salem Street Woburn, MA 01801 #: 43103002 Category: G2		No Reporting Requirements			No Discharge Violations		No Enforcement Actions	

# Non-SIU Sampling Requirements and Discharge Violations

Between Dates 07/01/2021 and 06/30/2022

<u>INDUSTRY</u>	<u>-----CURRENT SAMPLING REQUIREMENTS-----</u>		<u>-----DISCHARGE VIOLATIONS-----</u>				<u>-----ENFORCEMENT ACTIONS-----</u>	
	<u>Frequency</u>	<u>Parameter</u>	<u>Date</u>	<u>Parameter</u>	<u>Result</u>	<u>Limit</u>	<u>Date</u>	<u>Actions</u>
Verdox Inc. 1 -B Gill Street Woburn, MA 01801 #: 43408453 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Water Chemicals, Inc. 64 Cummings Park Woburn, MA 01801 #: 43000402 Category: 10	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Woburn Dental Associates 26 Warren Avenue Woburn, MA 01801 #: 43406314 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Woburn Dental Group, PC 109 Montvale Avenue Woburn, MA 01801 #: 43406310 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions
Woburn Family Dental 578 Main Street Woburn, MA 01801 #: 43406319 Category: D1	No Reporting Requirements				No Discharge Violations			No Enforcement Actions

# Appendix C

## Significant Industrial Users In Significant Noncompliance

## Summary of Industries in SNC for Violations

Between 04/01/2021 and 06/30/2022

SIU Status: Y

### Bedford

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
03403799	Y	Entegris, Inc.	1-Jul-21 31-Dec-21	B	B. Discharge - TRC Violation - 33% +
03103123	Y	Thermo Fisher Scientific	1-Jan-22 30-Jun-22	B	B. Discharge - TRC Violation - 33% +

### Boston (Dwntn)

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
45006015	Y	Boston University Medical Campus	1-Apr-21 30-Sep-21	B	B. Discharge - TRC Violation - 33% +
45005701	Y	Dana-Farber Cancer Institute	1-Apr-21 30-Sep-21	B	B. Discharge - TRC Violation - 33% +
			1-Jul-21 31-Dec-21	A	A. Discharge - Chronic Violation - 66% +
				B	B. Discharge - TRC Violation - 33% +
			1-Oct-21 31-Mar-22	F3	F3. Reporting - Self-Monitoring SNC Late or Missing
				B	B. Discharge - TRC Violation - 33% +
				F3	F3. Reporting - Self-Monitoring SNC Late or Missing
45005962	Y	Harvard University - Longwood Campus	1-Apr-21 30-Sep-21	A	A. Discharge - Chronic Violation - 66% +
				B	B. Discharge - TRC Violation - 33% +
45004837	Y	Northeastern University	1-Apr-21 30-Sep-21	B	B. Discharge - TRC Violation - 33% +
			1-Oct-21 31-Mar-22	A	A. Discharge - Chronic Violation - 66% +
				B	B. Discharge - TRC Violation - 33% +
45004825	Y	Trustees of Boston University-Charles River Campus	1-Jan-22 30-Jun-22	A	A. Discharge - Chronic Violation - 66% +
				B	B. Discharge - TRC Violation - 33% +
45005753	Y	Tufts Medical Center	1-Jul-21 31-Dec-21	F3	F3. Reporting - Self-Monitoring SNC Late or Missing

### Braintree

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
06000958	Y	Symmons Industries, Inc.	1-Oct-21 31-Mar-22	A	A. Discharge - Chronic Violation - 66% +
				B	B. Discharge - TRC Violation - 33% +
			1-Jan-22 30-Jun-22	A	A. Discharge - Chronic Violation - 66% +
				B	B. Discharge - TRC Violation - 33% +

## Summary of Industries in SNC for Violations

Between 04/01/2021 and 06/30/2022

SIU Status: Y

### Brookline

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
07101154	Y	MBTA Reservoir Carhouse	1-Jul-21 31-Dec-21	A B	A. Discharge - Chronic Violation - 66% + B. Discharge - TRC Violation - 33% +

### Cambridge

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
09101756	Y	ARE - 300 Tech Square	1-Oct-21 31-Mar-22	B	B. Discharge - TRC Violation - 33% +
09101193	Y	Biogen, Inc.	1-Oct-21 31-Mar-22	B	B. Discharge - TRC Violation - 33% +
			1-Jan-22 30-Jun-22	B	B. Discharge - TRC Violation - 33% +
09003755	Y	Harvard University - Cambridge Campus	1-Oct-21 31-Mar-22	A B	A. Discharge - Chronic Violation - 66% + B. Discharge - TRC Violation - 33% +
			1-Jan-22 30-Jun-22	B	B. Discharge - TRC Violation - 33% +
09003259	Y	Massachusetts Institute of Technology (MIT)	1-Apr-21 30-Sep-21	A B	A. Discharge - Chronic Violation - 66% + B. Discharge - TRC Violation - 33% +
			1-Jul-21 31-Dec-21	A B	A. Discharge - Chronic Violation - 66% + B. Discharge - TRC Violation - 33% +
			1-Oct-21 31-Mar-22	A	A. Discharge - Chronic Violation - 66% +
09001132	Y	The Charles Stark Draper Laboratory, Inc.	1-Jan-22 30-Jun-22	A B	A. Discharge - Chronic Violation - 66% + B. Discharge - TRC Violation - 33% +

### Holbrook

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
16100468	Y	Preferred Services Company, Inc.	1-Jul-21 31-Dec-21	F3	F3. Reporting - Self-Monitoring SNC Late or Missing

### Jamaica Plain

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
--------------------	------------	----------------------	---------------	------------	------------------

## Summary of Industries in SNC for Violations

Between 04/01/2021 and 06/30/2022

SIU Status: Y

### Jamaica Plain

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
51006016	Y	Commonwealth of Massachusetts Department of Public Health	1-Jan-22 30-Jun-22	B	B. Discharge - TRC Violation - 33% +
51005733	Y	VA Boston Healthcare System - Jamaica Plain	1-Jul-21 31-Dec-21	B	B. Discharge - TRC Violation - 33% +
			1-Oct-21 31-Mar-22	B	B. Discharge - TRC Violation - 33% +
			1-Jan-22 30-Jun-22	F3	F3. Reporting - Self-Monitoring SNC Late or Missing
				B	B. Discharge - TRC Violation - 33% +

### Milton

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
21006031	Y	Beth Israel Deaconess Hospital-Milton Inc.	1-Apr-21 30-Sep-21	B	B. Discharge - TRC Violation - 33% +
			1-Jul-21 31-Dec-21	B	B. Discharge - TRC Violation - 33% +
			1-Oct-21 31-Mar-22	A	A. Discharge - Chronic Violation - 66% +
				B	B. Discharge - TRC Violation - 33% +

### Norwood

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
25100244	Y	Absolute Metal Finishing, Inc.	1-Apr-21 30-Sep-21	F3	F3. Reporting - Self-Monitoring SNC Late or Missing
25101050	Y	Goldman Kolber, LLC (GK Jewelry Inc.)	1-Apr-21 30-Sep-21	F3	F3. Reporting - Self-Monitoring SNC Late or Missing
			1-Oct-21 31-Mar-22	F3	F3. Reporting - Self-Monitoring SNC Late or Missing

### South Boston

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
55008794	Y	Massachusetts Department of Transportation (Ted W VB #6)	1-Jul-21 31-Dec-21	A	A. Discharge - Chronic Violation - 66% +
			1-Oct-21 31-Mar-22	B	B. Discharge - TRC Violation - 33% +
				A	A. Discharge - Chronic Violation - 66% +

## Summary of Industries in SNC for Violations

Between 04/01/2021 and 06/30/2022

SIU Status: Y

### South Boston

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
				B	B. Discharge - TRC Violation - 33% +

### Waltham

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
35004157	Y	Giner, Inc.	1-Jan-22 30-Jun-22	B	B. Discharge - TRC Violation - 33% +
35004626	Y	Light Metal Platers LLC	1-Apr-21 30-Sep-21	B	B. Discharge - TRC Violation - 33% +
35006361	Y	Nova Biomedical Corporation	1-Oct-21 31-Mar-22	B	B. Discharge - TRC Violation - 33% +
				F3	F3. Reporting - Self-Monitoring SNC Late or Missing
			1-Jan-22 30-Jun-22	B	B. Discharge - TRC Violation - 33% +

### West Roxbury

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
56005702	Y	VA Boston Healthcare System	1-Apr-21 30-Sep-21	B	B. Discharge - TRC Violation - 33% +

### Westwood

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
38101644	Y	Romanow Container	1-Oct-21 31-Mar-22	B	B. Discharge - TRC Violation - 33% +

### Wilmington

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>	<u>SNC</u>	<u>Violation</u>
40404506	Y	Conformis, Inc.	1-Apr-21 30-Sep-21	F1	F1. Reporting - Baseline Monitoring
				F2	F2. Reporting - 90 Day Compliance



## Summary of Industries in SNC for Violations

Between 04/01/2021 and 06/30/2022

SIU Status: Y

### Woburn

<u>Facility ID</u>	<u>SIU</u>	<u>Industry Name</u>	<u>Period</u>		<u>SNC</u>	<u>Violation</u>
43406797	Y	Abiomed Inc	1-Apr-21	30-Sep-21	F3	F3. Reporting - Self-Monitoring SNC Late or Missing
43005100	Y	Ultra Electronics	1-Oct-21	31-Mar-22	F3	F3. Reporting - Self-Monitoring SNC Late or Missing

---

SNC A Count:	<b>15</b>
SNC B Count:	<b>36</b>
SNC E Count:	<b>0</b>
SNC F Count:	<b>13</b>
SNC H Count:	<b>0</b>

## Appendix D

### Former Significant Industrial Users

## SIU's In Previous Fiscal Year

These Industries Were SIU's in FY 2021 But Not in FY 2022

<u>FACILITY</u>	<u>IND_NAME</u>	<u>Address</u>	<u>Reason Deleted</u>
45006784	USDA Human Nutrition Research Center	711 Washington Street Boston, MA 02111	Co. achieved compliance
06404646	Atlas High Purity Solutions, LLC	100 Messina Drive Suite 105 Braintree, MA 02184	Co. achieved compliance
09005730	Cambridge Health Alliance - Cambridge Hospital	1493 Cambridge Street Cambridge, MA 02139	Co. achieved compliance
11103361	Peter Pan Bus Lines	333 Third Street Chelsea, MA 02150	Co. achieved compliance
18005041	Hopwood Globe LLC	303 Commercial Street Malden, MA 02148	OOB
22005741	Metrowest Medical Center - Leonard Morse Hospital	67 Union Street Natick, MA 01760	Ceased discharge
23100233	Celldex Therapeutics, Inc.	119 Fourth Avenue Needham, MA 02494	OOB
55103189	Legal Sea Foods, Inc.	One Seafood Way South Boston, MA 02210	OOB
32005369	Honorcraft, LLC	292 A Page Street Stoughton, MA 02072	OOB
43101471	Epic Technologies Inc.	500 W Cummings Park Suite 6950 Woburn, MA 01801	OOB

# Appendix E

## Gas/Oil Separator Warning Letters



## TRAPS Enforcement Actions Between Dates

Enforcement Actions Between 7/1/2021 6/30/2022

### Arlington

<u>Municipality</u>	<u>Industry Name</u>	<u>Address</u>	<u>Facility ID</u>	<u>Enforcement Type</u>	<u>Violation Date*</u>
Arlington	Valvoline Instant Oil Change	82 Mystic Street	01302054	WARN	09/15/2021
Arlington	Safelite Auto Glass	94 Massachusetts Avenue	01300049	WARN	01/28/2022

### Ashland

<u>Municipality</u>	<u>Industry Name</u>	<u>Address</u>	<u>Facility ID</u>	<u>Enforcement Type</u>	<u>Violation Date*</u>
Ashland	Monro Muffler	311 Elliot Street	02401347	WARN	02/07/2022
Ashland	Powertune	15 Alden Street	02302420	WARN	02/16/2022
Ashland	LF, LLC - 87 Nickerson Rd.	87 Nickerson Road	02405387	WARN	02/18/2022
Ashland	LF,LLC - 83 Nickerson Rd.	83 Nickerson Road	02404663	WARN	02/18/2022

### Belmont

<u>Municipality</u>	<u>Industry Name</u>	<u>Address</u>	<u>Facility ID</u>	<u>Enforcement Type</u>	<u>Violation Date*</u>
Belmont	F & M Investment Enterprises LLC	40 Brighton Street	04404186	WARN	10/05/2021

### Braintree

<u>Municipality</u>	<u>Industry Name</u>	<u>Address</u>	<u>Facility ID</u>	<u>Enforcement Type</u>	<u>Violation Date*</u>
Braintree	Oars Enterprises, LLC	10 Rex Drive	06300181	WARN	08/24/2021
Braintree	Jiffy Lube	504 Quincy Avenue	06300180	WARN	09/07/2021

## Burlington

<u>Municipality</u>	<u>Industry Name</u>	<u>Address</u>	<u>Facility ID</u>	<u>Enforcement Type</u>	<u>Violation Date*</u>
Burlington	4 Burlington Woods Drive	4 Burlington Woods Drive	08404433	WARN	09/07/2021

## Everett

<u>Municipality</u>	<u>Industry Name</u>	<u>Address</u>	<u>Facility ID</u>	<u>Enforcement Type</u>	<u>Violation Date*</u>
Everett	DPV Transportation	383 Second Street	13407906	WARN	02/24/2022
Everett	Everett Public Works	19 Norman Street	13403789	WARN	02/24/2022

## Framingham

<u>Municipality</u>	<u>Industry Name</u>	<u>Address</u>	<u>Facility ID</u>	<u>Enforcement Type</u>	<u>Violation Date*</u>
Framingham	Framingham Gulf Auto Service	1287 Worcester Road	14300628	WARN	02/22/2022
Framingham	MGM Auto Body/Igor's Auto Shop	232 Rear Hollis Street	14300575	WARN	02/23/2022
Framingham	Aoude Gulf	655 Waverly Street	14300599	WARN	02/28/2022
Framingham	Fast Stop Auto Service	91 Grant Street	14300573	WARN	03/09/2022
Framingham	A.L. Prime Energy Con. Inc.	1115 Worcester Road	14300623	WARN	03/16/2022
Framingham	Shell	543 Old Connecticut Path	14300583	WARN	03/16/2022
Framingham	Tommy's Taxi Co.	167 Franklin Street	14300569	WARN	03/31/2022

## Melrose

<u>Municipality</u>	<u>Industry Name</u>	<u>Address</u>	<u>Facility ID</u>	<u>Enforcement Type</u>	<u>Violation Date*</u>
Melrose	Windsor at Oak Grove Village	12 Island Hill Avenue	20402798	WARN	12/13/2021

## Quincy

<u>Municipality</u>	<u>Industry Name</u>	<u>Address</u>	<u>Facility ID</u>	<u>Enforcement Type</u>	<u>Violation Date*</u>
Quincy	68 Beale Street Apartments	68 Beale Street	26404465	WARN	08/16/2021
Quincy	Quincy Fire Station 8	140 Doane Street	26301291	WARN	08/17/2021

Quincy	Quincy Fire Station Engine 7	86 Huckins Avenue	26301309	WARN	08/17/2021
Quincy	Quincy Fire Station #2	311 Hancock Street	26301297	WARN	08/17/2021
Quincy	Elevation Apartments at Crown Colony	7 Crown Drive	26405126	WARN	08/23/2021
Quincy	Avalon Bay Communities	217 Quarry Street	26404637	WARN	08/25/2021
Quincy	Blue Cross Blue Shield of Massachusetts	1 Enterprise Drive	26402750	WARN	11/05/2021

## Randolph

<u>Municipality</u>	<u>Industry Name</u>	<u>Address</u>	<u>Facility ID</u>	<u>Enforcement Type</u>	<u>Violation Date*</u>
Randolph	Randolph Center Auto	328 N Main Street	27300885	WARN	09/14/2021
Randolph	A & G Auto Care LLC	870 N Main Street	27300889	WARN	09/14/2021
Randolph	Dattco	86 York Avenue	27300901	WARN	09/28/2021
Randolph	L&W Auto Body	536 S Main Street	27300899	WARN	09/28/2021
Randolph	Energy North	93 Mazzeo Drive	27300882	WARN	10/05/2021
Randolph	AutoTuner	146 S Main Street	27403254	WARN	10/06/2021
Randolph	Jiffy Lube	26 Warren Street	27401653	WARN	10/25/2021

## Reading

<u>Municipality</u>	<u>Industry Name</u>	<u>Address</u>	<u>Facility ID</u>	<u>Enforcement Type</u>	<u>Violation Date*</u>
Reading	Auto Body Clinic	17 High Street	28400251	WARN	10/19/2021
Reading	Prime Honda 128	88 Walkers Brook Drive	28402621	WARN	10/20/2021
Reading	Reading Square Service	749 Main Street	28401151	WARN	10/26/2021
Reading	Reading Commons	7 Archstone Circle	28402766	WARN	10/26/2021
Reading	Reading Petroleum	431 Main Street	28400256	WARN	11/02/2021
Reading	Reading Woods Condominiums	55 Jacob Way	28403771	WARN	12/22/2021

## Westwood

<u>Municipality</u>	<u>Industry Name</u>	<u>Address</u>	<u>Facility ID</u>	<u>Enforcement Type</u>	<u>Violation Date*</u>
Westwood	Shell Service Station	394 Providence Highway	38301700	WARN	11/16/2021
Westwood	Ira Mazda	420 Providence Highway	38402821	WARN	11/17/2021

Westwood	Fox Hill Village Condos)	10 Longwood Drive	38301696	WARN	11/23/2021
Westwood	Gables University Station	85 University Avenue	38404320	WARN	12/17/2021

Weymouth

<u>Municipality</u>	<u>Industry Name</u>	<u>Address</u>	<u>Facility ID</u>	<u>Enforcement Type</u>	<u>Violation Date*</u>
Weymouth	548 East Street, Weymouth MA	548 East Street	39402557	WARN	03/30/2022

**Data Source:**

Data Entry	07/01/2021
Data Entry	06/30/2022

\* Traps warning letters for the above FY22 violation dates were issued in FY23

Appendix E



# Appendix F

## Penalties Assessed and Collected

# Penalties Assessed and Collected

Between 7/1/2021 and 6/30/2022

<b>SIU</b>			<u>Amount</u>	<u>Amount</u>
<u>Facility ID</u>	<u>Company</u>	<u>Municipality</u>	<u>Assessed</u>	<u>Collected</u>
			<b>Totals:</b>	<b>0</b>
<b>Non-SIU</b>			<u>Amount</u>	<u>Amount</u>
<u>Facility ID</u>	<u>Company</u>	<u>Municipality</u>	<u>Assessed</u>	<u>Collected</u>
06404931	Extended Stay America #1029	Braintree	\$20,000.00	
			<b>Totals:</b>	<b>\$20,000.00</b>
<b>Combined SIU &amp; Non-SIU Totals:</b>			<b>\$20,000.00</b>	

Appendix G

TRAC Staff

## TRAC Staff June 2022

### Director's Office

Dam Johnson	Matthew Kenneth	Director, TRAC Admin Coordinator
-------------	--------------------	-------------------------------------

### Field Operations & Permitting

Yarossi	Peter	Senior Program Manager
McKenna	Kevin	Project Manager
Francesconi	Ralph	Project Manager
Burns	Richard	Sr. Field Inspector, PC&PS
Salamone	Angelo	Sr. Field Inspector, Water/Wastewater
McCarty	John	General Construction Inspector
Donlon	Sean	Field Inspector, Water/Wastewater

### Enforcement/MIS

McGrath	Tracy	Senior Program Manager, Compliance
Halloran	Thomas	Project Manager, PIMS
McMann	Monica	Compliance Coordinator
Coughlin	William	Compliance Coordinator
Capraro	Dennis	Compliance Coordinator
Gerade	Scott	Compliance Coordinator
Meggison	Tori	Data Management Supervisor
Whyte	Jean	Administrative Systems Coordinator
Lanza	Chris	Records Coordinator

### Inspections/Permitting

Pierre-Louis	Alix	Program Manager, Inspections and Permitting
Thomas	Kattia	Project Manager, Permitting
Schultz	Walter	Project Manager, Inspections
Quercio	Michael	Source Coordinator
Mattison	Lanna	Regional Inspector
Bezza	Chris	Regional Inspector
Buczko	Stephen	Industrial Coordinator
Heckmann	Timothy	Industrial Coordinator
Chapman	Lisa	Industrial Coordinator
Cunningham	Kenneth	Industrial Coordinator
Johnson	Emily	Industrial Coordinator
Riley	George	Industrial Coordinator
Mallon	Alexandria	Industrial Coordinator
Rounds	Molly	Industrial Coordinator
Viera	Susan	Industrial Coordinator

### Sampling

Owen	Shawn	Program Manager, Monitoring
Rabideau	Robert	Sr. Sampling Associate
Keary	Simmerman	Sr. Sampling Associate
Barbaro	Paul	Sampling Associate
Boland	Thomas	Sampling Associate
Harley	Julian	Sampling Associate
Mastin	Jon	Sampling Associate
Tomas	Lopez-Gomez	Sampling Associate
Devine	Jeffery	Sampling Associate
Leuchte	Eric	Sampling Associate
Moscho	Michael	Sampling Associate
Vacant		Sampling Associate
Vacant		Sampling Associate
Vacant		Sampling Associate

## Appendix H

# Priority Pollutant Scan Results and Comparison of Influent and Effluent to Established Standards for Deer Island

**Table H-1  
Average Influent Concentrations  
Deer Island Wastewater Treatment Plant - Fiscal Year 2022**

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
<b>Metals (ug/L)</b>															
ANTIMONY	25	25	25	25	25	25	25	25	25	25	25	25	25	25	0 of 48
ALUMINUM	322	950	470	574	378	3920	376	610	620	522	503	469	745	6510	47 of 48
ARSENIC	0.67	1.28	0.825	1.19	0.557	3.21	0.4	0.4	0.706	0.72	1.1	1.18	0.964	4.81	27 of 48
BERYLLIUM	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0 of 48
BORON	125	125	125	125	125	125	168	125	125	125	125	125	128	210	1 of 48
CADMIUM	0.142	0.328	0.178	0.192	0.185	0.975	0.196	0.291	0.366	0.402	0.225	0.207	0.289	1.31	48 of 48
CHROMIUM	0.776	3.02	1.07	2.38	1.82	19.2	2.17	2.39	3.45	3.54	2.22	2.62	3.36	30.8	46 of 48
COPPER	32.5	56.2	28.6	38.4	36.7	203	42.8	29.8	34.7	50.9	38.3	48.5	49.5	308	48 of 48
IRON	1400	1040	1260	1610	1390	9130	1530	1690	2090	2040	1740	1850	1980	14300	54 of 54
LEAD	2.42	6.41	2.11	5.53	3.59	87.3	2.46	2.93	11.8	4.24	3.22	3.46	9.98	154	46 of 48
MERCURY	0.291	0.115	0.0467	0.0556	0.0613	0.948	0.0311	0.071	0.133	0.127	0.0482	0.0607	0.156	1.35	46 of 48
MOLYBDENUM	3.72	5.44	2.76	6.77	4.47	11.1	3.68	4.65	5.75	7.03	3.02	7.66	5.32	12.8	48 of 48
NICKEL	2.2	3.03	1.54	1.96	1.9	8.95	2.15	2.63	2.85	2.68	2.4	2.4	2.74	13.8	48 of 48
SELENIUM	0.45	0.45	0.45	0.45	0.45	0.827	0.45	0.45	0.45	0.45	0.537	0.48	0.844	0.844	3 of 48
SILVER	0.045	0.431	0.11	0.237	0.225	1.32	0.185	0.3	0.201	0.427	0.198	0.264	0.299	2.06	43 of 48
THALLIUM	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
ZINC	83.3	162	75.4	98.5	80.9	550	87.6	93.6	120	126	112	113	132	855	48 of 48
<b>Cyanide (ug/L)</b>															
CYANIDE	10	12.4	10	10	25.5	11.9	14.4	10	23.5	11.9	10	13.6	13.8	37.1	10 of 48
<b>FOG and PHC (mg/L)</b>															
PETROLEUM HYDROCARBONS	0.421	0.608	0.249	0.562	0.623	0	0	1.52	1.07	1.19	1.73	3.01	1.01	3.05	38 of 38
FATS OIL AND GREASE	11.6	22.8	8.09	12.2	15.2	22.6	28.5	16.8	42.1	27.2	26	33.2	21.1	55.8	46 of 48
<b>Conventional Parameters (mg/L)</b>															
BIOCHEMICAL OXYGEN DEMAND	100	144	117	147	129	209	168	127	143	160	185	197	147	352	710 of 711
CHEMICAL OXYGEN DEMAND	218	339	256	294	295	412	378	298	318	378	436	450	326	641	705 of 705
TOTAL SUSPENDED SOLIDS	126	176	136	169	149	252	191	150	183	183	217	216	173	384	693 of 693
<b>Nutrients (mg/L)</b>															
AMMONIA	17.2	21.7	21	24.1	22.1	36.1	31.9	24.5	26.6	29.2	34.5	35.8	25.9	54.6	106 of 106
NITRATE	0.168	0.169	0.17	0.202	0.408	0.209	0.157	0.384	0.13	0.286	0.241	0.0794	0.21	0.728	83 of 106
NITRITE	0.175	0.199	0.193	0.11	0.162	0.154	0.121	0.198	0.154	0.158	0.217	0.139	0.168	0.368	97 of 106
TOTAL KJELDAHL NITROGEN	26	30.9	31.1	34.4	31.8	46.5	42.9	34	36.6	40.7	49.4	57.2	37.3	70.7	100 of 100
ORTHOPHOSPHATE	1.12	1.62	1.63	1.85	1.66	2.39	2.23	1.64	1.83	2.13	2.46	3.08	1.89	3.44	106 of 106
TOTAL PHOSPHORUS	2.74	2.88	3.22	3.66	3.45	4.55	4.37	3.35	4.01	4.69	5.78	5.72	3.85	8.11	106 of 106
<b>Pesticides and PCBs (ug/L)</b>															
4,4'-DDD	0.000525	0.000528	0.000523	0.000554	0.000527	0.000519	0.000529	0.000519	0.000575	0.000525	0.00056	0.000542	0.000536	0.00062	0 of 48
4,4'-DDE	0.00042	0.000422	0.000419	0.000443	0.000422	0.000415	0.000423	0.000415	0.00046	0.00042	0.000448	0.000434	0.000429	0.00049	0 of 48
4,4'-DDT	0.000525	0.000528	0.000523	0.000554	0.000527	0.000519	0.000529	0.000519	0.000575	0.000525	0.00056	0.000542	0.000536	0.00062	0 of 48
ALDRIN	0.000525	0.000528	0.000523	0.000554	0.000527	0.000519	0.000529	0.000519	0.000575	0.000525	0.00056	0.000542	0.000536	0.00062	0 of 48
ALPHA-BHC	0.00042	0.000422	0.000419	0.000443	0.000422	0.000415	0.000423	0.000415	0.00046	0.00042	0.000448	0.000434	0.000429	0.00049	0 of 48
ALPHA-CHLORDANE	0.00246	0.00282	0.00118	0.00131	0.00187	0.00315	0.00284	0.000415	0.00046	0.00042	0.00258	0.00172	0.0017	0.00354	15 of 48
AROCLOR-1016	0.0262	0.0264	0.0262	0.0277	0.0263	0.0259	0.0264	0.0259	0.0287	0.0262	0.028	0.0271	0.0268	0.0308	0 of 48
AROCLOR-1221	0.0525	0.0528	0.0523	0.0554	0.0527	0.0519	0.0529	0.0519	0.0575	0.0525	0.056	0.0542	0.0536	0.0616	0 of 48
AROCLOR-1232	0.0262	0.0264	0.0262	0.0277	0.0263	0.0259	0.0264	0.0259	0.0287	0.0262	0.028	0.0271	0.0268	0.0308	0 of 48
AROCLOR-1242	0.0262	0.0264	0.0262	0.0277	0.0263	0.0259	0.0264	0.0259	0.0287	0.0262	0.028	0.0271	0.0268	0.0308	0 of 48
AROCLOR-1248	0.0262	0.0264	0.0262	0.0277	0.0263	0.0259	0.0264	0.0259	0.0287	0.0262	0.028	0.0271	0.0268	0.0308	0 of 48

**Table H-1  
Average Influent Concentrations  
Deer Island Wastewater Treatment Plant - Fiscal Year 2022**

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
<b>Pesticides and PCBs (ug/L) (cont.)</b>															
AROCLOR-1254	0.0262	0.0264	0.0262	0.0277	0.0263	0.0259	0.0264	0.0259	0.0287	0.0262	0.028	0.0271	0.0268	0.0308	0 of 48
AROCLOR-1260	0.0262	0.0264	0.0262	0.0277	0.0263	0.0259	0.0264	0.0259	0.0287	0.0262	0.028	0.0271	0.0268	0.0308	0 of 48
BETA-BHC	0.00042	0.000422	0.000419	0.000443	0.000422	0.000415	0.000423	0.000415	0.00046	0.00042	0.000448	0.000434	0.000429	0.00049	0 of 48
CHLORDANE (TECHNICAL)	0.0525	0.0528	0.0523	0.0554	0.0527	0.0519	0.0529	0.0519	0.0575	0.0525	0.056	0.0542	0.0536	0.0616	0 of 48
DELTA-BHC	0.00042	0.000422	0.000419	0.000443	0.000422	0.000415	0.000423	0.000415	0.00046	0.00042	0.000448	0.000434	0.000429	0.00049	0 of 48
DIELDRIN	0.00042	0.000422	0.000419	0.000443	0.000422	0.000415	0.000423	0.000415	0.00046	0.00042	0.000448	0.000434	0.000429	0.00049	0 of 48
ENDOSULFAN I	0.00042	0.000422	0.000419	0.000443	0.000422	0.000415	0.000423	0.000415	0.00046	0.00042	0.000448	0.000434	0.000429	0.00049	0 of 48
ENDOSULFAN II	0.000525	0.000528	0.000523	0.000554	0.000527	0.000519	0.000529	0.000519	0.000575	0.000525	0.00056	0.000542	0.000536	0.00062	0 of 48
ENDOSULFAN SULFATE	0.000525	0.000528	0.000523	0.000554	0.000527	0.000519	0.000529	0.000519	0.000575	0.000525	0.00056	0.000542	0.000536	0.00062	0 of 48
ENDRIN	0.00042	0.000422	0.000419	0.000443	0.000422	0.000415	0.000423	0.000415	0.00046	0.00042	0.000448	0.000434	0.000429	0.00049	0 of 48
ENDRIN ALDEHYDE	0.000525	0.000528	0.000523	0.000554	0.000527	0.000519	0.000529	0.000519	0.000575	0.000525	0.00056	0.000542	0.000536	0.00062	0 of 48
ENDRIN KETONE	0.000525	0.000528	0.000523	0.000554	0.000527	0.000519	0.000529	0.000519	0.000575	0.000525	0.00056	0.000542	0.000536	0.00062	0 of 48
GAMMA-BHC	0.00042	0.000422	0.000419	0.000443	0.000422	0.000415	0.000423	0.000415	0.00046	0.00042	0.000448	0.000434	0.000429	0.00049	0 of 48
GAMMA-CHLORDANE	0.00209	0.00233	0.000419	0.000443	0.000422	0.0128	0.000423	0.00151	0.00156	0.00042	0.00122	0.00211	0.00191	0.0171	12 of 48
HEPTACHLOR	0.00042	0.000422	0.000419	0.000443	0.000422	0.000415	0.000423	0.000415	0.00046	0.00042	0.000448	0.000434	0.000429	0.00049	0 of 48
HEPTACHLOR EPOXIDE	0.00042	0.000422	0.000419	0.000443	0.000422	0.000415	0.000423	0.000415	0.00046	0.00042	0.000448	0.000434	0.000429	0.00049	0 of 48
METHOXYCHLOR	0.000525	0.000528	0.000523	0.000554	0.000527	0.000519	0.000529	0.000519	0.000575	0.000525	0.00056	0.000542	0.000536	0.00062	0 of 48
TOTAL AMP PCBs	~	0.00972	~	0.00576	~	0.0244	~	0.0209	~	0.0337	~	0.0128	0.0175	0.0372	22 of 22
TOXAPHENE	0.0525	0.0528	0.0523	0.0554	0.0527	0.0519	0.0529	0.0519	0.0575	0.0525	0.056	0.0542	0.0536	0.0616	0 of 48
<b>Pesticides and PCBs (ug/L) - low detection limit methods</b>															
2,4'-DDD	~	0.00347	~	0.00662	~	0.000974	~	0.00259	~	0.0187	~	0.00682	0.00647	0.0365	15 of 22
2,4'-DDE	~	0.000211	~	0.000223	~	0.000207	~	0.000205	~	0.000421	~	0.000201	0.000247	0.00043	0 of 22
2,4'-DDT	~	0.000211	~	0.000345	~	0.00364	~	0.00294	~	0.00249	~	0.000201	0.00172	0.00683	12 of 22
4,4'-DDD	~	0.000211	~	0.000297	~	0.00155	~	0.000448	~	0.000421	~	0.000201	0.000527	0.00286	5 of 22
4,4'-DDE	~	0.00358	~	0.00122	~	0.00231	~	0.00193	~	0.00223	~	0.00162	0.00209	0.00442	21 of 22
4,4'-DDT	~	0.000551	~	0.000679	~	0.000207	~	0.000205	~	0.000421	~	0.000201	0.000416	0.00091	3 of 22
ALDRIN	~	0.000211	~	0.000223	~	0.000207	~	0.000205	~	0.000421	~	0.000201	0.000247	0.00043	0 of 22
ALPHA-CHLORDANE	~	0.0071	~	0.00304	~	0.00395	~	0.00581	~	0.00463	~	0.0042	0.00471	0.00719	22 of 22
BZ 101 PENTACHLOROBIPHENYL	~	0.00157	~	0.000902	~	0.00205	~	0.00052	~	0.000568	~	0.00272	0.00116	0.00277	22 of 22
BZ 105 PENTACHLOROBIPHENYL	~	0.000566	~	0.000343	~	0.000719	~	0.000491	~	0.000696	~	0.000201	0.000517	0.00088	19 of 22
BZ 118 PENTACHLOROBIPHENYL	~	0.00047	~	0.000223	~	0.000207	~	0.0162	~	0.0273	~	0.000474	0.000808	0.0277	12 of 22
BZ 126 PENTACHLOROBIPHENYL	~	0.000211	~	0.000223	~	0.000207	~	0.000205	~	0.000421	~	0.000201	0.000247	0.00043	0 of 22
BZ 128 HEXACHLOROBIPHENYL	~	0.000188	~	0.00012	~	0.000207	~	0.000205	~	0.000421	~	0.000201	0.000217	0.00043	6 of 22
BZ 138 HEXACHLOROBIPHENYL	~	0.00246	~	0.00144	~	0.00614	~	0.00154	~	0.00162	~	0.00279	0.00247	0.00865	22 of 22
BZ 153 HEXACHLOROBIPHENYL	~	0.00174	~	0.00112	~	0.00443	~	0.00112	~	0.00113	~	0.00284	0.00184	0.00641	22 of 22
BZ 170 HEPTACHLOROBIPHENYL	~	0.000211	~	0.000223	~	0.00404	~	0.000205	~	0.000421	~	0.000201	0.000848	0.00742	1 of 22
BZ 18 TRICHLOROBIPHENYL	~	0.000211	~	0.000223	~	0.000207	~	0.000205	~	0.000421	~	0.000201	0.000247	0.00043	0 of 22
BZ 180 HEPTACHLOROBIPHENYL	~	0.00113	~	0.000627	~	0.00327	~	0.000516	~	0.000835	~	0.00138	0.00118	0.00497	21 of 22
BZ 187 HEPTACHLOROBIPHENYL	~	0.000732	~	0.000362	~	0.00232	~	0.000282	~	0.000624	~	0.00094	0.000789	0.00402	18 of 22
BZ 195 OCTACHLOROBIPHENYL	~	0.000211	~	0.000223	~	0.000207	~	0.000205	~	0.000421	~	0.000201	0.000247	0.00043	0 of 22
BZ 206 NONACHLOROBIPHENYL	~	0.000211	~	0.000228	~	0.000207	~	0.000205	~	0.000421	~	0.000201	0.000248	0.00043	1 of 22
BZ 209 DECACHLOROBIPHENYL	~	0.00021	~	0.000116	~	0.000207	~	0.000205	~	0.000511	~	0.000504	0.000253	0.00059	7 of 22
BZ 28 TRICHLOROBIPHENYL	~	0.000211	~	0.000223	~	0.000207	~	0.000205	~	0.000421	~	0.000201	0.000247	0.00043	0 of 22
BZ 44 TETRACHLOROBIPHENYL	~	0.000324	~	0.000223	~	0.000207	~	0.000205	~	0.000421	~	0.000201	0.000265	0.00043	1 of 22
BZ 52 TETRACHLOROBIPHENYL	~	0.00086	~	0.000675	~	0.00163	~	0.000514	~	0.000702	~	0.00141	0.000869	0.00214	22 of 22
BZ 66 TETRACHLOROBIPHENYL	~	0.000211	~	0.000223	~	0.000207	~	0.000205	~	0.000421	~	0.000201	0.000247	0.00043	0 of 22
BZ 77 TETRACHLOROBIPHENYL	~	0.000211	~	0.000223	~	0.000207	~	0.000205	~	0.000421	~	0.000201	0.000247	0.00043	0 of 22
BZ 8 DICHLOROBIPHENYL	~	0.000211	~	0.000204	~	0.000207	~	0.000205	~	0.000421	~	0.000201	0.000242	0.00043	1 of 22

**Table H-1  
Average Influent Concentrations  
Deer Island Wastewater Treatment Plant - Fiscal Year 2022**

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
<b>Pesticides and PCBs (ug/L) - low detection limit methods (cont.)</b>															
CIS-NONACHLOR	~	0.0019	~	0.000524	~	0.001	~	0.00116	~	0.000827	~	0.000682	0.001	0.00202	22 of 22
DDMU	~	0.000211	~	0.000223	~	0.000207	~	0.000205	~	0.000421	~	0.000201	0.000247	0.00043	0 of 22
DIELDRIN	~	0.000211	~	0.000794	~	0.000207	~	0.000205	~	0.000421	~	0.000201	0.000393	0.00147	1 of 22
ENDRIN	~	0.000211	~	0.000223	~	0.000207	~	0.000205	~	0.000421	~	0.000201	0.000247	0.00043	0 of 22
GAMMA-BHC	~	0.000211	~	0.000223	~	0.000207	~	0.000205	~	0.000421	~	0.000201	0.000247	0.00043	0 of 22
GAMMA-CHLORDANE	~	0.00547	~	0.00315	~	0.0141	~	0.0154	~	0.017	~	0.00497	0.0102	0.0205	22 of 22
HEPTACHLOR	~	0.000211	~	0.000223	~	0.000207	~	0.000438	~	0.000421	~	0.000201	0.000295	0.00066	2 of 22
HEPTACHLOR EPOXIDE	~	0.000211	~	0.000223	~	0.000207	~	0.000205	~	0.000421	~	0.000201	0.000247	0.00043	0 of 22
HEXACHLOROBENZENE	~	0.00391	~	0.000673	~	0.00471	~	0.00202	~	0.00225	~	0.00095	0.00236	0.00496	22 of 22
MIREX	~	0.000211	~	0.000223	~	0.000207	~	0.000205	~	0.000421	~	0.00488	0.000532	0.00488	1 of 22
OXYCHLORDANE	~	0.000211	~	0.000223	~	0.0126	~	0.000205	~	0.000421	~	0.000201	0.00218	0.015	2 of 22
TOTAL CHLORDANE	~	0.0135	~	0.00485	~	0.00943	~	0.0105	~	0.00712	~	0.00649	0.00856	0.0147	22 of 22
TOTAL DDT	~	0.00742	~	0.00855	~	0.00821	~	0.00776	~	0.0231	~	0.00844	0.0106	0.0411	21 of 22
TRANS-NONACHLOR	~	0.00645	~	0.00181	~	0.00548	~	0.00438	~	0.00252	~	0.00229	0.00378	0.00751	22 of 22
<b>Semivolatile Organics (ug/L)</b>															
1,2,4-TRICHLOROBENZENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
1,2-DIPHENYLHYDRAZINE (AS AZOBENZENE)	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
2,2'-OXYBIS(1-CHLOROPROPANE)	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
2,4,5-TRICHLOROPHENOL	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
2,4,6-TRICHLOROPHENOL	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
2,4-DICHLOROPHENOL	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
2,4-DIMETHYLPHENOL	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
2,4-DINITROPHENOL	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
2,4-DINITROTOLUENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
2,6-DINITROTOLUENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
2-CHLORONAPHTHALENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
2-CHLOROPHENOL	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
2-METHYL-4,6-DINITROPHENOL	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
2-METHYLNAPHTHALENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
2-METHYLPHENOL	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	10.6	1.98	2.6	18.8	1 of 46
2-NITROANILINE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
2-NITROPHENOL	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
3,3'-DICHLOROBENZIDINE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
3-NITROANILINE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
4-BROMOPHENYL PHENYL ETHER	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
4-CHLORO-3-METHYLPHENOL	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
4-CHLOROANILINE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
4-CHLOROPHENYL PHENYL ETHER	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
4-METHYLPHENOL (INCLUDES 3-METHYLPHENOL)	1.95	7.65	1.96	2.12	1.99	36.5	23.1	10.2	9.78	19.9	1.95	51.1	10.7	57.3	16 of 46
4-NITROANILINE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
4-NITROPHENOL	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
ACENAPHTHENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
ACENAPHTHYLENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
ANILINE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46



**Table H-1  
Average Influent Concentrations  
Deer Island Wastewater Treatment Plant - Fiscal Year 2022**

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
<b>Semivolatile Organics (ug/L)</b>															
ANTHRACENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
BENZIDINE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
BENZO(A)ANTHRACENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
BENZO(A)PYRENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
BENZO(B)FLUORANTHENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
BENZO(G,H,I)PERYLENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
BENZO(K)FLUORANTHENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
BENZOIC ACID	1.95	64.2	1.96	5.82	1.99	122	108	63.4	78.3	123	78.1	206	57	217	30 of 46
BENZYL ALCOHOL	1.95	42.2	1.96	2.12	1.99	24.4	1.94	1.88	7.96	24.9	42.9	33.3	12.5	58.6	15 of 46
BIS(2-CHLOROETHOXY)METHANE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
BIS(2-CHLOROETHYL)ETHER	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
BIS(2-ETHYLHEXYL)PHTHALATE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
BUTYLBENZYLPHthalATE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
CARBAZOLE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
CHRYSENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
DIBENZO(A,H)ANTHRACENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
DIBENZOFURAN	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
DIETHYLPHthalATE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
DIMETHYLPHthalATE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
DI-N-BUTYLPHthalATE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
DI-N-OCTYLPHthalATE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
FLUORANTHENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
FLUORENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
HEXACHLOROBENZENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
HEXACHLOROBUTADIENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
HEXACHLOROCYCLOPENTADIENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
HEXACHLOROETHANE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
INDENO(1,2,3-CD)PYRENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
ISOPHORONE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
NAPHTHALENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
N-DECANE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
NITROBENZENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
N-NITROSODIMETHYLAMINE (NDMA)	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
N-NITROSODI-N-PROPYLAMINE (NDPA)	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
N-NITROSODIPHENYLAMINE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
N-OCTADECANE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
PENTACHLOROPHENOL	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
PHENANTHRENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
PHENOL	1.95	13.5	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	18.4	3.69	27.5	5 of 46
PYRENE	1.95	1.97	1.96	2.12	1.99	1.97	1.94	1.88	2.16	1.89	1.95	1.98	1.99	2.3	0 of 46
<b>Polyaromatic Hydrocarbons - low detection limit methods</b>															
1-METHYLNAPHTHALENE	~	0.0688	~	0.106	~	0.103	~	0.0264	~	0.034	~	0.0431	0.0662	0.136	24 of 24
1-METHYLPHENANTHRENE	~	0.033	~	0.022	~	0.122	~	0.00997	~	0.0119	~	0.0291	0.0352	0.191	24 of 24
2,3,5-TRIMETHYLNAPHTHYLENE	~	0.0298	~	0.049	~	0.0436	~	0.0177	~	0.0178	~	0.0297	0.0322	0.0652	24 of 24
2,6-DIMETHYLNAPHTHALENE	~	0.0334	~	0.0513	~	0.0649	~	0.0103	~	0.0266	~	0.0436	0.038	0.0811	24 of 24
2-METHYLNAPHTHALENE	~	0.0769	~	0.079	~	0.0944	~	0.0278	~	0.0364	~	0.0388	0.0597	0.129	24 of 24
ACENAPHTHENE	~	0.0873	~	0.0513	~	0.191	~	0.0511	~	0.0417	~	0.0486	0.0752	0.265	24 of 24
ACENAPHTHYLENE	~	0.0142	~	0.0102	~	0.0454	~	0.00725	~	0.0102	~	0.0114	0.0155	0.0677	24 of 24

**Table H-1  
Average Influent Concentrations  
Deer Island Wastewater Treatment Plant - Fiscal Year 2022**

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
<b>Polyaromatic Hydrocarbons - low detection limit methods (cont.)</b>															
ANTHRACENE	~	0.0362	~	0.0175	~	0.217	~	0.0116	~	0.0146	~	0.0173	0.0479	0.353	23 of 24
BENZO(A)ANTHRACENE	~	0.0482	~	0.0307	~	0.505	~	0.023	~	0.0262	~	0.0737	0.106	0.836	24 of 24
BENZO(A)PYRENE	~	0.0397	~	0.0306	~	0.43	~	0.0211	~	0.023	~	0.0456	0.0894	0.713	24 of 24
BENZO(B)FLUORANTHENE	~	0.0708	~	0.0459	~	0.557	~	0.0406	~	0.0438	~	0.082	0.128	0.916	24 of 24
BENZO(E)PYRENE	~	0.0373	~	0.0295	~	0.287	~	0.019	~	0.0205	~	0.0384	0.0661	0.471	24 of 24
BENZO(G,H,I)PERYLENE	~	0.0282	~	0.0271	~	0.258	~	0.0175	~	0.0207	~	0.00985	0.0564	0.44	24 of 24
BENZO(K)FLUORANTHENE	~	0.0253	~	0.0131	~	0.148	~	0.0109	~	0.0105	~	0.0216	0.0349	0.24	24 of 24
BENZOTHAZOLE	~	0.646	~	0.695	~	0.541	~	0.257	~	0.556	~	0.267	0.508	0.783	24 of 24
BIPHENYL	~	0.0161	~	0.0338	~	0.0285	~	0.00633	~	0.00804	~	0.00993	0.0183	0.0455	24 of 24
C1-CHRYSENES	~	0.0456	~	0.0265	~	0.336	~	0.0188	~	0.0232	~	0.0573	0.0765	0.546	24 of 24
C1-DIBENZOTHIOPHENES	~	0.0324	~	0.0287	~	0.113	~	0.0189	~	0.0246	~	0.026	0.0388	0.143	23 of 24
C1-FLUORANTHENES/PYRENES	~	0.0487	~	0.0479	~	0.344	~	0.0202	~	0.0231	~	0.0255	0.0797	0.566	23 of 24
C1-FLUORENES	~	0.0602	~	0.066	~	0.113	~	0.0352	~	0.0393	~	0.0517	0.0602	0.144	23 of 24
C1-NAPHTHALENES	~	0.101	~	0.134	~	0.136	~	0.0361	~	0.0464	~	0.0561	0.0878	0.18	24 of 24
C1-PHENANTHRENES/ANTHRACENES	~	0.179	~	0.097	~	0.564	~	0.0574	~	0.0789	~	0.115	0.169	0.84	23 of 24
C2-CHRYSENES	~	0.000528	~	0.000549	~	0.00107	~	0.000513	~	0.000527	~	0.000511	0.000608	0.00155	0 of 24
C2-DIBENZOTHIOPHENES	~	0.000528	~	0.000549	~	0.00107	~	0.000513	~	0.000527	~	0.000511	0.000608	0.00155	0 of 24
C2-FLUORANTHENES/PYRENES	~	0.0296	~	0.0234	~	0.141	~	0.00982	~	0.0123	~	0.0112	0.0358	0.224	23 of 24
C2-FLUORENES	~	0.0723	~	0.0945	~	0.145	~	0.0733	~	0.061	~	0.094	0.0892	0.176	23 of 24
C2-NAPHTHALENES	~	0.106	~	0.193	~	0.168	~	0.0381	~	0.073	~	0.0912	0.116	0.255	24 of 24
C2-PHENANTHRENES/ANTHRACENES	~	0.0583	~	0.0855	~	0.25	~	0.0284	~	0.0358	~	0.038	0.0814	0.381	23 of 24
C3-CHRYSENES	~	0.000528	~	0.000549	~	0.00107	~	0.000513	~	0.000527	~	0.000511	0.000608	0.00155	0 of 24
C3-DIBENZOTHIOPHENES	~	0.000528	~	0.000549	~	0.00107	~	0.000513	~	0.000527	~	0.000511	0.000608	0.00155	0 of 24
C3-FLUORANTHENES/PYRENES	~	0.000528	~	0.000549	~	0.00107	~	0.000513	~	0.000527	~	0.000511	0.000608	0.00155	0 of 24
C3-FLUORENES	~	0.000528	~	0.000549	~	0.00107	~	0.000513	~	0.000527	~	0.000511	0.000608	0.00155	0 of 24
C3-NAPHTHALENES	~	0.105	~	0.205	~	0.156	~	0.0657	~	0.0612	~	0.0566	0.116	0.27	23 of 24
C3-PHENANTHRENES/ANTHRACENES	~	0.167	~	0.0625	~	0.117	~	0.0351	~	0.0806	~	0.28	0.109	0.463	22 of 24
C4-CHRYSENES	~	0.000528	~	0.000549	~	0.00107	~	0.000513	~	0.000527	~	0.000511	0.000608	0.00155	0 of 24
C4-NAPHTHALENES	~	0.000528	~	0.000549	~	0.00107	~	0.000513	~	0.000527	~	0.000511	0.000608	0.00155	0 of 24
C4-PHENANTHRENES/ANTHRACENES	~	0.000528	~	0.000549	~	0.00107	~	0.000513	~	0.000527	~	0.000511	0.000608	0.00155	0 of 24
CHRYSENE	~	0.0568	~	0.039	~	0.527	~	0.0296	~	0.0314	~	0.0539	0.112	0.864	24 of 24
DIBENZO(A,H)ANTHRACENE	~	0.000528	~	0.000549	~	0.00107	~	0.00541	~	0.000527	~	0.000511	0.00155	0.00558	4 of 24
DIBENZOFURAN	~	0.0319	~	0.0215	~	0.0791	~	0.0149	~	0.0161	~	0.0239	0.0296	0.116	24 of 24
DIBENZOTHIOPHENE	~	0.0216	~	0.0176	~	0.0881	~	0.00974	~	0.0122	~	0.0228	0.0268	0.135	24 of 24
FLUORANTHENE	~	0.113	~	0.0928	~	0.937	~	0.0671	~	0.071	~	0.132	0.216	1.52	24 of 24
FLUORENE	~	0.0552	~	0.0408	~	0.142	~	0.0228	~	0.0267	~	0.0438	0.0525	0.215	24 of 24
INDENO(1,2,3-CD)PYRENE	~	0.131	~	0.0652	~	0.394	~	0.0228	~	0.0458	~	0.141	0.121	0.594	24 of 24
NAPHTHALENE	~	0.171	~	0.0945	~	0.158	~	0.0591	~	0.0683	~	0.0692	0.101	0.207	24 of 24
PERYLENE	~	0.00566	~	0.0072	~	0.0961	~	0.0194	~	0.0199	~	0.041	0.0284	0.157	21 of 24
PHENANTHRENE	~	0.18	~	0.112	~	1	~	0.0777	~	0.0873	~	0.174	0.25	1.59	24 of 24
PYRENE	~	0.099	~	0.0849	~	0.821	~	0.0555	~	0.0616	~	0.119	0.19	1.34	24 of 24
<b>Volatile Organics (ug/L)</b>															
1,1,1-TRICHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
1,1,2,2-TETRACHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
1,1,2-TRICHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
1,1-DICHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
1,1-DICHLOROETHENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
1,2-DICHLOROBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48

**Table H-1  
Average Influent Concentrations  
Deer Island Wastewater Treatment Plant - Fiscal Year 2022**

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
<b>Volatile Organics (ug/L) (cont.)</b>															
1,2-DICHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
1,2-DICHLOROPROPANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
1,3-DICHLOROBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
1,4-DICHLOROBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
2-BUTANONE	1.53	3.71	2	2.03	1.49	4.62	2.28	0.5	3.14	3.35	0.5	3.74	2.29	6.48	17 of 48
2-CHLOROETHYL VINYL ETHER	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
2-HEXANONE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
4-METHYL-2-PENTANONE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
ACETONE	107	213	233	54.1	95.2	117	75.5	167	71.3	214	206	108	137	363	48 of 48
ACROLEIN	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0 of 48
ACRYLONITRILE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
BENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
BROMODICHLOROMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
BROMOFORM	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
BROMOMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
CARBON DISULFIDE	0.5	5.38	0.5	0.5	0.5	0.5	19.6	0.5	0.5	0.5	5.75	22.3	3.88	39.6	8 of 48
CARBON TETRACHLORIDE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
CHLOROBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
CHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
CHLOROFORM	0.5	0.5	0.5	0.5	0.5	0.5	2.18	0.5	0.5	0.5	0.5	0.5	0.618	3.94	1 of 48
CHLOROMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
CIS-1,2-DICHLOROETHENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
CIS-1,3-DICHLOROPROPENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
DIBROMOCHLOROMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
ETHYLBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
M,P-XYLENE	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0 of 48
METHYLENE CHLORIDE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
O-XYLENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
STYRENE	0.5	2.14	0.5	0.5	0.5	0.5	0.5	0.5	7.63	0.5	0.5	0.5	1.27	14.7	2 of 48
TETRACHLOROETHENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
TOLUENE	0.5	1.3	0.5	0.5	0.5	2.19	0.5	0.5	20.8	0.5	0.5	3.76	2.71	34.9	6 of 48
TRANS-1,2-DICHLOROETHENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
TRANS-1,3-DICHLOROPROPENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
TRICHLOROETHENE	0.5	0.5	0.5	0.5	0.5	0.5	1.38	2	0.5	0.5	0.5	0.5	0.695	3.51	2 of 48
TRICHLOROFLUOROMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
VINYL ACETATE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 48
VINYL CHLORIDE	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0 of 48

**Notes:** Where parameters were below detection levels, one half of the method detection limit for inorganic compounds or one tenth of the quantitation limit for organic compounds was substituted to calculate concentrations. The annual average concentration is the flow-weighted average of all data points. The maximum concentration is the highest concentration observed in the monitoring year. Pesticides and PCBs\*\* and Polyaromatic Hydrocarbons\*\* tested with more sensitive methods which are not EPA-approved for permit compliance.  
~ No data

**Table H-2**  
**Comparison of Treatment Plant Influent With Threshold Inhibition Levels**  
**Deer Island Treatment Plant Data - Fiscal Year 2022**

Parameter	EPA Inhibition Levels		Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
	Activated Sludge (ug/L)	Anaerobic Digestion (ug/L)												
			Average Concentration (ug/L)											
<b>Arsenic</b>	100	1600	0.67	1.28	0.825	1.19	0.557	3.21	0.4	0.4	0.706	0.72	1.1	1.18
<b>Cadmium</b>	1000	20000	0.142	0.328	0.178	0.192	0.185	0.975	0.196	0.291	0.366	0.402	0.225	0.207
<b>Chromium</b>	1000	130000	0.776	3.02	1.07	2.38	1.82	19.2	2.17	2.39	3.45	3.54	2.22	2.62
<b>Copper</b>	1000	40000	32.5	56.2	28.6	38.4	36.7	203	42.8	29.8	34.7	50.9	38.3	48.5
<b>Cyanide</b>	100	4000	10	12.4	10	10	25.5	11.9	14.4	10	23.5	11.9	10	13.6
<b>Lead</b>	100	340000	2.42	6.41	2.11	5.53	3.59	87.3	2.46	2.93	11.8	4.24	3.22	3.46
<b>Mercury</b>	100	<b>NA</b>	0.291	0.115	0.0467	0.0556	0.0613	0.948	0.0311	0.071	0.133	0.127	0.0482	0.0607
<b>Nickel</b>	1000	10000	2.2	3.03	1.54	1.96	1.9	8.95	2.15	2.63	2.85	2.68	2.4	2.4
<b>Silver</b>	250	13000	0.045	0.431	0.11	0.237	0.225	1.32	0.185	0.3	0.201	0.427	0.198	0.264
<b>Zinc</b>	300	400000	83.3	162	75.4	98.5	80.9	<u>550</u>	87.6	93.6	120	126	112	113

Values that are bold and underlined are inhibition level exceedances

**NA** No Applicable Criteria

**Table H-3  
Average Effluent Concentrations  
Deer Island Wastewater Treatment Plant - Fiscal Year 2022**

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
<b>Metals (ug/L)</b>															
ANTIMONY	25	25	25	25	25	25	25	25	25	25	25	25	25	25	0 of 24
ALUMINUM	44.9	35	33.7	40.9	28.6	47.8	34.6	55.3	61.1	71.1	60.7	41.5	45.7	121	49 of 49
ARSENIC	0.4	0.4	0.607	0.612	0.4	0.4	0.4	0.4	0.4	0.4	0.671	0.648	0.474	0.946	4 of 24
BERYLLIUM	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0 of 24
BORON	125	125	125	125	125	125	125	125	125	125	125	125	125	125	0 of 24
CADMIUM	0.0606	0.0492	0.0421	0.0451	0.0482	0.0441	0.033	0.062	0.0863	0.0811	0.048	0.0484	0.0549	0.114	48 of 49
CHROMIUM	0.35	0.835	0.35	0.35	0.35	0.86	0.35	0.35	0.35	0.35	0.35	0.454	0.426	2.37	3 of 49
COPPER	5	3.95	5.38	4.65	4.39	6.08	5.27	6.22	8	7.1	7.65	6.07	5.7	8.37	49 of 49
IRON	151	253	184	155	196	243	206	223	429	312	260	278	236	435	24 of 24
LEAD	0.676	0.546	0.585	0.579	0.57	0.538	0.529	0.52	0.764	0.578	0.577	0.522	0.592	1.26	13 of 49
MERCURY	0.0036	0.00353	0.00304	0.00311	0.00261	0.00309	0.00335	0.00419	0.00871	0.00611	0.00598	0.00306	0.00417	0.0104	48 of 48
MOLYBDENUM	1.3	1.74	1.75	1.56	1.01	1.2	1.79	2.71	1.03	1.56	1.37	2.16	1.58	6.72	47 of 49
NICKEL	1.3	1.74	1.75	1.56	1.01	1.2	1.79	2.71	1.03	1.56	1.37	2.16	1.58	6.72	47 of 49
SELENIUM	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0.45	0 of 24
SILVER	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0.045	0 of 48
THALLIUM	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
ZINC	20.2	14.1	12.7	12	12.4	12.1	13.3	23.2	27.7	22.4	21.8	13.3	17.4	31.4	49 of 49
<b>Cyanide (ug/L)</b>															
CYANIDE	10	10	10	10	10	10	36.6	10	10	10	10	10	10.9	36.6	1 of 23
<b>FOG and PHC (mg/L)</b>															
PETROLEUM HYDROCARBON	0.107	0.111	0.125	0.178	0.454	0.476	0.154	0.02	0.02	0.122	0.02	0.0175	0.149	1.4	37 of 64
FATS OIL AND GREASE	0.69	0.674	0.67	0.675	0.675	0.685	0.703	0.671	0.684	0.683	0.59	0.377	0.656	0.778	0 of 64
<b>Conventional Parameters (mg/L)</b>															
BIOCHEMICAL OXYGEN DEMAND	18.1	14.1	17.8	17.8	15.6	14.9	18.9	17.3	22.2	17.6	18	16.4	17.5	42.3	363 of 363
CHEMICAL OXYGEN DEMAND	55.4	59.7	58.2	67.6	57.1	71.7	79.9	81.7	81.3	70.8	79.6	94.6	69.9	150	365 of 365
TOTAL SUSPENDED SOLIDS	9.52	7.28	7.92	12.5	7.01	11.9	14	14.9	16.8	14.1	12.5	13.7	11.6	66.3	367 of 367
<b>Nutrients (mg/L)</b>															
AMMONIA	12.3	20.1	19.2	20.3	19.1	29.5	26.8	21.2	23	24	28.5	33.4	22.1	37.7	89 of 89
NITRATE	0.559	0.243	0.23	0.422	0.795	0.569	0.278	0.288	0.595	0.347	0.854	0.932	0.494	2.07	63 of 64
NITRITE	1.56	0.513	0.39	0.478	0.332	0.105	0.358	0.609	0.646	0.564	0.355	0.0962	0.544	2.37	64 of 64
TOTAL KJELDAHL NITROGEN	14.6	22	22.1	22.6	20.4	29.7	28.9	22.8	25.7	26.8	31.6	36.6	24.5	42.4	64 of 64
ORTHOPHOSPHATE	0.945	1.47	1.39	1.41	1.3	1.95	1.7	1.13	0.958	1.16	2.11	2.49	1.45	2.8	52 of 52
TOTAL PHOSPHORUS	1.18	1.98	1.77	1.82	1.69	2.42	2.2	1.44	1.45	1.69	2.44	3.03	1.87	3.46	52 of 52
<b>Pesticides and PCBs (ug/L)</b>															
4,4'-DDD	0.000541	0.000526	0.000588	0.00053	0.000538	0.00052	0.000549	0.000532	0.000521	0.000524	0.0006	0.00055	0.000543	0.000599	0 of 12
4,4'-DDE	0.000433	0.000421	0.00047	0.00042	0.00043	0.00042	0.000439	0.000426	0.000417	0.000419	0.00048	0.00044	0.000434	0.000479	0 of 12
4,4'-DDT	0.000541	0.000526	0.000588	0.00053	0.000538	0.00052	0.000549	0.000532	0.000521	0.000524	0.0006	0.00055	0.000543	0.000599	0 of 12
ALDRIN	0.000541	0.000526	0.000588	0.00053	0.000538	0.00052	0.000549	0.000532	0.000521	0.000524	0.0006	0.00055	0.000543	0.000599	0 of 12
ALPHA-BHC	0.000433	0.000421	0.00047	0.00042	0.00043	0.00042	0.000439	0.000426	0.000417	0.000419	0.00048	0.00044	0.000434	0.000479	0 of 12
ALPHA-CHLORDANE	0.000433	0.000421	0.00047	0.00042	0.00043	0.00042	0.000439	0.000426	0.000417	0.000419	0.00048	0.00044	0.000434	0.000479	0 of 12
AROCLOR-1016	0.027	0.0263	0.0294	0.0263	0.0269	0.0262	0.0274	0.0266	0.026	0.0262	0.03	0.0274	0.0271	0.03	0 of 12
AROCLOR-1221	0.0541	0.0526	0.0588	0.0526	0.0538	0.0524	0.0549	0.0532	0.0521	0.0524	0.0599	0.0549	0.0543	0.0599	0 of 12
AROCLOR-1232	0.027	0.0263	0.0294	0.0263	0.0269	0.0262	0.0274	0.0266	0.026	0.0262	0.03	0.0274	0.0271	0.03	0 of 12
AROCLOR-1242	0.027	0.0263	0.0294	0.0263	0.0269	0.0262	0.0274	0.0266	0.026	0.0262	0.03	0.0274	0.0271	0.03	0 of 12
AROCLOR-1248	0.027	0.0263	0.0294	0.0263	0.0269	0.0262	0.0274	0.0266	0.026	0.0262	0.03	0.0274	0.0271	0.03	0 of 12

**Average Effluent Concentrations  
Deer Island Wastewater Treatment Plant - Fiscal Year 2022**

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
<b>Pesticides and PCBs (ug/L) (cont.)</b>															
AROCLOR-1254	0.027	0.0263	0.0294	0.0263	0.0269	0.0262	0.0274	0.0266	0.026	0.0262	0.03	0.0274	0.0271	0.03	0 of 12
AROCLOR-1260	0.027	0.0263	0.0294	0.0263	0.0269	0.0262	0.0274	0.0266	0.026	0.0262	0.03	0.0274	0.0271	0.03	0 of 12
BETA-BHC	0.000433	0.000421	0.00047	0.00042	0.00043	0.00042	0.000439	0.000426	0.000417	0.000419	0.00048	0.00044	0.000434	0.000479	0 of 12
CHLORDANE (TECHNICAL)	0.0541	0.0526	0.0588	0.0526	0.0538	0.0524	0.0549	0.0532	0.0521	0.0524	0.0599	0.0549	0.0543	0.0599	0 of 12
DELTA-BHC	0.000433	0.000421	0.00047	0.00042	0.00043	0.00042	0.000439	0.000426	0.000417	0.000419	0.00048	0.00044	0.000434	0.000479	0 of 12
DIELDRIN	0.000433	0.000421	0.00047	0.00042	0.00043	0.00042	0.000439	0.000426	0.000417	0.000419	0.00048	0.00044	0.000434	0.000479	0 of 12
ENDOSULFAN I	0.000433	0.000421	0.00047	0.00042	0.00043	0.00042	0.000439	0.000426	0.000417	0.000419	0.00048	0.00044	0.000434	0.000479	0 of 12
ENDOSULFAN II	0.000541	0.000526	0.000588	0.00053	0.000538	0.00052	0.000549	0.000532	0.000521	0.000524	0.0006	0.00055	0.000543	0.000599	0 of 12
ENDOSULFAN SULFATE	0.000541	0.000526	0.000588	0.00053	0.000538	0.00052	0.000549	0.000532	0.000521	0.000524	0.0006	0.00055	0.000543	0.000599	0 of 12
ENDRIN	0.000433	0.000421	0.00047	0.00042	0.00043	0.00042	0.000439	0.000426	0.000417	0.000419	0.00048	0.00044	0.000434	0.000479	0 of 12
ENDRIN ALDEHYDE	0.000541	0.000526	0.000588	0.00053	0.000538	0.00052	0.000549	0.000532	0.000521	0.000524	0.0006	0.00055	0.000543	0.000599	0 of 12
ENDRIN KETONE	0.000541	0.000526	0.000588	0.00053	0.000538	0.00052	0.000549	0.000532	0.000521	0.000524	0.0006	0.00055	0.000543	0.000599	0 of 12
GAMMA-BHC	0.000433	0.000421	0.00047	0.00042	0.00043	0.00042	0.000439	0.000426	0.000417	0.000419	0.00048	0.00044	0.000434	0.000479	0 of 12
GAMMA-CHLORDANE	0.000433	0.000421	0.00047	0.00042	0.00043	0.00042	0.000439	0.000426	0.000417	0.000419	0.00048	0.00044	0.000434	0.000479	0 of 12
HEPTACHLOR	0.000433	0.000421	0.00047	0.00042	0.00043	0.00042	0.000439	0.000426	0.000417	0.000419	0.00048	0.00044	0.000434	0.000479	0 of 12
HEPTACHLOR EPOXIDE	0.000433	0.000421	0.00047	0.00042	0.00043	0.00042	0.000439	0.000426	0.000417	0.000419	0.00048	0.00044	0.000434	0.000479	0 of 12
HEXACHLOROBENZENE	0.000433	0.000421	0.00047	0.00042	0.00043	0.00042	0.000439	0.000426	0.000417	0.000419	0.00048	0.00044	0.000434	0.000479	0 of 12
METHOXYCHLOR	0.00541	0.00526	0.00588	0.00526	0.00538	0.00524	0.00549	0.00532	0.00521	0.00524	0.00599	0.00549	0.00543	0.00599	0 of 12
TOTAL AMP PCBs	0.00134	0.00119	0.00144	0.00127	0.00116	0.00199	0.00194	0.00352	0.00571	0.0044	0.00109	0.00106	0.00218	0.00601	48 of 48
TOXAPHENE	0.0541	0.0526	0.0588	0.0526	0.0538	0.0524	0.0549	0.0532	0.0521	0.0524	0.0599	0.0549	0.0543	0.0599	0 of 12
<b>Pesticides and PCBs (ug/L) - low detection limit methods</b>															
2,4'-DDD	0.000147	0.000169	0.000263	0.0009	0.000139	0.00014	0.000117	0.000105	0.000103	0.000106	0.00011	0.00011	0.000207	0.00283	26 of 48
2,4'-DDE	0.000102	0.000105	0.000108	0.00011	0.000103	0.00011	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000105	0.000116	0 of 48
2,4'-DDT	0.000102	0.000105	0.000108	0.00032	0.000756	0.00032	0.00103	0.000646	0.000103	0.00135	0.00011	0.00011	0.000406	0.00141	20 of 48
4,4'-DDD	0.000106	0.000109	0.000108	0.00012	0.000103	9.9E-05	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000107	0.000165	7 of 48
4,4'-DDE	0.000245	0.000147	0.000327	0.00013	0.00021	0.00019	0.00019	0.000318	0.000265	0.000273	0.00014	0.0002	0.000225	0.000409	44 of 48
4,4'-DDT	0.000108	0.000129	0.000103	0.0001	0.000103	0.00011	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000107	0.000223	5 of 48
ALDRIN	0.000102	0.000105	0.000108	0.00011	0.000103	0.00011	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000105	0.000116	0 of 48
ALPHA-CHLORDANE	0.00115	0.000858	0.00118	0.00037	0.000759	0.00056	0.000552	0.00129	0.00139	0.000883	0.00099	0.00082	0.000929	0.00167	48 of 48
BZ 101 PENTACHLOROBIPHENYL	0.000243	0.000169	0.000229	0.00014	0.000143	0.00011	0.000113	0.000149	0.000168	0.000123	0.00028	0.00027	0.000179	0.000458	46 of 48
BZ 105 PENTACHLOROBIPHENYL	9.34E-05	0.000113	0.000118	0.00013	9.51E-05	9E-05	0.000107	0.000119	0.000179	0.00017	0.00011	0.00011	0.000119	0.000239	22 of 48
BZ 118 PENTACHLOROBIPHENYL	0.000106	4.91E-05	0.0001	0.00011	0.000103	0.000128	0.00142	0.00281	0.00489	0.00353	0.0002	0.00013	0.00121	0.00524	34 of 48
BZ 126 PENTACHLOROBIPHENYL	0.000102	0.000105	0.000108	0.00011	0.000103	0.00011	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000105	0.000116	0 of 48
BZ 128 HEXACHLOROBIPHENYL	0.000043	6.42E-05	7.37E-05	0.00014	0.000103	6.7E-05	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	9.16E-05	0.000228	12 of 48
BZ 138 HEXACHLOROBIPHENYL	0.0002	0.000204	0.000276	0.00016	0.00018	0.00015	0.000173	0.000167	0.000176	0.000221	0.0002	0.00017	0.000192	0.000437	48 of 48
BZ 153 HEXACHLOROBIPHENYL	0.000208	0.000185	0.000235	0.00016	0.000155	0.00014	0.000158	0.000153	0.000149	0.000141	0.00016	0.00017	0.000171	0.000331	48 of 48
BZ 170 HEPTACHLOROBIPHENYL	7.13E-05	0.000105	0.000108	0.00013	0.000103	0.00011	0.000107	0.000105	0.000103	0.000106	9.7E-05	0.00011	0.000103	0.000207	4 of 48
BZ 18 TRICHLOROBIPHENYL	0.000102	0.000105	0.000108	0.00011	0.000103	0.00011	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000105	0.000116	0 of 48
BZ 180 HEPTACHLOROBIPHENYL	0.000131	8.94E-05	0.000111	0.0001	0.000103	8.4E-05	0.000107	0.000105	0.000103	0.000103	0.00014	0.00011	0.000108	0.000226	26 of 48
BZ 187 HEPTACHLOROBIPHENYL	8.24E-05	7.33E-05	7.22E-05	9.2E-05	0.000414	7.1E-05	0.000107	0.000105	0.000103	0.000106	0.0001	8.7E-05	0.000121	0.00087	25 of 48
BZ 195 OCTACHLOROBIPHENYL	0.000102	0.000105	0.000108	0.00011	0.000103	0.00011	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000106	0.000127	1 of 48
BZ 206 NONACHLOROBIPHENYL	0.000102	0.000199	0.000108	0.00012	0.000103	9.1E-05	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000113	0.000466	3 of 48
BZ 209 DECACHLOROBIPHENYL	9.31E-05	8.61E-05	7.01E-05	7.5E-05	6.89E-05	4.1E-05	0.000107	0.000105	7.22E-05	8.05E-05	9.3E-05	0.00012	8.41E-05	0.000194	36 of 48
BZ 28 TRICHLOROBIPHENYL	0.000102	0.000105	0.000123	0.00012	0.000103	0.00011	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000108	0.000159	4 of 48
BZ 44 TETRACHLOROBIPHENYL	6.71E-05	0.000105	8.71E-05	0.00014	0.000103	8.5E-05	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000101	0.00025	8 of 48
BZ 52 TETRACHLOROBIPHENYL	0.000139	0.000151	0.000183	9.7E-05	0.000109	7.6E-05	6.96E-05	9.29E-05	0.000119	0.000115	0.00013	0.00016	0.000122	0.000297	47 of 48
BZ 66 TETRACHLOROBIPHENYL	0.000102	8.53E-05	0.000103	0.00011	0.000103	8.7E-05	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000102	0.000138	4 of 48
BZ 77 TETRACHLOROBIPHENYL	8.12E-05	0.000147	0.000108	6.7E-05	0.000103	0.00011	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000103	0.000227	5 of 48
BZ 8 DICHLOROBIPHENYL	0.000102	0.000105	0.000108	0.00011	0.000103	0.00011	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000105	0.000116	0 of 48

**Average Effluent Concentrations  
Deer Island Wastewater Treatment Plant - Fiscal Year 2022**

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
<b>Pesticides and PCBs (ug/L) - low detection limit methods (cont.)</b>															
CIS-NONACHLOR	0.000152	0.000111	0.000219	0.00012	0.000114	7E-05	0.000101	0.000139	0.000143	0.000129	0.00012	0.00011	0.000132	0.000253	40 of 48
DDMU	0.000102	0.000105	0.000108	0.00011	0.000103	0.00011	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000105	0.000116	0 of 48
DIELDRIN	0.000102	0.000105	0.00118	0.00011	0.000103	0.00011	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000214	0.00134	4 of 48
ENDRIN	0.000102	0.000105	0.000108	0.00011	0.000103	0.00011	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000105	0.000116	0 of 48
GAMMA-BHC	0.000102	0.000105	0.000108	0.00011	0.000103	0.00011	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000105	0.000116	0 of 48
GAMMA-CHLORDANE	0.000969	0.000802	0.000934	0.00078	0.00191	0.00104	0.00107	0.00274	0.00463	0.00296	0.00107	0.00064	0.00166	0.00508	48 of 48
HEPTACHLOR	0.000102	0.000105	0.000108	0.00011	0.000103	9.2E-05	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000104	0.000116	2 of 48
HEPTACHLOR EPOXIDE	0.000102	0.000105	0.000108	0.00011	0.000103	0.00011	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000105	0.000116	0 of 48
HEXACHLOROBENZENE	0.000363	0.000388	0.000228	0.0002	0.000211	0.00043	0.000416	0.00056	0.000657	0.000546	0.00061	0.00067	0.000424	0.000823	48 of 48
MIREX	0.000102	0.000105	0.000108	0.00011	0.000103	0.00011	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000105	0.000116	0 of 48
OXYCHLORDANE	0.000102	0.000105	0.000108	0.00011	0.000103	0.00011	0.000107	0.000105	0.000103	0.000106	0.00011	0.00011	0.000105	0.000116	0 of 48
TOTAL CHLORDANE	0.00168	0.00125	0.0018	0.00058	0.00115	0.0008	0.000755	0.0018	0.00196	0.00126	0.00128	0.00109	0.00133	0.00244	48 of 48
TOTAL DDT	0.000494	0.000344	0.00061	0.00142	0.0011	0.00057	0.00133	0.000935	0.000265	0.00163	0.00014	0.0002	0.000758	0.00327	47 of 48
TRANS-NONACHLOR	0.000532	0.000394	0.000619	0.00021	0.00039	0.0002	0.000204	0.000506	0.000573	0.000382	0.0003	0.00027	0.000402	0.000775	48 of 48
<b>Semivolatile Organics (ug/L)</b>															
1,2,4-TRICHLOROBENZENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
1,2-DIPHENYLHYDRAZINE (AS AZOBENZENE)	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
2,2'-OXYBIS(1-CHLOROPROPANE)	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
2,4,5-TRICHLOROPHENOL	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
2,4,6-TRICHLOROPHENOL	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
2,4-DICHLOROPHENOL	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
2,4-DIMETHYLPHENOL	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
2,4-DINITROPHENOL	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
2,4-DINITROTOLUENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
2,6-DINITROTOLUENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
2-CHLORONAPHTHALENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
2-CHLOROPHENOL	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
2-METHYL-4,6-DINITROPHENOL	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
2-METHYLNAPHTHALENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
2-METHYLPHENOL	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
2-NITROANILINE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
2-NITROPHENOL	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
3,3'-DICHLOROBENZIDINE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
3-NITROANILINE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
4-BROMOPHENYL PHENYL ETHER	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
4-CHLORO-3-METHYLPHENOL	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
4-CHLOROANILINE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
4-CHLOROPHENYL PHENYL ETHER	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
4-METHYLPHENOL (INCLUDES 3-METHYLPHENOL)	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
4-NITROANILINE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
4-NITROPHENOL	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
ACENAPHTHENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
ACENAPHTHYLENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
ANILINE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24

**Average Effluent Concentrations  
Deer Island Wastewater Treatment Plant - Fiscal Year 2022**

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
<b>Semivolatle Organics (ug/L) (cont.)</b>															
ANTHRACENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
BENZIDINE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
BENZO(A)ANTHRACENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
BENZO(A)PYRENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
BENZO(B)FLUORANTHENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
BENZO(G,H,I)PERYLENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
BENZO(K)FLUORANTHENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
BENZOIC ACID	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
BENZYL ALCOHOL	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
BIS(2-CHLOROETHOXY)METHANE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
BIS(2-CHLOROETHYL)ETHER	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
BIS(2-ETHYLHEXYL)PHTHALATE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
BUTYLBENZYLPHTHALATE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
CARBAZOLE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
CHRYSENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
DIBENZO(A,H)ANTHRACENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
DIBENZOFURAN	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
DIETHYLPHTHALATE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
DIMETHYLPHTHALATE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
DI-N-BUTYLPHTHALATE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
DI-N-OCTYLPHTHALATE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
FLUORANTHENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
FLUORENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
HEXACHLOROBENZENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
HEXACHLOROBUTADIENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
HEXACHLOROCYCLOPENTADIENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
HEXACHLOROETHANE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
INDENO(1,2,3-CD)PYRENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
ISOPHORONE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
NAPHTHALENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
N-DECANE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
NITROBENZENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
N-NITROSODIMETHYLAMINE (NDMA)	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
N-NITROSODI-N-PROPYLAMINE (NDPA)	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
N-NITROSODIPHENYLAMINE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
N-OCTADECANE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
PENTACHLOROPHENOL	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
PHENANTHRENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
PHENOL	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
PYRENE	1.95	1.97	1.96	1.95	1.89	1.94	1.97	1.89	1.92	1.95	2.01	2.08	1.95	2.11	0 of 24
<b>Polyaromatic Hydrocarbons (ug/L) - low detection limit methods</b>															
1-METHYLNAPHTHALENE	0.00171	0.00247	0.00261	0.00296	0.00356	0.00368	0.00518	0.00532	0.00501	0.00525	0.00436	0.00424	0.00374	0.00665	48 of 48
1-METHYLPHENANTHRENE	0.00142	0.00255	0.00208	0.0011	0.00105	0.00173	0.0015	0.00216	0.00264	0.0013	0.00112	0.00235	0.00175	0.00329	48 of 48
2,3,5-TRIMETHYLNAPHTHYLENE	0.00375	0.00519	0.0043	0.00554	0.00298	0.00541	0.00281	0.00586	0.00596	0.00368	0.0033	0.00489	0.00448	0.00812	48 of 48
2,6-DIMETHYLNAPHTHALENE	0.00177	0.00199	0.00163	0.00178	0.00192	0.00552	0.00278	0.00215	0.00292	0.00332	0.0022	0.00317	0.00246	0.00647	48 of 48
2-METHYLNAPHTHALENE	0.00168	0.00302	0.00264	0.00248	0.00209	0.00338	0.00659	0.0074	0.00647	0.00243	0.00206	0.00499	0.00369	0.0107	48 of 48
ACENAPHTHENE	0.00489	0.00697	0.0058	0.00504	0.00599	0.0144	0.0152	0.017	0.0147	0.00666	0.0066	0.00808	0.00903	0.0192	48 of 48
ACENAPHTHYLENE	0.000333	0.0005	0.000447	0.00027	0.000383	0.00071	0.0012	0.00114	0.000772	0.000328	0.00042	0.00044	0.000566	0.00155	27 of 48



**Average Effluent Concentrations  
Deer Island Wastewater Treatment Plant - Fiscal Year 2022**

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
<b>Polyaromatic Hydrocarbons (ug/L) - low detection limit methods (cont.)</b>															
ANTHRACENE	0.00164	0.00249	0.00208	0.0012	0.00128	0.00207	0.00201	0.00228	0.00374	0.0016	0.00145	0.00341	0.00208	0.00531	48 of 48
BENZO(A)ANTHRACENE	0.00291	0.0034	0.003	0.00136	0.00193	0.00291	0.00258	0.00481	0.00976	0.00418	0.00321	0.00436	0.0037	0.0114	48 of 48
BENZO(A)PYRENE	0.00214	0.00232	0.00213	0.00077	0.00183	0.00265	0.00325	0.00432	0.00922	0.0035	0.00268	0.00304	0.00314	0.0109	48 of 48
BENZO(B)FLUORANTHENE	0.00422	0.00389	0.00383	0.00101	0.00228	0.00231	0.00238	0.00892	0.0177	0.0069	0.00546	0.00537	0.00543	0.0204	48 of 48
BENZO(E)PYRENE	0.00228	0.00229	0.00232	0.00115	0.00141	0.00151	0.00156	0.00411	0.00956	0.00369	0.00295	0.00265	0.003	0.0114	48 of 48
BENZO(G,H,I)PERYLENE	0.00151	0.00188	0.00158	0.00068	0.00114	0.0011	0.00109	0.00301	0.00725	0.00263	0.00182	0.00221	0.00218	0.00865	48 of 48
BENZO(K)FLUORANTHENE	0.00124	0.00209	0.00109	0.00036	0.0026	0.00218	0.00263	0.00243	0.00498	0.00177	0.00124	0.00168	0.00201	0.00636	45 of 48
BENZOTHAZOLE	0.138	0.186	0.161	0.146	0.0624	0.0941	0.209	0.188	0.168	0.172	0.194	0.192	0.157	0.241	48 of 48
BIPHENYL	0.00133	0.00216	0.0022	0.00173	0.00154	0.00218	0.0028	0.00168	0.00176	0.00124	0.00136	0.00173	0.00179	0.00349	48 of 48
C1-CHRYSENES	0.00253	0.0025	0.00272	0.0017	0.00261	0.00289	0.00302	0.00359	0.00642	0.00338	0.00309	0.00322	0.00313	0.00744	48 of 48
C1-DIBENZOTHIOPHENES	0.00412	0.00549	0.0051	0.00394	0.0051	0.00738	0.00725	0.00693	0.00781	0.00645	0.00642	0.00829	0.00601	0.01	48 of 48
C1-FLUORANTHENES/PYRENES	0.00429	0.00402	0.00379	0.00318	0.00386	0.00428	0.00437	0.00496	0.00841	0.00454	0.00376	0.00485	0.00453	0.00941	48 of 48
C1-FLUORENES	0.00649	0.00894	0.0076	0.00718	0.00704	0.0099	0.0106	0.0111	0.011	0.00746	0.0074	0.0115	0.00869	0.0143	48 of 48
C1-NAPHTHALENES	0.00381	0.00617	0.00567	0.00459	0.00447	0.00558	0.00837	0.009	0.00819	0.00567	0.00501	0.00699	0.00604	0.0122	48 of 48
C1-PHENANTHRENES/ANTHRACENES	0.00859	0.0124	0.011	0.00815	0.0101	0.0164	0.0168	0.0163	0.0224	0.0126	0.0121	0.0179	0.0134	0.0232	48 of 48
C2-CHRYSENES	0.000254	0.000264	0.000269	0.00027	0.000257	0.00026	0.000267	0.000264	0.000258	0.000265	0.00026	0.00027	0.000262	0.000289	0 of 48
C2-DIBENZOTHIOPHENES	0.000254	0.000264	0.000269	0.00027	0.000257	0.00026	0.000267	0.000264	0.000258	0.000265	0.00026	0.00027	0.000262	0.000289	0 of 48
C2-FLUORANTHENES/PYRENES	0.00231	0.00216	0.00186	0.00165	0.00201	0.00207	0.00222	0.00263	0.00445	0.00251	0.00204	0.00232	0.00236	0.00516	48 of 48
C2-FLUORENES	0.00696	0.00811	0.0074	0.00634	0.00744	0.00902	0.0101	0.0127	0.0139	0.00745	0.00765	0.0107	0.00891	0.0157	48 of 48
C2-NAPHTHALENES	0.00481	0.00764	0.00588	0.00765	0.00564	0.00746	0.00905	0.00818	0.00874	0.00613	0.00493	0.00797	0.00691	0.0143	48 of 48
C2-PHENANTHRENES/ANTHRACENES	0.00534	0.00641	0.00578	0.00544	0.00678	0.00647	0.0065	0.00675	0.00947	0.00707	0.00606	0.00812	0.00662	0.0107	48 of 48
C3-CHRYSENES	0.000254	0.000264	0.000269	0.00027	0.000257	0.00026	0.000267	0.000264	0.000258	0.000265	0.00026	0.00027	0.000262	0.000289	0 of 48
C3-DIBENZOTHIOPHENES	0.000254	0.000264	0.000269	0.00027	0.000257	0.00026	0.000267	0.000264	0.000258	0.000265	0.00026	0.00027	0.000262	0.000289	0 of 48
C3-FLUORANTHENES/PYRENES	0.000254	0.000264	0.000269	0.00027	0.000257	0.00026	0.000267	0.000264	0.000258	0.000265	0.00026	0.00027	0.000262	0.000289	0 of 48
C3-FLUORENES	0.000254	0.000264	0.000269	0.00027	0.000257	0.00026	0.000267	0.000264	0.000258	0.000265	0.00026	0.00027	0.000262	0.000289	0 of 48
C3-NAPHTHALENES	0.011	0.0157	0.0137	0.0175	0.0157	0.0213	0.019	0.022	0.021	0.0122	0.0111	0.0166	0.0163	0.0249	48 of 48
C3-PHENANTHRENES/ANTHRACENES	0.0041	0.00462	0.0054	0.00375	0.00528	0.00462	0.00494	0.00579	0.00889	0.0062	0.00699	0.00726	0.00558	0.0097	48 of 48
C4-CHRYSENES	0.000254	0.000264	0.000269	0.00027	0.000257	0.00026	0.000267	0.000264	0.000258	0.000265	0.00026	0.00027	0.000262	0.000289	0 of 48
C4-NAPHTHALENES	0.000254	0.000264	0.000269	0.00027	0.000257	0.00026	0.000267	0.000264	0.000258	0.000265	0.00026	0.00027	0.000262	0.000289	0 of 48
C4-PHENANTHRENES/ANTHRACENES	0.000254	0.000264	0.000269	0.00027	0.000257	0.00026	0.000267	0.000264	0.000258	0.000265	0.00026	0.00027	0.000262	0.000289	0 of 48
CHRYSENE	0.00408	0.00443	0.00367	0.00184	0.00267	0.00328	0.00318	0.00708	0.0145	0.00611	0.00437	0.0056	0.0051	0.0173	48 of 48
DIBENZO(A,H)ANTHRACENE	0.000254	0.000264	0.000269	0.00027	0.000257	0.00026	0.000267	0.000892	0.00181	0.000727	0.00026	0.00136	0.000562	0.00222	16 of 48
DIBENZOFURAN	0.00814	0.00764	0.00714	0.00467	0.00382	0.00618	0.00707	0.00609	0.00696	0.00464	0.00406	0.00839	0.00628	0.0113	48 of 48
DIBENZOTHIOPHENE	0.00298	0.00519	0.00372	0.00389	0.00288	0.00495	0.00536	0.00492	0.00588	0.00385	0.00533	0.00594	0.00444	0.00845	48 of 48
FLUORANTHENE	0.0118	0.0113	0.0105	0.00679	0.00755	0.0107	0.0103	0.0182	0.0322	0.0137	0.00947	0.0155	0.0132	0.0375	48 of 48
FLUORENE	0.00539	0.00761	0.00706	0.00463	0.00372	0.00638	0.00781	0.00713	0.00799	0.00418	0.00356	0.00898	0.00616	0.013	48 of 48
INDENO(1,2,3-CD)PYRENE	0.00421	0.00576	0.00505	0.00211	0.00387	0.00683	0.00678	0.009	0.0178	0.0126	0.0111	0.00751	0.00749	0.0198	48 of 48
NAPHTHALENE	0.00303	0.00459	0.00468	0.00333	0.00289	0.00441	0.00918	0.0126	0.0109	0.00427	0.00331	0.00668	0.00579	0.0166	48 of 48
PERYLENE	0.000254	0.00038	0.000269	0.00027	0.000257	0.00026	0.000267	0.00323	0.00419	0.00296	0.00347	0.00261	0.00146	0.00615	21 of 48
PHENANTHRENE	0.0117	0.0168	0.0153	0.00748	0.00802	0.0142	0.0157	0.0178	0.023	0.00871	0.00849	0.0199	0.0138	0.0295	48 of 48
PYRENE	0.0119	0.00987	0.00978	0.00613	0.00808	0.00889	0.00839	0.014	0.0245	0.0124	0.00927	0.0138	0.0115	0.0281	48 of 48
<b>Volatile Organics (ug/L)</b>															
1,1,1-TRICHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
1,1,2,2-TETRACHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
1,1,2-TRICHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
1,1-DICHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
1,1-DICHLOROETHENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
1,2-DICHLOROBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24

**Average Effluent Concentrations  
Deer Island Wastewater Treatment Plant - Fiscal Year 2022**

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
<b>Volatile Organics (ug/L) (cont.)</b>															
1,2-DICHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
1,2-DICHLOROPROPANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
1,3-DICHLOROBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
1,4-DICHLOROBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
2-BUTANONE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
2-CHLOROETHYL VINYL ETHER	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
2-HEXANONE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
4-METHYL-2-PENTANONE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
ACETONE	13.8	1	1	1	1	1	1	1	1	1	1	1	2.29	27	1 of 24
ACROLEIN	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0 of 24
ACRYLONITRILE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
BENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
BROMODICHLOROMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
BROMOFORM	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
BROMOMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
CARBON DISULFIDE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
CARBON TETRACHLORIDE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
CHLOROBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
CHLOROETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
CHLOROFORM	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
CHLOROMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
CIS-1,2-DICHLOROETHENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
CIS-1,3-DICHLOROPROPENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
DIBROMOCHLOROMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
ETHYLBENZENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
M,P-XYLENE	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0 of 24
METHYLENE CHLORIDE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
O-XYLENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
STYRENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
TETRACHLOROETHENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
TOLUENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
TRANS-1,2-DICHLOROETHENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
TRANS-1,3-DICHLOROPROPENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
TRICHLOROETHENE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
TRICHLOROFLUOROMETHANE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
VINYL ACETATE	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0 of 24
VINYL CHLORIDE	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0 of 24

**Notes:** Where parameters were below detection levels, one half of the method detection limit for inorganic compounds or one tenth of the quantitation limit for organic compounds was substituted to calculate concentrations. The annual average concentration is the flow-weighted average of all data points. The maximum concentration is the highest concentration observed in the monitoring year.

**Table H-4  
Comparison of Treatment Plant Effluent  
With Acute Water Quality Criteria\*  
Deer Island Treatment Plant - Fiscal Year 2022**

Instream Concentration (ug/L)**													
Parameter	Acute Criterion (ug/L)	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
<b>Arsenic</b>	<b>69</b>	0.008	0.008	0.0161	0.016	0.008	0.008	0.008	0.008	0.008	0.008	0.0189	0.0175
<b>Cadmium</b>	<b>33</b>	0.0014	0.0011	0.001	0.001	0.0012	0.001	0.0008	0.0014	0.002	0.0023	0.0011	0.0012
<b>Chromium</b>	<b>A</b>	0.007	0.0446	0.007	0.007	0.007	0.0474	0.007	0.007	0.007	0.007	0.007	0.0163
<b>Copper</b>	<b>4.8</b>	0.1148	0.1004	0.1516	0.106	0.0984	0.1532	0.1098	0.1402	0.1674	0.1576	0.1626	0.1288
<b>Cyanide</b>	<b>1.0</b>	0.2	0.2	0.2	0.2	0.2	0.2	0.732	0.2	0.2	0.2	0.2	0.2
<b>Lead</b>	<b>210</b>	0.0194	0.012	0.012	0.012	0.012	0.012	0.012	0.012	0.0252	0.012	0.012	0.012
<b>Mercury</b>	<b>1.8</b>	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0002	0.0001	0.0001	0.0001
<b>Nickel</b>	<b>74</b>	0.038	0.0434	0.0474	0.0368	0.0286	0.0348	0.0422	0.1344	0.034	0.0422	0.0352	0.0498
<b>Silver</b>	<b>0.95</b>	0.0009	0.0009	0.0009	0.0009	0.0009	0.0009	0.0009	0.0009	0.0009	0.0009	0.0009	0.0009
<b>Zinc</b>	<b>90</b>	0.452	0.302	0.272	0.29	0.336	0.268	0.276	0.498	0.628	0.492	0.464	0.302

Values that are bold and underlined are criteria exceedances.

For below detection levels, half the method detection limit is used when estimating concentrations to compare with water quality standards.

A No applicable criteria

\* EPA National Recommended Water Quality Criteria as incorporated into the Mass WQS [314 CMR 4.05(5)(e)]

\*\* Instream concentration calculated by dividing the maximum effluent concentration by 50, the dilution allowed in the permit for acute criterion compliance.

\*\*\* Instream concentration calculated by dividing the monthly average effluent concentration by 70, the dilution allowed in the permit for chronic criterion compliance.

**Table H-5  
Comparison of Treatment Plant Effluent  
With Chronic Water Quality Criteria\*  
Deer Island Treatment Plant - Fiscal Year 2022**

Instream Concentration (ug/L)**													
Parameter	Chronic Criterion (ug/L)	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
<b>Arsenic</b>	<b>36</b>	0.0057	0.0057	0.0087	0.0087	0.0057	0.0057	0.0057	0.0057	0.0057	0.0057	0.0096	0.0093
<b>Cadmium</b>	<b>7.9</b>	0.0009	0.0007	0.0006	0.0006	0.0007	0.0006	0.0005	0.0009	0.0012	0.0012	0.0007	0.0007
<b>Chromium</b>	<b>A</b>	0.005	0.0119	0.005	0.005	0.005	0.0123	0.005	0.005	0.005	0.005	0.005	0.0065
<b>Copper</b>	<b>3.1</b>	0.0714	0.0564	0.0769	0.0664	0.0627	0.0869	0.0753	0.0889	0.1143	0.1014	0.1093	0.0867
<b>Cyanide</b>	<b>1.0</b>	0.1429	0.1429	0.1429	0.1429	0.1429	0.1429	0.5229	0.1429	0.1429	0.1429	0.1429	0.1429
<b>Lead</b>	<b>8.1</b>	0.0097	0.0078	0.0084	0.0083	0.0081	0.0077	0.0076	0.0074	0.0109	0.0083	0.0082	0.0075
<b>Mercury</b>	<b>0.94</b>	0.0001	0.0001	0	0	0	0	0	0.0001	0.0001	0.0001	0.0001	0
<b>Nickel</b>	<b>8.2</b>	0.0186	0.0249	0.025	0.0223	0.0144	0.0171	0.0256	0.0387	0.0147	0.0223	0.0196	0.0309
<b>Silver</b>	<b>A</b>	0.0006	0.0006	0.0006	0.0006	0.0006	0.0006	0.0006	0.0006	0.0006	0.0006	0.0006	0.0006
<b>Zinc</b>	<b>81</b>	0.2886	0.2014	0.1814	0.1714	0.1771	0.1729	0.19	0.3314	0.3957	0.32	0.3114	0.19

Values that are bold and underlined are criteria exceedances.

For below detection levels, half the method detection limit is used when estimating concentrations to compare with water quality standards.

A No applicable criteria

\* EPA National Recommended Water Quality Criteria as incorporated into the Mass WQS [314 CMR 4.05(5)(e)]

\*\* Instream concentration calculated by dividing the maximum effluent concentration by 50, the dilution allowed in the permit for acute criterion compliance.

\*\*\* Instream concentration calculated by dividing the monthly average effluent concentration by 70, the dilution allowed in the permit for chronic criterion compliance.

# Appendix I

## Priority Pollutant Scan Results and Comparison of Influent and Effluent to Established Standards for Clinton

**Table I-1**  
**Average Influent Concentrations**  
**Clinton Wastewater Treatment Plant - Fiscal Year 2022**

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
<b>Metals and Cyanide (ug/L)</b>															
ALUMINUM	~	~	45	~	~	141	~	~	45	~	~	223	90.3	223	2 of 4
ANTIMONY	~	~	25	~	~	25	~	~	25	~	~	25	25	25	0 of 4
ARSENIC	~	~	3.51	~	~	3.42	~	~	2.22	~	~	4.38	3.25	4.38	4 of 4
BERYLLIUM	~	~	0.25	~	~	0.25	~	~	0.25	~	~	0.25	0.25	0.25	0 of 4
BORON	~	~	125	~	~	125	~	~	125	~	~	125	125	125	0 of 4
CADMIUM	~	~	1	~	~	1	~	~	1	~	~	1	1	1	0 of 4
CHROMIUM	~	~	2	~	~	2	~	~	2	~	~	2	2	2	0 of 4
COPPER	~	~	17.4	~	~	33.6	~	~	13.4	~	~	31.6	21.3	33.6	4 of 4
IRON	~	~	867	~	~	1980	~	~	616	~	~	2530	1250	2530	4 of 4
LEAD	~	~	0.6	~	~	1.71	~	~	0.6	~	~	2.22	1.05	2.22	2 of 4
MERCURY	~	~	0.0125	~	~	0.0125	~	~	0.0125	~	~	0.0125	0.0125	0.0125	0 of 4
MOLYBDENUM	~	~	7.5	~	~	7.5	~	~	7.5	~	~	7.5	7.5	7.5	0 of 4
NICKEL	~	~	2.5	~	~	2.5	~	~	2.5	~	~	2.5	2.5	2.5	0 of 4
SELENIUM	~	~	0.45	~	~	0.45	~	~	0.45	~	~	0.45	0.45	0.45	0 of 4
SILVER	~	~	1	~	~	1	~	~	1	~	~	1	1	1	0 of 4
THALLIUM	~	~	75	~	~	75	~	~	75	~	~	75	75	75	0 of 4
ZINC	~	~	37.3	~	~	88.8	~	~	68.5	~	~	104	66.3	104	4 of 4
CYANIDE	~	~	10	~	~	10	~	~	10	~	~	10	10	10	0 of 5
<b>Nutrients (mg/L)</b>															
AMMONIA	9.9	15.8	9.36	8.87	10.2	15.6	18.2	13.6	13.3	16.7	28.4	24.6	13.1	34	97 of 97
TOTAL PHOSPHORUS	3.14	4.53	2.78	2.73	2.57	3.75	5.29	3.59	4.17	4.95	6.66	6.46	3.93	15.6	132 of 132
<b>Conventional Parameters (mg/L)</b>															
CHEMICAL OXYGEN DEMAND	194	274	208	178	264	317	375	251	266	354	494	522	284	807	159 of 159
BIOCHEMICAL OXYGEN DEMAND	100	141	98.6	103	119	157	182	125	129	168	198	196	134	272	161 of 161
TOTAL SUSPENDED SOLIDS	160	219	170	186	176	185	267	169	175	261	293	309	203	760	162 of 162

**Notes:** Where parameters were below detection levels, one half of the method detection limit for inorganic compounds or one tenth of the quantitation limit for organic compounds was substituted to calculate concentrations. The annual average concentration is the flow-weighted average of all data points. The maximum concentration is the highest concentration observed in the monitoring year.  
~ No data

**Table I-2**  
**Comparison of Treatment Plant Influent With Threshold Inhibition Levels**  
**Clinton Treatment Plant Data - Fiscal Year 2022**

Parameter	EPA Inhibition Levels		Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
	Activated Sludge (ug/L)	Anaerobic Digestion (ug/L)												
	Average Concentration (ug/L)													
<b>Arsenic</b>	100	1600	~	~	3.51	~	~	3.42	~	~	2.22	~	~	4.38
<b>Cadmium</b>	1000	20000	~	~	1	~	~	1	~	~	1	~	~	1
<b>Chromium</b>	1000	130000	~	~	2	~	~	2	~	~	2	~	~	2
<b>Copper</b>	1000	40000	~	~	17.4	~	~	33.6	~	~	13.4	~	~	31.6
<b>Cyanide</b>	100	4000	~	~	10	~	~	10	~	~	10	~	~	10
<b>Lead</b>	100	340000	~	~	0.6	~	~	1.71	~	~	0.6	~	~	2.22
<b>Mercury</b>	100	<b>A</b>	~	~	0.0125	~	~	0.0125	~	~	0.0125	~	~	0.0125
<b>Nickel</b>	1000	10000	~	~	2.5	~	~	2.5	~	~	2.5	~	~	2.5
<b>Silver</b>	250	13000	~	~	1	~	~	1	~	~	1	~	~	1
<b>Zinc</b>	300	400000	~	~	37.3	~	~	88.8	~	~	68.5	~	~	104

Values that are bold and underlined are inhibition level exceedances

**A** No applicable criteria

~ No data

**Table I-3**  
**Average Effluent Concentrations**  
**Clinton Wastewater Treatment Plant - Fiscal Year 2022**

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Ave Annual	Max Annual	No of Detects
<b>Metals and Cyanide (ug/L)</b>															
ALUMINUM	~	~	3.13	~	~	14.1	~	~	3.13	~	~	3.13	5	23.9	2 of 12
ANTIMONY	~	~	0.313	~	~	0.313	~	~	0.313	~	~	0.313	0.313	0.313	0 of 12
ARSENIC	~	~	0.156	~	~	1.83	~	~	0.207	~	~	0.156	0.457	2.29	4 of 12
BERYLLIUM	~	~	0.0313	~	~	0.0313	~	~	0.0313	~	~	0.0313	0.0313	0.0313	0 of 12
BORON	~	~	125	~	~	125	~	~	125	~	~	125	125	125	0 of 12
CADMIUM	~	~	0.0688	~	~	0.13	~	~	0.0758	~	~	0.185	0.101	0.245	10 of 12
CHROMIUM	~	~	2	~	~	2	~	~	2	~	~	2	2	2	0 of 12
COPPER	8.63	7.39	7.38	7.12	6.62	10.5	9.2	10	7.06	7.15	10.1	12.3	8.38	12.9	25 of 25
IRON	~	~	406	~	~	748	~	~	629	~	~	675	575	960	12 of 12
LEAD	~	~	0.2	~	~	0.177	~	~	0.162	~	~	0.156	0.178	0.279	11 of 12
MERCURY	~	~	0.0125	~	~	0.0125	~	~	0.0125	~	~	0.0125	0.0125	0.0125	0 of 12
MOLYBDENUM	~	~	2.06	~	~	12.9	~	~	1.27	~	~	2.41	3.74	34.9	12 of 12
NICKEL	~	~	4.89	~	~	3.04	~	~	4.1	~	~	5.78	4.49	6.55	12 of 12
SELENIUM	~	~	0.313	~	~	0.313	~	~	0.313	~	~	0.313	0.313	0.313	0 of 12
SILVER	~	~	0.0625	~	~	0.0625	~	~	0.0625	~	~	0.0625	0.0625	0.0625	0 of 12
THALLIUM	~	~	0.0313	~	~	0.0625	~	~	0.0625	~	~	0.0625	0.0511	0.0625	0 of 12
ZINC	~	~	7.3	~	~	22	~	~	18.4	~	~	14.7	14.3	24.8	12 of 12
CYANIDE	~	~	10	~	~	10	~	~	10	~	~	10	10	10	0 of 4
<b>Nutrients (mg/L)</b>															
AMMONIA	0.1	0.1	0.0881	0.1	0.1	0.0779	0.1	0.143	0.125	0.103	0.1	0.0962	0.0999	0.407	19 of 109
ORTHOPHOSPHATE	0.0331	0.0171	0.014	0.0198	0.18	0.397	0.339	0.123	0.0612	0.0192	0.0337	0.0306	0.0976	0.57	500 of 522
TOTAL PHOSPHORUS	0.0255	0.0447	0.0409	0.0307	0.192	0.544	0.453	0.233	0.0891	0.0388	0.0655	0.0783	0.0942	0.788	131 of 139
<b>Conventional Parameters (mg/L)</b>															
CHEMICAL OXYGEN DEMAND	25.8	23.7	25.6	22.6	21	21.8	26.1	25.1	24.8	21.8	21.8	23.8	23.8	39	117 of 158
BIOCHEMICAL OXYGEN DEMAND	1.81	1.58	1.62	1.74	1.63	3.54	3.22	3.57	1.67	1.47	1.5	1.38	2.03	4.76	114 of 169
TOTAL SUSPENDED SOLIDS	1.52	1.47	1.55	1.57	1.19	4.35	4.93	5.04	2.82	2.12	2.2	1.83	2.43	7.8	152 of 168

**Notes:** Where parameters were below detection levels, one half of the method detection limit for inorganic compounds or one tenth of the quantitation limit for organic compounds was substituted to calculate concentrations. The annual average concentration is the flow-weighted average of all data points. The maximum concentration is the highest concentration observed in the monitoring year.  
~ No data



**Table I-4  
Comparison of Treatment Plant Effluent  
With Acute Water Quality Criteria\*  
Clinton Treatment Plant - Fiscal Year 2022**

**Instream Concentration (ug/L)\*\***

Parameter	Acute Criterion (ug/L)	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
Aluminum	<b>368</b>	~	~	1.9531	~	~	14.9375	~	~	1.9531	~	~	1.9531
Arsenic	<b>340</b>	~	~	0.0975	~	~	1.4313	~	~	0.2044	~	~	0.0975
Cadmium	<b>0.79</b>	~	~	0.0944	~	~	0.0956	~	~	0.0615	~	~	0.1531
Chromium	<b>258</b>	~	~	1.25	~	~	1.25	~	~	1.25	~	~	1.25
Copper <sup>†</sup>	<b>25.7</b>	5.3938	4.6188	5.3	4.45	4.1375	7.125	5.75	6.25	5.1188	4.4688	6.3125	8.0625
Cyanide	<b>22</b>	~	~	6.25	~	~	6.25	~	~	6.25	~	~	6.25
Lead	<b>22.2</b>	~	~	0.1494	~	~	0.1744	~	~	0.1138	~	~	0.11
Mercury	<b>1.4</b>	~	~	0.0078	~	~	0.0078	~	~	0.0078	~	~	0.0078
Nickel	<b>207</b>	~	~	4.0938	~	~	1.9563	~	~	2.5813	~	~	3.6563
Silver	<b>0.6090</b>	~	~	0.0391	~	~	0.0391	~	~	0.0391	~	~	0.0391
Zinc	<b>51.6</b>	~	~	4.8125	~	~	15.5	~	~	12.1875	~	~	9.75

Values that are bold and underlined are criteria exceedances

For below detection levels, half the method detection limit is used when estimating concentrations to compare with water quality standards.

\* EPA National Recommended Water Quality Criteria as incorporated into the Mass WQS [314 CMR 4.05(5)(e)]

\*\* Instream concentration calculated by dividing the maximum effluent concentration by 1.6, the dilution allowed in the permit for acute criterion compliance.

\*\*\* Instream concentration calculated by dividing the monthly average effluent concentration by 1.6, the dilution allowed in the permit for chronic criterion compliance.

† MassDEP established site specific criterion (314 CMR 4.00, Table 28)

A No applicable criteria

~ No data

**Table I-5  
Comparison of Treatment Plant Effluent  
With Chronic Water Quality Criteria\*  
Clinton Treatment Plant - Fiscal Year 2022**

**Instream Concentration (ug/L)\*\***

Parameter	Chronic Criterion (ug/L)	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun
Aluminum	200	~	~	1.9563	~	~	8.8125	~	~	1.9563	~	~	1.9563
Arsenic	150	~	~	0.0975	~	~	1.1438	~	~	0.1294	~	~	0.0975
Cadmium	0.13	~	~	0.043	~	~	0.0813	~	~	0.0474	~	~	0.1156
Chromium	33.55	~	~	1.25	~	~	1.25	~	~	1.25	~	~	1.25
Copper <sup>†</sup>	18.1	5.3938	4.6188	4.6125	4.45	4.1375	6.5625	5.75	6.25	4.4125	4.4688	6.3125	7.6875
Cyanide	5.20	~	~	<u>6.25</u>	~	~	<u>6.25</u>	~	~	<u>6.25</u>	~	~	<u>6.25</u>
Lead	0.8652	~	~	0.125	~	~	0.1106	~	~	0.1013	~	~	0.0975
Mercury	0.77	~	~	0.0078	~	~	0.0078	~	~	0.0078	~	~	0.0078
Nickel	22.9	~	~	3.0563	~	~	1.9	~	~	2.5625	~	~	3.6125
Silver	A	~	~	0.0391	~	~	0.0391	~	~	0.0391	~	~	0.0391
Zinc	52.0	~	~	4.5625	~	~	13.75	~	~	11.5	~	~	9.1875

Values that are bold and underlined are criteria exceedances

For below detection levels, half the method detection limit is used when estimating concentrations to compare with water quality standards.

\* EPA National Recommended Water Quality Criteria as incorporated into the Mass WQS [314 CMR 4.05(5)(e)]

\*\* Instream concentration calculated by dividing the maximum effluent concentration by 1.6, the dilution allowed in the permit for acute criterion compliance.

\*\*\* Instream concentration calculated by dividing the monthly average effluent concentration by 1.6, the dilution allowed in the permit for chronic criterion compliance.

† MassDEP established site specific criterion (314 CMR 4.00, Table 28)

A No applicable criteria

~ No data

# Appendix J

## Effluent Toxicity Tests

## Deer Island Wastewater Treatment Plant, Toxicity Test Results, FY22

	<b>Mysid*</b> <b>Acute</b>	<b>Arbacia**</b> <b>Chronic</b>	<b>Menidia***</b> <b>Acute</b>	<b>Menidia***</b> <b>Chronic</b>
<b>Limit</b>	50%	1.5%	50%	1.5%
<b>July 2021</b>	> 100	100	> 100	100
<b>August</b>	> 100	100	> 100	100
<b>September</b>	> 100	100	> 100	100
<b>October</b>	> 100	50	> 100	100
<b>November</b>	> 100	100	> 100	50
<b>December</b>	> 100	100	> 100	50
<b>January 2022</b>	> 100	100	> 100	100
<b>February</b>	> 100	100	> 100	50
<b>March</b>	> 100	100	> 100	50
<b>April</b>	> 100	100	> 100	50
<b>May</b>	> 100	100	> 100	100
<b>June</b>	> 100	100	> 100	50

\*Mysid is *Americamysis bahia*, a marine animal similar to a shrimp.

\*\*Arbacia is *Arbacia punctulata*, a sea urchin. Chronic test measures fertilization.

\*\*\*Menidia is *Menidia beryllina*, a small fish. Chronic test measures growth.

## Clinton Wastewater Treatment Plant, Toxicity Test Results, FY22

	<b>Acute</b>	<b>Chronic</b>
<b>Limit</b>	100%	62.5%
<b>Sep-21</b>	>100	100
<b>Dec-21</b>	>100	62.5
<b>Mar-22</b>	>100	62.5
<b>Jun-22</b>	>100	100

\*The toxicity tests use *Ceriodaphnia dubia*, a freshwater daphnid shrimp.

The chronic test measures reproduction.

## Appendix K

# Comparison of Sludge Quality to EPA and State Standards

## Residuals Quality

EPA and the MassDEP regulate the quality of sewage biosolids intended for beneficial use. At the federal level, these products are governed by the Clean Water Act. These regulations establish quality criteria for several metals and for the degree of pathogen reduction. Federal and state regulations have adopted a two-tiered approach to biosolids regulation. Products meeting the strictest standards for all parameters (MassDEP Type I) may be distributed or marketed with few restrictions. Products meeting only the less-prohibitive Type II standards may be used as fertilizer, but additional distribution, use restrictions and management practices apply. FY22, MWRA's biosolids met all applicable federal and state standards for unrestricted use as a fertilizer.

Federal and state limits for the distribution of biosolids as a MassDEP Type I Sludge with no limitations for land application are outlined in the tables below.

### Federal Limits (40 CFR 503.13, Table 3)

Pollutant	Monthly Average Concentrations (milligrams per kilogram, dry weight)
Arsenic	41
Cadmium	39
Chromium	1,200
Copper	1,500
Lead	300
Mercury	17
Nickel	420
Selenium	36
Zinc	2,800

### Massachusetts Limits for Type I Sludge (310 CMR 32.12, Table 32.12(2)(a))

Pollutant	Maximum Allowable Concentrations (milligrams per kilogram, dry weight)
Boron (water soluble)	300
Cadmium	14
Chromium (total)	1,000
Copper	1,000
Lead	300
Mercury	10
Molybdenum	40
Nickel	200
Zinc	2,500

## MWRA BIOSOLID PELLET METALS ANALYSIS, JULY '21 THROUGH JUNE '22

All concentrations are expressed in mg/kg, dry weight basis

	Most Stringent Limit	Jul '21	Aug '21	Sep '21	Oct '21	Nov '21	Dec '21	Jan '22	Feb '22	Mar '22	Apr '22	May '22	Jun '22
<b>ARSENIC</b>	<b>41</b>	4.6	4.3	3.0	4.3	4.0	3.8	3.7	3.6	3.1	3.7	3.4	3.9
<b>BORON</b>	<b>300</b>	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
<b>CADMIUM</b>	<b>14</b>	2.9	3.3	2.1	2.0	2.2	2.3	1.6	1.4	2.7	3.1	3.7	3.1
<b>CHROMIUM</b>	<b>1,000</b>	64.2	63.5	32.1	54.9	58.1	57.2	58.5	60.2	57.5	52.6	54.9	56.5
<b>COPPER</b>	<b>1,000</b>	555.3	575.3	376.8	565.5	555.3	544.2	536.3	504.0	522.0	477.5	475.0	504.8
<b>LEAD</b>	<b>300</b>	109.9	113.0	74.3	103.2	93.0	65.5	69.0	78.1	79.2	80.1	68.7	69.5
<b>MERCURY</b>	<b>10</b>	1.6	1.5	1.0	1.2	1.3	1.3	1.2	1.4	1.2	1.6	1.3	1.2
<b>MOLYBDENUM</b>	<b>40</b>	25.5	21.5	15.7	19.4	22.2	21.7	21.8	19.0	15.3	14.1	17.2	25.1
<b>NICKEL</b>	<b>200</b>	28.2	26.8	18.3	29.3	26.3	30.8	23.4	29.1	29.2	26.6	24.8	27.3
<b>SELENIUM</b>	<b>36</b>	5.5	5.0	3.5	3.8	4.3	4.4	4.0	3.0	3.7	3.7	4.6	4.4
<b>ZINC</b>	<b>2,500</b>	1,230.0	1,227.5	819.2	1,170.0	1,170.0	1,122.0	1,122.5	1,047.5	996.8	974.3	1,025.0	1,112.0

# Appendix L

## Summary of EPA Program Statistics Summary Report Form

- Metropolitan Boston
- Clinton



# EPA Region 1 Annual Pretreatment Report Summary Sheet

July 1, 2021 — June 30, 2022

POTW Name:

Massachusetts Water Resources Authority – Deer Island

NPDES Permit #:

MA01103284

Pretreatment Report Period Start Date:

7/1/2021

Pretreatment Report Period End Date:

6/30/2022

# of Significant Industrial Users (SIUs):

181

# of SIUs Without Control Mechanisms:

0

# of SIUs not Inspected:

0

# of SIUs not Sampled:

5\*

# of SIUs in Significant Noncompliance (SNC)  
With Pretreatment Standards:

30

# of SIUs in SNC with Reporting Requirements:

7

# of SIUs in SNC with Pretreatment Compliance  
Schedule:

0

# of SIUs in SNC Published in Newspaper:

29

# of SIUs with Compliance Schedules:

0

# of Violation Notices Issued to SIUs:

102

# of Administrative Orders Issued to SIUs:

7

# of Civil Suits Filed Against SIUs:

0

# of Criminal Suits Filed Against SIUs:

0

# of Categorical Industrial Users:

69

# of CIUs in SNC:

11

\*Discharging SIUs were not sampled because: they did not discharge during the year (three industries) or they went out of business early in fiscal year (two industries).

Penalties

Total Dollar Amount of Penalties Collected:

20,000.00

# of IUs from which Penalties have been collected:

0

Local Limits

Date of Most Recent Technical Evaluation  
Of Local Limits:

September 2001

Date of Most Recent Adoption of Technically  
Based Local Limits:

June 20, 2003

Pollutant	Limit (mg/l)	MAHL (lb/day)
See Appendix M.		

# EPA Region 1 Annual Pretreatment Report Summary Sheet

July 1, 2021—June 30, 2022

POTW Name:

Massachusetts Water Resources Authority – Clinton

NPDES Permit #:

MA0100404

Pretreatment Report Period Start Date:

07/01/2021

Pretreatment Report Period End Date:

06/30/2022

# of Significant Industrial Users (SIUs):

3

# of SIUs Without Control Mechanisms:

0

# of SIUs not Inspected:

0

# of SIUs not Sampled:

0

# of SIUs in Significant Noncompliance (SNC)  
With Pretreatment Standards:

0

# of SIUs in SNC with Reporting Requirements:

0

# of SIUs in SNC with Pretreatment Compliance  
Schedule:

0

# of SIUs in SNC Published in Newspaper:

0

# of SIUs with Compliance Schedules:

0

# of Violation Notices Issued to SIUs:

1

# of Administrative Orders Issued to SIUs:

0

# of Civil Suits Filed Against SIUs:

0

# of Criminal Suits Filed Against SIUs:

0

# of Categorical Industrial Users:

1

# of CIUs in SNC:

0

Penalties

Total Dollar Amount of Penalties Collected:

# of IUs from which Penalties have been collected:

Local Limits

Date of Most Recent Technical Evaluation  
Of Local Limits:

Date of Most Recent Adoption of Technically  
Based Local Limits:

Pollutant	Limit (mg/l)	MAHL (lb/day)
See Appendix M.		

Metropolitan (DITP)

# Appendix M

## ➤ Local Limits

### Metropolitan Area

Corrected MAHLs based on DITP Recycle Stream Loadings  
(2001)

Discharge Limitations/Local Limits from the MWRA Sewer  
Use Rules and Regulations (Metropolitan Area)

### Clinton Area

Discharge Limitations/Local Limits from the MWRA Sewer  
Use Rules and Regulations (specific to Clinton)

TABLE 3-II  
 MWRA LOCAL LIMITS DEVELOPMENT  
 CORRECTED MAHLS BASED ON DITP RECYCLE  
 STREAM LOADINGS (a)

	Prelim Calculated MAHL (lbs/day)	Corrected MAHL (lbs/day)	
2-Chloronaphthalene	5,081,832	5,081,832	
4,4'-DDT	0.201	0.201	
Antimony	7,584,824	7,584,824	
Arsenic	11.8	12.2	(a)
Benzidine	0.640	0.640	
Boron	2,592	2,773	(a)
Cadmium	2.71	2.86	(a)
Chromium, Hexavalent	3,247	3,247	
Chromium, Total	216	219	(a)
Copper	173	201	(a)
Cyanide	34.1	34.1	
Dioxins	16,234	1.65x10 <sup>-5</sup>	(b)
Fluoranthene	437,274	437,274	
Hexachlorobutadiene	59,091	59,091	
Lead	43.7	50.3	(a)
Mercury	1.51	1.58	(a)
Molybdenum	29.5	34.5	(a)
Nickel	89.4	92.2	(a)
Nitrogen, Total	95,750	95,750	
PCBs	0.201	0.201	
Pentachlorophenol	171	171	
Petroleum Hydrocarbons	167,936	167,936	
Phenanthrene	1,623,381	1,623,381	
Phenol	129,870	129,870	
Selenium	25.9	26.1	(a)
Silver	105	105	
Trichloroethylene	67.6	67.6	
Zinc	500	500	

Notes:

MAHLs were corrected for the pollutants that appear in bold.

(a) MAHLs were corrected for pollutants with MAHLs that are dependent on sludge criteria. Corrections were made to account for the effects of DITP recycle stream loadings.

(b) The Prelim calculated MAHL is not correct for dioxin, and Prelim could not be used to calculate the correct MAHL due to the very stringent dioxin water quality criteria (1.4x10<sup>-8</sup>), which could not be entered into Prelim correctly. Therefore, the corrected MAHL for dioxins was manually calculated.



September 2001

10.24 : Specific Discharge Limitations/Local Limits

- (1) Any discharge of the following materials is prohibited:
- (a) Into the Metropolitan Sewerage Service Area:
    1. Mercury (enforced at 0.001 mg/l);
    2. Polychlorinated Biphenyls (PCBs);
    3. Pesticides, unless the Authority determines upon request that the substance is acceptable for Discharge to the Sanitary Sewer under the criteria for exclusion or exemption in 40 CFR Parts 152 and 455, or that the substance is otherwise acceptable to Discharge, and that the substance would not otherwise violate 360 CMR 10.021 through 310 CMR 10.024; and
    4. Hexachlorobutadiene.
  - (b) Into the Clinton Sewerage Service Area:
    1. Mercury (enforced at 0.001 mg/l);
    2. Polychlorinated Biphenyls (PCBs);
    3. Pesticides, unless the Authority determines upon request that the substance is acceptable for discharge to the sanitary sewer under the criteria for exclusion or exemption in 40 CFR Parts 152 and 455, or that the substance is otherwise acceptable to discharge, and that the substance would not otherwise violate 360 CMR 10.021 through 310 CMR 10.024;
    4. Hexachlorobutadiene; and
    5. Substances listed in 360 CMR 10.000: *Appendix C*.
- (2) Any discharge of the following materials shall not exceed the daily maximum limit for that material:
- (a) Into the Metropolitan Sewerage Service Area:

<u>Material</u>	<u>Daily Maximum Limit (mg/l)</u>
Acrolein	0.15
Antimony (total)	10.0
Arsenic (total)	0.5
Benzene	0.3
Cadmium (total)	0.1
Chromium (hexavalent)	0.5
Chromium (total)	1.0
Copper (total)	1.0
Cyanide (total)	0.5
Formaldehyde	9.0
Lead (total)	0.2
Nickel (total)	1.0
Phenol	5.0
Selenium (total)	5.0
Silver (total)	2.0
Each Toxic Organic	1.0, unless elsewhere limited in 360 CMR 10.000 for the Metropolitan Sewerage Service Area
Total Toxic Organics	5.0
Vinyl Chloride	0.02
Vinylidene Chloride	0.3
Zinc (total)	1.0



10.024: continued

(b) Into the Clinton Sewerage Service Area:

<u>Material</u>	<u>Daily Maximum Limit mg/l</u>
Acrolein	0.5
Aluminum (total)	30.0
Arsenic (total)	0.5
Benzene	0.4
Bis(2-ethylhexyl)phthalate	0.2
Bromomethane	0.2
Cadmium (total)	0.5
Carbon disulfide	0.6
Carbon tetrachloride	0.1
Chromium (hexavalent)	1.0
Chromium (total)	5.0
Copper (total)	1.0
Cyanide (total)	1.0
Cyclohexane	0.6
1,1-Dichloroethylene	0.2
cis-1,3-Dichloropropene	0.6
trans-1,3-Dichloropropene	0.1
2,4-Dinitrotoluene	0.2
Formaldehyde	9.0
Hexachloroethane	0.2
Lead (total)	0.2
Nickel (total)	2.0
Nitrosamines	0.1
N-Nitrosodibutylamine	0.1
N-Nitrosodiethylamine	0.1
N-Nitrosodimethylamine	0.2
N-Nitrosodiphenylamine	0.5
Pentachlorobenzene	0.2
Selenium (total)	1.0
Silver (total)	1.0, except 2.0 for a Group Permit for Photo Processing and Printing Operations, and a Combined Permit
1,2,4,5-Tetrachlorobenzene	0.1
Trichlorofluoromethane	0.3
Each Toxic Organic	1.0, unless elsewhere limited in 360 CMR 10.000 for the Clinton Sewerage Service Area
Total Toxic Organics	5.0
Zinc	5.0

(3) The Daily Maximum Limit shall be determined on the basis of a Composite Sample, except a Grab Sample or Samples may be used in the following circumstances:

- (a) for a batch discharge, when the Grab Sample would be fairly representative of the batch as a whole;
- (b) for pollutants that are not amenable to composite sampling of an industrial wastestream by use of an automatic wastewater sampler, such as hexavalent chromium and volatile organics; or
- (c) when the Authority determines it is not feasible or appropriate to take a Composite Sample, such as when the discharge is of too short duration for automatic composite sampling or the sampling location is inaccessible for an automatic wastewater sampler.

10.24 : continued

A Composite Sample shall be taken at preselected intervals throughout the time in a day (or in a consecutive 24-hour period over two days when there is a continuous discharge of at least 24 hours over the course of the two days) during which the wastewater is discharged, except a shorter time period may be used if that shorter time period encompasses all or most of the wastewater discharge that day (or consecutive 24-hour period when there is a continuous discharge over the course of two days) or if a shorter period is authorized by the Authority. A batch discharge may have a Composite Sample taken throughout the discharge of the batch. A flow proportioned Composite Sample shall be taken, except a time interval Composite Sample may be taken when the Authority determines it is not feasible or appropriate to take a flow proportioned Composite Sample.

If a Grab Sample may appropriately be used, and more than one Grab Sample of a Discharge is taken during the day, the Daily Maximum Limit shall be measured by either the mathematical average of the analytical results of the Grab Samples or the analytical result of a composite of the Grab Samples.

10.25 : Dilution Prohibition

No person shall achieve, or attempt to achieve, compliance with 360 CMR 10.000 by diluting a Discharge instead of using proper pretreatment. The increased use of process water in place of proper treatment shall be considered dilution prohibited by 360 CMR 10.000.

10.26 : Compliance Measurement Location

All limitations imposed by 360 CMR 10.000 shall be applied at the end of the Pretreatment process line, at the end of the process line if there is no Pretreatment, or at or near the discharge location if there is no Pretreatment or process line. This shall not be construed to authorize a Person to introduce a pollutant into a wastestream after the compliance measurement location; rather, a sample taken at the compliance measurement location is intended to measure the pollutants in a discharge to the sewer before dilution of the wastestream.

Where it deems appropriate, the Authority may by permit or order impose alternative limits or compliance measurement locations to assure compliance with 360 CMR 10.000 and with federal, state, and local requirements. This may include use of the Combined Wastestream Formula when authorized by EPA regulations or use of a dilution factor when more than one stream is combined.

The Authority may require samples from individual process waste streams whether such waste streams are pretreated prior to discharge or not. The Authority may require that compliance measurement locations be clearly marked and/or photographed.

APPENDIX A: METROPOLITAN SEWERAGE SERVICE AREA TOXIC ORGANICS

<u>CAS #</u>	<u>NAME</u>
107-13-1	Acrylonitrile
75-25-2	Bromoform
75-27-4	Bromodichloromethane
74-83-9	Bromomethane
75-15-0	Carbon Disulfide
56-23-5	Carbon Tetrachloride
108-90-7	Chlorobenzene
75-00-3	Chloroethane
110-75-8	2-Chloroethyl Vinyl Ether (mixed)
67-66-3	Chloroform
74-87-3	Chloromethane
124-48-1	Dibromochloromethane
75-34-3	1,1 -Dichloroethane
107-06-2	1,2-Dichloroethane
156-60-5	t-1,2-Dichloroethene
78-87-5	1,2-Dichloropropane
10061-01-5	c-1,3-Dichloropropene
10061-02-6	t-1,3-Dichloropropene
75718	Dichlorodifluoromethane
100-41-4	Ethylbenzene
75-09-2	Methylene Chloride
100-42-5	Styrene
79-34-5	1,1,2,2-Tetrachloroethane
127-18-4	Tetrachloroethene
108-88-3	Toluene
71-55-6	1,1,1-Trichloroethane
79-00-5	1,1,2-Trichloroethane
79016	Trichloroethylene
75-69-4	Trichlorofluoromethane
108-05-4	Vinyl Acetate
1330-20-7	Xylene (total)
83-32-9	Acenaphthene
208-96-8	Acenaphthylene
120-12-7	Anthracene
92-87-5	Benzidine
56-55-3	Benzo(A) Anthracene
205-99-2	Benzo(B)Fluoranthene
207-08-9	Benzo(K)Fluoranthene
191-24-2	Benzo(GHI) Perylene
50-32-8	Benzo(A) Pyrene
85-68-7	Benzyl Butyl Phthalate
111-91-1	Bis (2-Chloroethoxy) Methane
111-44-4	Bis (2-Chloroethyl) Ether
117-81-7	Bis (2-Ethylhexyl) Phthalate
101-55-3	4-Bromophenyl Phenyl Ether
106-47-8	4-Chloroaniline
91-58-7	2-Chloronaphthalene
95578	2-Chlorophenol
7005-72-3	4-Chlorophenyl Phenyl Ether
218-01-9	Chrysene
53-70-3	Dibenzo (A,H) Anthracene
132-64-9	Dibenzo Furan
95-50-1	1,2-Dichlorobenzene
541-73-1	1,3-Dichlorobenzene
106-46-7	1,4-Dichlorobenzene

## APPENDIX A: continued

<u>CAS #</u>	<u>NAME</u>
91-94-1	3,3'-Dichlorobenzidine
120832	2,4-Dichlorophenol
84-66-2	Diethyl Phthalate
105679	2,4-Dimethylphenol
131-11-3	Dimethyl Phthalate
84-74-2	Di-n-butyl Phthalate
51285	2,4-Dinitrophenol
534-52-1	2-Methyl-4,6-Dinitrophenol
121-14-2	2,4-Dinitrotoluene
606-20-2	2,6-Dinitrotoluene
117-84-0	Di-n-octyl Phthalate
122-66-7	1,2-Diphenylhydrazine
206-44-0	Fluoranthene
86-73-7	Fluorene
118-74-1	Hexachlorobenzene
87-68-3	Hexachlorobutadiene
67-72-1	Hexachloroethane
193-39-5	Indeno (1,2,3-cd) Pyrene
78-59-1	Isophorone
91-57-6	2-Methylnaphthalene
95-48-7	2-Methylphenol (o-Cresol)
108-39-4	3-Methylphenol (m-Cresol)
106-44-5	4-Methylphenol (p-Cresol)
91-20-3	Naphthalene
98-95-3	Nitrobenzene
88755	2-Nitrophenol
62-75-9	N-Nitrosodimethylamine
621-64-7	N-Nitroso-di-n-Propylamine
95-95-4	2,4,5-Trichlorophenol
88062	2,4,6-Trichlorophenol
75-07-0	Acetaldehyde
107-18-6	Allyl alcohol
107-05-1	Allyl chloride
628-63-7	Amyl acetate
62-53-3	Aniline
100-47-0	Benzonitrile
100-44-7	Benzyl chloride
123-86-4	Butyl acetate
1395-284-6	Butylamine
417-030-3	Crotonaldehyde
110-82-7	Cyclohexane
119-4-65-6	Dichlorobenil
75-99-0	2,2-Dichloropropionic acid
109-89-7	Diethyl amine
99-65-0	1,3-Dinitrobenzene
124-40-3	Dimethyl amine
106-89-8	Epichlorohydrin
107-15-3	Ethylene diamine
106-93-4	Ethylene dibromide
98-01-1	Furfural
78-79-5	Isoprene
4250-446-1	Isopropanolamine dodecylbenzenesulfonate
115-32-2	Kelthane
203-265-7	Mercaptodimethur

APPENDIX A: continued

<u>CAS #</u>	<u>NAME</u>
74-93-1	Methyl mercaptan
80-62-6	Methyl methacrylate
75-04-7	Monoethyl amine
74-89-5	Monomethyl amine
1338-24-5	Napthenic acid
1321-12-6	Nitrotoluene
75-44-5	Phosgene
75-56-9	Propylene oxide
108-60-1	2,2'-Oxybis(1-Chloropropane)
91-22-5	Quinoline
108-46-3	Resorcinol
27323-41-7	Triethanolamine dodecylbenzenesulfonate
121-44-8	Triethylamine
75-50-3	Trimethylamine
1300-71-6	Xylenol

APPENDIX D: PESTICIDES

<u>CAS #</u>	<u>Name</u>
93-76-5	2,4,5-T
93-72-1	2,4,5-TP (Silvex)
94-75-7	2,4-D (2,4-Dichlorophenoxy acetic acid)
72-54-8	4,4'-DDD
72-55-9	4,4'-DDE
50-29-3	4,4'-DDT
309-00-2	Aldrin
319-84-6	<i>alpha</i> -BHC
959-98-8	<i>alpha</i> -Endosulfan
3655-10-7	Amobam
319-85-7	<i>beta</i> -BHC
33213-65-9	<i>beta</i> -Endosulfan
51026-28-9	Busan 40
128-03-0	Busan 85
133-06-2	captan
63-25-2	Carbaryl
1563-66-2	Carbofuran
57-74-9	Chlordane
2921-88-2	Chlorpyrifos
56-72-4	Coumaphos
319-86-8	<i>delta</i> BHC
8065-48-3	Demeton
333-41-5	Diazinon
1918-00-9	Dicamba
not found alone	Dichlorophenoxyacetate
62-73-7	Dichlorvos
60-57-1	Dieldrin
124-40-3	Dimethylamine
85-00-7	Diquat
298044	Disulfoton
330-54-1	Diuron
1031078	Endosulfan Sulfate
72-20-8	Endrin
7421-93-4	Endrin Aldehyde
563-12-1	Ethion
502-55-6	EXD
14484-64-1	Ferbam
98-01-1	Furfural
58899	<i>gamma</i> -BHC (Lindane)
86-50-0	Guthion
76448	Heptachlor
1024573	Heptachlor Epoxide
143-50-0	Kepone
137-41-7	KN Methyl
121-75-5	Malathion
137-42-8	Metham
72-43-5	Methoxychlor
298-00-0	Methyl Parathion
7786-34-7	Mevinphos
315-18-4	Mexacarbate
2385-85-5	Mirex
142-59-6	Nabam
138-93-2	Nabonate
300-76-5	Naled
56-38-2	Parathion
87-86-5	Pentachlorophenol
2312-35-8	Propargite

Appendix D: continued

<u>CAS #</u>	<u>Name</u>
75-56-9	Propylene oxide
121-21-1	Pyrethrins
57-24-9	Strychnine
137-26-8	Thiram
8001-35-2	Toxaphene
52-68-6	Trichlorofon
12122-67-7	Zineb
137-30-4	Ziram

*See* 360 CMR 10.004 and 360 CMR 10.024(1)(a) and (b).

10.24 Specific Discharge Limitations/Local Limits

- (1) Any discharge of the following materials is prohibited:
- (a) Into the Metropolitan Sewerage Service Area:
    - 1. Mercury (enforced at 0.001 mg/l);
    - 2. Polychlorinated Biphenyls (PCBs);
    - 3. Pesticides, unless the Authority determines upon request that the substance is acceptable for Discharge to the Sanitary Sewer under the criteria for exclusion or exemption in 40 CFR Parts 152 and 455, or that the substance is otherwise acceptable to Discharge, and that the substance would not otherwise violate 360 CMR 10.021 through 310 CMR 10.024; and
    - 4. Hexachlorobutadiene.
  - (b) Into the Clinton Sewerage Service Area:
    - 1. Mercury (enforced at 0.001 mg/l);
    - 2. Polychlorinated Biphenyls (PCBs);
    - 3. Pesticides, unless the Authority determines upon request that the substance is acceptable for discharge to the sanitary sewer under the criteria for exclusion or exemption in 40 CFR Parts 152 and 455, or that the substance is otherwise acceptable to discharge, and that the substance would not otherwise violate 360 CMR 10.021 through 310 CMR 10.024;
    - 4. Hexachlorobutadiene; and
    - 5. Substances listed in 360 CMR 10.000: *Appendix C*.
- (2) Any discharge of the following materials shall not exceed the daily maximum limit for that material:
- (a) Into the Metropolitan Sewerage Service Area:

<u>Material</u>	<u>Daily Maximum Limit (mg/l)</u>
Acrolein	0.15
Antimony (total)	10.0
Arsenic (total)	0.5
Benzene	0.3
Cadmium (total)	0.1
Chromium (hexavalent)	0.5
Chromium (total)	1.0
Copper (total)	1.0
Cyanide (total)	0.5
Formaldehyde	9.0
Lead (total)	0.2
Nickel (total)	1.0
Phenol	5.0
Selenium (total)	5.0
Silver (total)	2.0
Each Toxic Organic	1.0, unless elsewhere limited in 360 CMR 10.000 for the Metropolitan Sewerage Service Area
Total Toxic Organics	5.0
Vinyl Chloride	0.02
Vinylidene Chloride	0.3
Zinc (total)	1.0



10.024: continued

(b) Into the Clinton Sewerage Service Area:

<u>Material</u>	<u>Daily Maximum Limit mg/l</u>
Acrolein	0.5
Aluminum (total)	30.0
Arsenic (total)	0.5
Benzene	0.4
Bis(2-ethylhexyl)phthalate	0.2
Bromomethane	0.2
Cadmium (total)	0.5
Carbon disulfide	0.6
Carbon tetrachloride	0.1
Chromium (hexavalent)	1.0
Chromium (total)	5.0
Copper (total)	1.0
Cyanide (total)	1.0
Cyclohexane	0.6
1,1-Dichloroethylene	0.2
cis-1,3-Dichloropropene	0.6
trans-1,3-Dichloropropene	0.1
2,4-Dinitrotoluene	0.2
Formaldehyde	9.0
Hexachloroethane	0.2
Lead (total)	0.2
Nickel (total)	2.0
Nitrosamines	0.1
N-Nitrosodibutylamine	0.1
N-Nitrosodiethylamine	0.1
N-Nitrosodimethylamine	0.2
N-Nitrosodiphenylamine	0.5
Pentachlorobenzene	0.2
Selenium (total)	1.0
Silver (total)	1.0, except 2.0 for a Group Permit for Photo Processing and Printing Operations, and a Combined Permit
1,2,4,5-Tetrachlorobenzene	0.1
Trichlorofluoromethane	0.3
Each Toxic Organic	1.0, unless elsewhere limited in 360 CMR 10.000 for the Clinton Sewerage Service Area
Total Toxic Organics	5.0
Zinc	5.0

(3) The Daily Maximum Limit shall be determined on the basis of a Composite Sample, except a Grab Sample or Samples may be used in the following circumstances:

- (a) for a batch discharge, when the Grab Sample would be fairly representative of the batch as a whole;
- (b) for pollutants that are not amenable to composite sampling of an industrial wastestream by use of an automatic wastewater sampler, such as hexavalent chromium and volatile organics; or
- (c) when the Authority determines it is not feasible or appropriate to take a Composite Sample, such as when the discharge is of too short duration for automatic composite sampling or the sampling location is inaccessible for an automatic wastewater sampler.

10.24 : continued

A Composite Sample shall be taken at preselected intervals throughout the time in a day (or in a consecutive 24-hour period over two days when there is a continuous discharge of at least 24 hours over the course of the two days) during which the wastewater is discharged, except a shorter time period may be used if that shorter time period encompasses all or most of the wastewater discharge that day (or consecutive 24-hour period when there is a continuous discharge over the course of two days) or if a shorter period is authorized by the Authority. A batch discharge may have a Composite Sample taken throughout the discharge of the batch. A flow proportioned Composite Sample shall be taken, except a time interval Composite Sample may be taken when the Authority determines it is not feasible or appropriate to take a flow proportioned Composite Sample.

If a Grab Sample may appropriately be used, and more than one Grab Sample of a Discharge is taken during the day, the Daily Maximum Limit shall be measured by either the mathematical average of the analytical results of the Grab Samples or the analytical result of a composite of the Grab Samples.

10.25 : Dilution Prohibition

No person shall achieve, or attempt to achieve, compliance with 360 CMR 10.000 by diluting a Discharge instead of using proper pretreatment. The increased use of process water in place of proper treatment shall be considered dilution prohibited by 360 CMR 10.000.

10.26 : Compliance Measurement Location

All limitations imposed by 360 CMR 10.000 shall be applied at the end of the Pretreatment process line, at the end of the process line if there is no Pretreatment, or at or near the discharge location if there is no Pretreatment or process line. This shall not be construed to authorize a Person to introduce a pollutant into a wastestream after the compliance measurement location; rather, a sample taken at the compliance measurement location is intended to measure the pollutants in a discharge to the sewer before dilution of the wastestream.

Where it deems appropriate, the Authority may by permit or order impose alternative limits or compliance measurement locations to assure compliance with 360 CMR 10.000 and with federal, state, and local requirements. This may include use of the Combined Wastestream Formula when authorized by EPA regulations or use of a dilution factor when more than one stream is combined.

The Authority may require samples from individual process waste streams whether such waste streams are pretreated prior to discharge or not. The Authority may require that compliance measurement locations be clearly marked and/or photographed.

## APPENDIX B: CLINTON SEWERAGE SERVICE AREA TOXIC ORGANICS

<u>CAS #</u>	<u>Name</u>
83-32-9	Acenaphthene
208-95-8	Acenaphthylene
75-07-0	Acetaldehyde
107-18-6	Allyl alcohol
107-05-1	Allyl chloride
628-63-7	N-Amyl acetate
62-53-3	Aniline
120-12-7	Anthracene
191-24-2	Benzo[g,h,i]perylene
50-32-8	Benzo[a]pyrene
100-47-0	Benzonitrile
100-44-7	Benzyl chloride
111-91-1	Bis(2-chloroethoxy)methane
75-27-4	Bromodichloromethane
75-25-2	Bromoform
101-55-3	4-Bromophenyl phenyl ether
123-86-4	N-Butyl acetate
109-73-9	N-Butylamine
85-68-7	Butylbenzylphthalate
27134-26-5	Chloroaniline
108-90-7	Chlorobenzene
124-48-1	Chlorodibromomethane
59-50-7	p-Chloro-m-cresol
75-00-3	Chloroethane
110-75-8	2-Chloroethylvinyl ether
67-66-3	Chloroform
74-87-3	Chloromethane
91-58-7	2-Chloronaphthalene
95-57-8	2-Chlorophenol
7005-72-3	4-Chlorophenyl phenyl ether
4170-30-3	Crotonaldehyde
132-64-9	Dibenzofuran
1194-65-6	Dichlorobenil
95-50-1	1, 2-Dichlorobenzene
541-73-1	1, 3-Dichlorobenzene
106-46-7	1, 4-Dichlorobenzene
75-71-8	Dichlorodifluoromethane
75-34-3	1,1-Dichloroethane
107-06-2	1,2-Dichloroethane
156-60-5	trans -1,2-Dichloroethylene
120-83-2	2,4-Dichlorophenol
78-87-5	1,2-Dichloropropane
542-75-6	1,3-Dichloropropene
75-99-0	2,2-Dichloropropionic acid
109-89-7	Diethyl amine
84-66-2	Diethylphthalate
105-67-9	2,4-Dimethylphenol
131-11-3	Dimethylphthalate
51-28-5	2,4-Dinitrophenol
84-74-2	Di-n-butylphthalate
534-52-1	4,6-Dinitro-o-cresol
606-20-2	2,6 Dinitrotoluene
117-84-0	Di-n-octyl phthalate
106-89-8	Epichlorohydrin
100-41-4	Ethylbenzene
107-15-3	Ethylene diamine
106-93-4	Ethylene dibromide

APPENDIX B: continued

206-44-0	Fluoranthene
86-73-7	Fluorene
78-59-1	Isophorone
68514-39-6	Isoprene
42504-46-1	Isopropanolamine dodecylbenzenesulfonate
115-32-2	Kelthane
2032-65-7	Mercaptodimethur
534-52-1	2-Methyl-4,6-dinitrophenol
79-09-2	Methylene chloride
74-93-1	Methyl mercaptan
80-62-6	Methyl methacrylate
1321-94-4	Methylnaphthalene
95-48-7	2-Methylphenol
108-39-4	3-Methylphenol
106-44-5	4-Methylphenol
75-04-7	Monoethylamine
74-89-5	Monomethylamine
91-20-3	Naphthalene
1338-24-5	Naphthenic acid
98-95-3	Nitrobenzene
88-75-5	2-Nitrophenol
100-02-7	4-Nitrophenol
930-55-2	N-Nitrosopyrrolidine
1321-12-6	Nitrotoluene
85-01-8	Phenanthrene
108-95-2	Phenol
75-44-5	Phosgene
129-00-0	Pyrene
108-60-1	2,2'-Oxybis(1-Chloropropane)
91-22-5	Quinoline
108-46-3	Resorcinol
128-04-1	Sodium dimethyldithiocarbamate
100-42-5	Styrene
79-34-5	1,1,2,2-Tetrachloroethane
127-18-4	Tetrachloroethylene
108-88-3	Toluene
120-82-1	1,2,4-Trichlorobenzene
71-55-6	1,1,1-Trichloroethane
79-00-5	1,1,2-Trichloroethane
79-01-6	Trichloroethylene
27323-41-7	Triethanolamine dodecylbenzenesulfonate
121-44-8	Triethylamine
75-50-3	Trimethylamine
108-05-4	Vinyl acetate
1300-71-6	Xylenol

See 360 CMR 10.004 and 360 CMR 10.024(2)(b).

## APPENDIX C: CLINTON SEWERAGE SERVICE AREA PROHIBITED POLLUTANTS

<u>CAS #</u>	<u>Name</u>
107-13-1	Acrylonitrile
92-87-5	Benzidine
50-32-8	Benzo[a]pyrene
56-55-3	Benzo[a]anthracene
205-99-5	Benzo[b]fluoranthene
207-08-9	Benzo[k]fluoranthene
111-44-4	Bis(2-chloroethyl)ether
218-01-9	Chrysene
53-70-3	Dibenzo[a,h]anthracene
91-94-1	3,3-Dichlorobenzidine
122-66-7	1,2-Diphenylhydrazine
118-74-1	Hexachlorobenzene
608-73-1	Hexachlorocyclo-hexane-Technical
77-47-4	Hexchlorocyclopentadiene
193-39-5	Indeno(1,2,3-cd)pyrene
621-64-7	N-Nitrosodi-n-propylamine
688-73-3	Tributyltin
95-95-4	2,4,5-Trichlorophenol
88-06-2	2,4,6-Trichlorophenol
75-01-4	Vinyl chloride
1330-20-7	Xylene (total)

See 360 CMR 10.024(1)(b).

## APPENDIX D: PESTICIDES

<u>CAS #</u>	<u>Name</u>
93-76-5	2,4,5-T
93-72-1	2,4,5-TP (Silvex)
94-75-7	2,4-D (2,4-Dichlorophenoxy acetic acid)
72-54-8	4,4'-DDD
72-55-9	4,4'-DDE
50-29-3	4,4'-DDT
309-00-2	Aldrin
319-84-6	<i>alpha</i> -BHC
959-98-8	<i>alpha</i> -Endosulfan
3655-10-7	Amobam
319-85-7	<i>beta</i> -BHC
33213-65-9	<i>beta</i> -Endosulfan
51026-28-9	Busan 40
128-03-0	Busan 85
133-06-2	captan
63-25-2	Carbaryl
1563-66-2	Carbofuran
57-74-9	Chlordane
2921-88-2	Chlorpyrifos
56-72-4	Coumaphos
319-86-8	<i>delta</i> BHC
8065-48-3	Demeton
333-41-5	Diazinon
1918-00-9	Dicamba
not found alone	Dichlorophenoxyacetate
62-73-7	Dichlorvos
60-57-1	Dieldrin
124-40-3	Dimethylamine
85-00-7	Diquat
298044	Disulfoton
330-54-1	Diuron
1031078	Endosulfan Sulfate
72-20-8	Endrin
7421-93-4	Endrin Aldehyde
563-12-1	Ethion
502-55-6	EXD
14484-64-1	Ferbam
98-01-1	Furfural
58899	<i>gamma</i> -BHC (Lindane)
86-50-0	Guthion
76448	Heptachlor
1024573	Heptachlor Epoxide
143-50-0	Kepone
137-41-7	KN Methyl
121-75-5	Malathion
137-42-8	Metham
72-43-5	Methoxychlor
298-00-0	Methyl Parathion
7786-34-7	Mevinphos
315-18-4	Mexacarbate
2385-85-5	Mirex
142-59-6	Nabam
138-93-2	Nabonate
300-76-5	Naled
56-38-2	Parathion
87-86-5	Pentachlorophenol
2312-35-8	Propargite

Appendix D: continued

<u>CAS #</u>	<u>Name</u>
75-56-9	Propylene oxide
121-21-1	Pyrethrins
57-24-9	Strychnine
137-26-8	Thiram
8001-35-2	Toxaphene
52-68-6	Trichlorofon
12122-67-7	Zineb
137-30-4	Ziram

*See* 360 CMR 10.004 and 360 CMR 10.024(1)(a) and (b).

**MASSACHUSETTS WATER RESOURCES AUTHORITY  
CHARLESTOWN NAVY YARD**

**100 FIRST AVENUE  
CHARLESTOWN, MA 02129**

**617-242-6000**

**[WWW.MWRA.COM](http://WWW.MWRA.COM)**

