

MPDH Sample Results: 2019 Q1 (January - March)

<u>Case/Sample ID</u>	<u>Project Name</u>	<u>Sample Address</u>	<u>Collection Date</u>	<u>Results</u>	<u>Units</u>
433531	DPH-PB	1	1/7/19	< 1.00	ppb
433531	DPH-PB	1A	1/7/19	< 1.00	ppb
MA035-00042095	DPH-PB	2	1/11/19	< 1.00	ppb
MA035-00042095	DPH-PB	2A	1/11/19	< 1.00	ppb
433885	DPH-PB	3	1/17/19	< 1.00	ppb
433885	DPH-PB	3A	1/17/19	< 1.00	ppb
434305	DPH-PB	4	1/29/19	1.08	ppb
434305	DPH-PB	4A	1/29/19	1.18	ppb
433953	DPH-PB	5	1/31/19	< 1.00	ppb
433953	DPH-PB	5A	1/31/19	< 1.00	ppb
432532	DPH-PB	6	2/4/19	< 1.00	ppb
432532	DPH-PB	6A	2/4/19	< 1.00	ppb
434315	DPH-PB	7	2/8/19	< 1.00	ppb
434315	DPH-PB	7A	2/8/19	< 1.00	ppb
434307	DPH-PB	8	2/10/19	< 1.00	ppb
434307	DPH-PB	8A	2/10/19	1.23	ppb
C-434472	DPH-PB	9	2/22/19	< 1.00	ppb
C-434472	DPH-PB	9A	2/22/19	< 1.00	ppb
434912	DPH-PB	10	2/24/19	< 1.00	ppb
434912	DPH-PB	10A	2/24/19	< 1.00	ppb
433187	DPH-PB	11	2/25/19	< 1.00	ppb
433187	DPH-PB	11A	2/25/19	< 1.00	ppb
434729	DPH-PB	12	2/25/19	3.90	ppb
434729	DPH-PB	12A	2/25/19	4.29	ppb
435755	DPH-PB	13	2/25/19	< 1.00	ppb
435755	DPH-PB	13A	2/25/19	< 1.00	ppb
434565	DPH-PB	14	2/27/19	9.62	ppb
434565	DPH-PB	14A	2/27/19	5.29	ppb
434911	DPH-PB	15	2/27/19	4.62	ppb
434911	DPH-PB	15A	2/27/19	< 1.00	ppb
C-432116	DPH-PB	16	3/2/19	5.67	ppb
C-432116	DPH-PB	16A	3/2/19	19.10*	ppb
435963	DPH-PB	17	3/12/19	16.40*	ppb
435963	DPH-PB	17A	3/12/19	5.39	ppb
435104	DPH-PB	18	3/13/19	< 1.00	ppb
435104	DPH-PB	18A	3/13/19	< 1.00	ppb
435838	DPH-PB	19	3/14/19	< 1.00	ppb
435838	DPH-PB	19A	3/14/19	< 1.00	ppb
435774	DPH-PB	20	3/15/19	< 1.00	ppb
435774	DPH-PB	20A	3/15/19	< 1.00	ppb
435797	DPH-PB	21	3/21/19	< 1.00	ppb
435797	DPH-PB	21A	3/21/19	< 1.00	ppb
432116	DPH-PB	22	3/30/19	7.00	ppb
432116	DPH-PB	22A	3/30/19	35.40*	ppb

- **ppb** = parts per billion or µg/L
- “<” means that the lead level in the sample was non-detectable at the indicated sensitivity of the instrument and analytical method. Can also be stated as “less than the detection limit.”